CITY OF MUSCATINE, IOWA

CONSTRUCTION PLANS FOR

2ND & MULBERRY ROUNDABOUT

PLAN REVISIONS ISSUED FOR DATE

SHEET INDEX

UTILITY CONTACTS

Muscatine Public Works Department Muscatine IA 52761 Jim Edgmond City Engineer ph. 563-263-8933

Sewer Department 1459 Washington St Muscatine, IA 52761 Matt Chandler

Street Department 1459 Washington St Muscatine, IA 52761

Muscatine Power & Water 3205 Cedar St Muscatine, IA 52761 Nancy Streu ph. 563-263-2631

Eastern Iowa Light & Power 600 Fast 5th St Wilton, IA 52778 Chad Ruden ph. 563-529-3727

3205 Cedar St Muscatine, IA 52761 Communication Lines: Century Link 3908 Utica Ridge Rd Bettendorf, IA 52722 Antonio Glessner ph. 563-355-6402


Windstream 1450 N. Center Point Rd Hiawatha, IA 52233 Joe Green ph. 319-790-7510


Muscatine Power & Water 3205 Cedar St Muscatine, IA 52761 Tom Lewis ph. 563-263-2631


400 East 14th St Des Moines, IA 50319 Kent Frie ph. 515-725-4725

Gas Mains: **Alliant Energy** 215 Oak St Muscatine, IA 52761 John Carney ph. 563-288-3322

Muscatine Power & Water ph. 563-263-2631







SHEET TITLE

T.01 - T.05 U.01 - U.04 LANDSCAPE DETAILS THIS PLAN SET CONTAINS 65 SHEETS.



SHEET NO.

M.14

MAP OF A PORTION OF THE

CITY OF MUSCATINE

MSS.01 - MSS.03

N.01 - N.02

S.01 - S.09

CITY OF MUSCATINE **ENGINEERING DEPARTMENT** MUSCATINE, IOWA

A Resolution of Necessity regarding this project was approved by the Muscatine City Council on James Edgmond City Engineer

STREET LIGHT FOUNDATION DETAIL

STORM & SANITARY PLAN & PROFILE

PAVEMENT MARKINGS & SIGNS

SIDEWALK RAMP LAYOUT

LANDSCAPE PLAN



THE SUBSURFACE UTILITY INFORMATION IN THIS PLAN IS UTILITY QUALITY LEVEL D. THIS UTILITY QUALITY LEVEL WAS DETERMINED ACCORDING TO THE GUIDELINES OF CI/ASCE 38-02. ENTITLED "STANDARD GUIDELINES FOR THE COLLECTION AND DEPICTION OF EXISTING SUBSURFACE


GOVERNING SPECIFICATIONS


THE 2018 EDITION OF THE "IOWA STATEWIDE URBAN STANDARD SPECIFICATIONS FOR PUBLIC IMPROVEMENTS" SHALL GOVERN.

IOWA DEPARTMENT OF TRANSPORTATION "STANDARD SPECIFICATIONS FOR HIGHWAY AND BRIDGE CONSTRUCTION". SERIES 2015 AND ALL CURRENT GENERAL SUPPLEMENTAL SPECIFICATIONS AND MATERIALS INSTRUCTIONAL MEMORANDUM SHALL GOVERN AS REFERENCED.

ALL APPLICABLE FEDERAL, STATE, AND LOCAL LAWS AND ORDINANCES WILL BE COMPLIED WITH IN THE CONSTRUCTION OF THIS PROJECT.









I HERERY CERTIEV THAT THIS ENGINEERING DOCUMENT WAS THEREBY CERTIFY THAT I HIS ENGINEERING DOCUMENT WAS PREPARED BY ME OR UNDER MY DIRECT PERSONAL SUPERVISION AND THAT I AM A DUY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF IOWA.

ADRIANT HOLMES P.F. 17935 REG. NO.

PAGES OR SHEETS COVERED BY THIS SEAL

MY LICENSE RENEWAL DATE IS DECEMBER 31, 2019

ALL SHEETS - EXCEPT M-SERIES, T-SERIES, AND U-SERIES

855 WRIGHT BROTHERS BLVD SW, SUITE 2A CEDAR RAPIDS, IOWA 52404 Phone: (319) 362-3219 www.bolton-menk.com

CITY OF MUSCATINE, IOWA 2ND & MULBERRY ROUNDABOUT

11/21/2018

SHEET

A.01

TITLE SHEET

EXISTING

0	IRON PIPE MONUMENT SE	т [ELECTRIC TRANSFORMER	0	SEMAPHORE TRAFFIC LIGHT
•	MONUMENT FOUND		□EV	EXHAUST VENT	⊕	SIGNAL BOX
•	CAST IRON MONUMENT F	OUND	~	FLAG POLE	0	SIGNAL POLE - RR
	STONE MONUMENT FOUN	ND	0	FILL PIPE	•	SOIL BORING
\triangle	POST SET	(©	GAS MANHOLE	L	SIREN
+	BENCH MARK	1	©	GAS REGULATOR	無	SPRINKLER HEAD
© AS	AUTO SPRINKLER		⊗	GAS VALVE	D	STORM MANHOLE
0	ANTENNA		G	GAS METER	T	TELEPHONE MANHOLE
\otimes	AIR CONDITIONER	[ACCESS GRATE		PUBLIC TELEPHONE
(ANCHOR		Ė.	HANDICAPPED PARKING		TILE INLET
⊚ AP	AIR PUMP		H	HAND HOLE		TILE RISER
\triangleright	APRON	-	¢	HYDRANT	0	TRAFFIC ARM BARRIER
þ	BASKETBALL HOOP		⊗	IRRIGATION CONTROL VALVE		TRAFFIC SIGN
-B-	BIRD FEEDER	_		LIGHT DECORATIVE	E 芜芜 3	TRANSMISSION TOWER
	BENCH	=	*	LIGHT POLE	Ø	UTILITY POLE
0	BRACE POLE	Ó	MB	MAILBOX		VACUUM
\mathbb{Z}	CATCH BASIN		M	METER	\bigcirc	VENT PIPE
0	CLOTHES LINE POLE		P	POST	\Leftrightarrow	DECIDUOUS TREE
Δ	CONTROL POINT	(0	MANHOLE	关	CONIFEROUS TREE
0	CLEAN OUT	(L	LIFT STATION MANHOLE	(\$)	STUMP
⊞ CP	COMMUNICATION PEDES	ΓAL	₩	MONITORING WELL		BUSH
8	CURB STOP VALVE	4	A	ORDER MICROPHONE		WELL
\Diamond	DITCH TOP	I		PARK GRILL	W	WATER MANHOLE
0	DRINKING FOUNTAIN]		GAS PUMP	W	WATER METER
D	DOWN SPOUT		⊗	POST INDICATOR VALVE	\otimes	WATER SPIGOT
E	ELECTRIC MANHOLE	4	\Box	PARKING METER	M	WATER VALVE
E	ELECTRIC METER	(S	SANITARY MANHOLE	عللد	WETLAND / MARSH
⊞E	ELECTRIC PEDESTAL		*	SATELLITE DISH	Δ	WETLAND - DELINEATED
		OVERHEAR	ELECTRIC LINE			FACENAENTLINE
			ELECTRIC LINE UND ELECTRIC LI			EASEMENT LINE
			UND ELECTRIC LI	NE	xx	BUILDING SETBACK LINE
		GAS LINE	LINE	xx-	xx	FENCE LINE
		FIBER OPTIC	UND COMMUNIO	CATIONS LINE	-0	GUARD RAIL
				CATIONS LINE —————		ACCESS CONTROL LINE
			UTILITY LINE			CENTERLINE PROPERTY (LOT LINE
		WATER SYST				PROPERTY / LOT LINE
		STORM SEW TILE LINE	/EN			ROAD RIGHT-OF-WAY LINE RAILROAD RIGHT-OF-WAY LINE
		SANITARY SI	E\MED			GRAVEL EDGE
		SANITARY F				BITUMINOUS EDGE
		CULVERT	OKCLIVIAIN			CONCRETE EDGE
			ATE CONTOURS			CURB & GUTTER
		INDEX CONT				WATER EDGE
		COUNTY LIN				WATER CENTERLINE
		CITY LIMITS	·-			HIGHWATER LINE
		SIXTEENTH I	INF			WETLAND EDGE
		QUARTER LI				SWALE CENTERLINE
	· ·	SECTION LIN				RAILROAD TRACKS
	•	ADJACENT L				TREE DRIP LINE
	•				· · · —	

PROPOSED


22+00	ALIGNMENT/CENTERLINE —
	RIGHT-OF-WAY LINE —
	TEMPORARY EASEMENT
	CONSTRUCTION LIMITS
	CURB & GUTTER
	CURB & GUTTER (OUT)
	BITUMINOUS EDGE
	CONCRETE EDGE
	GRAVEL EDGE
	SILT FENCE-PREASSEMBLED
	SILT FENCE-HEAVY DUTY
\mathcal{O}	EROSION PROTECTION AT INLET
•	MANHOLE
	CATCH BASIN
	STORM INLET
•	APRON
	STORM SEWER
	PERFORATED PIPE DRAIN
	STORM DRAIN TILE
>	CULVERT W/APRON
1	STORM MANHOLE NUMBER
	SANITARY SEWER
	SANITARY FORCEMAIN
	SANITARY SEWER SERVICE
0	SANITARY LIFT STATION
	SANITARY MANHOLE
A A	SANITARY MANHOLE NUMBER


ı——ı——ı—	WATERMAIN
	WATERMAIN SERVICE
•	WATER SYSTEM MANHOL
♦ ♦•	HYDRANT
.	HYDRANT W/ VALVE
H	VALVE
8	CURBSTOP
<<	BEND
H	REDUCER
4	CROSS
ŀ	TEE
c	CAP
=	SLEEVE
	SIGN
*	LIGHT POLE
-	GUARD RAIL
⊕ B-?	SOIL BORING
3 16	WETLAND
•	BUSH
☆	CONIFEROUS TREE
O	DECIDUOUS TREE
⊕	LIGHT POLE
•	





REV	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
			JGS	2ND & MULBERRY ROUNDABOUT
			CHECKED	LEGEND
			ALH	LEGEND






TYPICAL DIMENSIONS AT STATIONS


LOCATION				WII	OTHS				TYPICAL
STA	SWL	PL	TA	L	М	R	PR	SWR	
5+85	22.5	0	0	12	0	12	11	6	1
6+25	10	12.5	0	12	0	12	10	6	1
6+50	10	12.5	0	14	0	14	7.75	6	1
7+50	6	20	0	18	11	18	5.25	6	2
8+00	6	20.5	4	20	24	20	8.75	6	2
9+50	6	20	7	26	22.5	24.5	5	5	2
10+00	6	27.25	0	19	11	17	3	5	2
10+50	6	14	0	19	3	17	2	5	2
11+00	13	0	0	15	0	15	0	5.5	1

FROM STA: 5+85.00 TO: 7+11.00 FROM STA: 10+49.33 TO: 11+28.70

MULBERRY AVENUE AND 2ND STREET TYPICAL SECTION
TYPICAL SECTION NOT TO SCALE











TYPICAL DIMENSIONS AT STATIONS

LOCATION		WIDTHS							TYPICAL	
STA	SWL	PL	L	A-L	С	A-R	R	PR	SWR	
8+75	0	0	25	17	46	17	25	0	0	1





ISSUED FOR	DATE	DESIGNED	CITY OF MUSCATINE, IOWA
		DRAWN	2ND & MULBERRY ROUNDABOUT
		RWW	ZIVD & MICEDENIN NOCKDADOOT
		10000	
		CHECKED	TYPICAL SECTIONS
			I TFICAL SECTIONS
		ALH	





ITEM NO.		ESTIMATED PROJECT QUANTITIES			
	ITEM CODE	ITEM	UNIT	TOTAL	AS BUIL'
SECTION 101	10 - GENERAL PRO	VISIONS			
1	1070-206-A-0	TRAFFIC CONTROL	LS	1	
SECTION 201	10 - EARTHWORK,	SUBGRADE, AND SUBBASE			
2	2010-108-C-0	CLEARING AND GRUBBING	LS	1	
3	2010-108-D-3	TOPSOIL, OFF SITE	CY	200	
4	2010-108-D-X	TOPSOIL, OFF SITE, LOAD & SPREAD	CY	800	
5	2010-108-E-0	EXCAVATION, CLASS 13	CY	2,900	
6	2010-108-G-0	SUBGRADE PREPARATION	SY	5,850	
7	2010-108-G-X	SUBGRADE STABILIZATION, 12-INCH	CY	500	
8	2010-108-H-0	SUBGRADE TREATMENT, GEOTEXTILE	SY	400	
9	2010-108-I-2	SUBBASE, MODIFIED SUBBASE, 6-INCH	SY	5,850	
10	2010-108-X-2	REMOVAL, HYDRANT	EA	3	
11	2010-108-X-3	REMOVAL, TRAFFIC SIGNAL FOUNDATION	EA	3	
12	2010-108-X-4	REMOVAL, STREET LIGHT POLES AND FOUNDATIONS	EA LF	13	
13	2010-108-X-5	EXPLORATORY EXCAVATION	LF	100	
SECTION 301	10 - TRENCH EXCA	VATION AND BACKFILL			
14	3010-108-C-0	TRENCH FOUNDATION	TON	200	
15	3010-108-D-0	REPLACEMENT OF UNSUITABLE BACKFILL MATERIAL	CY	2,600	
16	3010-108-D-0	REPLACEMENT OF UNSUITABLE BACKFILL MATERIAL, COHESIVE BACKFILL	CY	320	
17	3010-108-X-X	RAVINE FILL AREA EARTHWORK MANAGEMENT	CY	2,920	
18	3010-108-F-0	TRENCH COMPACTION TESTING	LS	1	
SECTION 404	A CANITARY OF	WEDG			
	10 - SANITARY SE		LF	690	
19	4010-108-A-1 4010-108-E-0	SANITARY SEWER GRAVITY MAIN, TRENCHED, PVC, 8 INCH SANITARY SEWER SERVICE STUB, PVC, 6"	LF	680 40	
21	4010-108-E-0 4010-108-H-0	REMOVAL OF SANITARY SEWER, LESS THAN 36"	LF	690	
22	4010-108-K-0	SANITARY SEWER ABANDONMENT, 8" DIA.	LF	205	
	1010 100 110	or and the server of the serve		200	
SECTION 402	20 - STORM SEWE	RS			
23	4020-108-A-1	STORM SEWER, TRENCHED, RCP, 15 INCH	LF	970	
24	4020-108-A-1	STORM SEWER, TRENCHED, RCP, 18 INCH	LF	180	
25	4020-108-C-0	REMOVAL OF STORM SEWER, LESS THAN 36 INCH	LF	8	
26	4040-108-A-0	SUBDRAIN, HPDE, 6 INCH	LF	1,490	
27	4040-108-C-0 4040-108-D-0	SUBDRAIN CLEANOUT SUBDRAIN OUTLETS AND CONNECTIONS	EA EA	7	
20	4040-100-D-0	OUBLIANT OUTLETO AND CONTROLLONG	LA	,	
SECTION 501	10 - PIPE AND FITT	INGS			
29	5010-108-A-1	WATER MAIN, TRENCHED, FUSED HDPE, 12"	LF	477	
30	5010-108-A-1	WATER MAIN, TRENCHED, FUSED HDPE, 10"	LF	26	
	5010-108-A-1	WATER MAIN, TRENCHED, FUSED HDPE, 6"	LF	238	
31			LF		
32	5010-108-C-1	CUT AND CAP, 10"	EA	1	
32 33	5010-108-C-1	CUT AND CAP, 12"	EA EA	2	
32			EA		
32 33 34	5010-108-C-1 5010-108-D-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH	EA EA	2	
32 33 34	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES	EA EA	2	
32 33 34 SECTION 502	5010-108-C-1 5010-108-D-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH	EA EA LF	2 470	
32 33 34 SECTION 502 35	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12"	EA EA LF	2 470 2	
32 33 34 SECTION 502 35 36 37	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0 5020-108-H-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12" TAPPING SLEEVE AND VALVE, 10"x10" HYDRANT, ASSEMBLY	EA EA EA EA	2 470 2 1	
32 33 34 SECTION 502 35 36 37	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0 5020-108-B-0 5020-108-H-0 10 - STRUCTURES	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12" TAPPING SLEEVE AND VALVE, 10"x10" HYDRANT, ASSEMBLY FOR SANITARY AND STORM SEWERS	EA EA EA EA	2 470 2 1 1	
32 33 34 BECTION 502 35 36 37 BECTION 601 38	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0 5020-108-H-0 5020-108-H-0 10 - STRUCTURES 6010-108-A-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12" TAPPING SLEEVE AND VALVE, 10"x10" HYDRANT, ASSEMBLY FOR SANITARY AND STORM SEWERS MANHOLE TYPE SW-301, 60 INCH	EA EA EA EA	2 470 2 1 1	
32 33 34 SECTION 502 35 36 37 SECTION 601 38 39	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0 5020-108-H-0 5020-108-H-0 10 - STRUCTURES 6010-108-A-0 6010-108-A-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12" TAPPING SLEEVE AND VALVE, 10"x10" HYDRANT, ASSEMBLY FOR SANITARY AND STORM SEWERS MANHOLE TYPE SW-301, 60 INCH MANHOLE TYPE SW-401, 60 INCH	EA EA EA EA EA	2 470 2 1 1 2 1	
32 33 34 35 35 36 37 38 ECTION 601 38 39 40	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0 5020-108-H-0 5020-108-H-0 10 - STRUCTURES 6010-108-A-0 6010-108-A-0 6010-108-B-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12" TAPPING SLEEVE AND VALVE, 10"x10" HYDRANT, ASSEMBLY FOR SANITARY AND STORM SEWERS MANHOLE TYPE SW-301, 60 INCH MANHOLE TYPE SW-401, 60 INCH INTAKE TYPE SW-501	EA EA EA EA EA EA	2 470 2 1 1 2 1 2 1 14	
32 33 34 35 36 37 38 38 39 40 41	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0 5020-108-H-0 5020-108-H-0 10 - STRUCTURES 6010-108-A-0 6010-108-B-0 6010-108-B-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12" TAPPING SLEEVE AND VALVE, 10"x10" HYDRANT, ASSEMBLY FOR SANITARY AND STORM SEWERS MANHOLE TYPE SW-301, 60 INCH MANHOLE TYPE SW-401, 60 INCH INTAKE TYPE SW-501 INTAKE TYPE SW-503	EA EA EA EA EA EA EA EA	2 470 2 1 1 2 1 2 1 14 1	
32 33 34 35 35 36 37 38 39 40 41 42	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0 5020-108-H-0 5020-108-H-0 10 - STRUCTURES 6010-108-A-0 6010-108-B-0 6010-108-B-0 6010-108-B-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12" TAPPING SLEEVE AND VALVE, 10"x10" HYDRANT, ASSEMBLY FOR SANITARY AND STORM SEWERS MANHOLE TYPE SW-301, 60 INCH MANHOLE TYPE SW-401, 60 INCH INTAKE TYPE SW-501 INTAKE TYPE SW-503 MANHOLE ADJUSTMENT, MAJOR	EA	2 470 2 1 1 2 1 14 1 1	
32 33 34 35 36 37 38 38 39 40 41	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0 5020-108-H-0 5020-108-H-0 10 - STRUCTURES 6010-108-A-0 6010-108-B-0 6010-108-B-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12" TAPPING SLEEVE AND VALVE, 10"x10" HYDRANT, ASSEMBLY FOR SANITARY AND STORM SEWERS MANHOLE TYPE SW-301, 60 INCH MANHOLE TYPE SW-401, 60 INCH INTAKE TYPE SW-501 INTAKE TYPE SW-503	EA EA EA EA EA EA EA EA	2 470 2 1 1 2 1 2 1 14 1	
32 33 34 35 36 37 38 39 40 41 42 43	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0 5020-108-H-0 10 - STRUCTURES 6010-108-A-0 6010-108-B-0 6010-108-B-0 6010-108-F-0 6010-108-H-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12" TAPPING SLEEVE AND VALVE, 10"x10" HYDRANT, ASSEMBLY FOR SANITARY AND STORM SEWERS MANHOLE TYPE SW-301, 60 INCH MANHOLE TYPE SW-401, 60 INCH INTAKE TYPE SW-501 INTAKE TYPE SW-503 MANHOLE ADJUSTMENT, MAJOR REMOVE MANHOLE	EA	2 470 2 1 1 2 1 14 1 1 1 4	
32 33 34 SECTION 502 35 36 37 SECTION 601 38 39 40 41 42 43 44	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0 5020-108-H-0 5020-108-H-0 10 - STRUCTURES 6010-108-A-0 6010-108-B-0 6010-108-B-0 6010-108-B-0 6010-108-H-0 6010-108-H-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12" TAPPING SLEEVE AND VALVE, 10"x10" HYDRANT, ASSEMBLY FOR SANITARY AND STORM SEWERS MANHOLE TYPE SW-301, 60 INCH INTAKE TYPE SW-401, 60 INCH INTAKE TYPE SW-503 MANHOLE ADJUSTMENT, MAJOR REMOVE MANHOLE REMOVE INTAKE MENT CONCRETE PAVEMENT	EA E	2 470 2 1 1 1 2 1 14 1 1 4 6	
32 33 34 SECTION 502 35 36 37 SECTION 601 38 39 40 41 42 43 44 SECTION 701 45	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0 5020-108-B-0 5020-108-H-0 10 - STRUCTURES 6010-108-A-0 6010-108-B-0 6010-108-B-0 6010-108-B-0 6010-108-H-0 10 - PORTLAND CE 7010-108-A-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12" TAPPING SLEEVE AND VALVE, 10"x10" HYDRANT, ASSEMBLY FOR SANITARY AND STORM SEWERS MANHOLE TYPE SW-301, 60 INCH MANHOLE TYPE SW-401, 60 INCH INTAKE TYPE SW-503 MANHOLE ADJUSTMENT, MAJOR REMOVE MANHOLE REMOVE INTAKE MENT CONCRETE PAVEMENT PAVEMENT, PCC, 10 INCH	EA EA LF EA	2 470 2 1 1 1 2 1 14 1 1 4 6	
32 33 34 SECTION 502 35 36 37 SECTION 601 38 39 40 41 42 43 44	5010-108-C-1 5010-108-D-0 20 - VALVES, FIRE 5020-108-B-0 5020-108-H-0 5020-108-H-0 10 - STRUCTURES 6010-108-A-0 6010-108-B-0 6010-108-B-0 6010-108-B-0 6010-108-H-0 6010-108-H-0	CUT AND CAP, 12" WATER SERVICE STUB, COPPER, 1-INCH HYDRANTS, AND APPURTENANCES TAPPING SLEEVE AND VALVE, 12"x12" TAPPING SLEEVE AND VALVE, 10"x10" HYDRANT, ASSEMBLY FOR SANITARY AND STORM SEWERS MANHOLE TYPE SW-301, 60 INCH INTAKE TYPE SW-401, 60 INCH INTAKE TYPE SW-503 MANHOLE ADJUSTMENT, MAJOR REMOVE MANHOLE REMOVE INTAKE MENT CONCRETE PAVEMENT	EA E	2 470 2 1 1 1 2 1 14 1 1 4 6	

49					
	7010-108-I-0	PCC PAVEMENT SAMPLES AND TESTING	LS	1	
ECTION 70	020 - HOT MIX ASPH	ALT PAVEMENT			
50	7020-108-B-0	HMA PAVEMENT, 8 INCH	SY	360	
ECTION 70	030 - SIDEWALKS, S	SHARED USE PATHS, AND DRIVEWAYS			
51	7030-108-A-0	REMOVAL OF SIDEWALK	SY	1,486	
52	7030-108-A-0	REMOVAL OF DRIVEWAY	SY	268	
53	7030-108-E-0	SIDEWALK, PCC, 5 IN.	SY	1,390	
54	7030-108-E-0	SIDEWALK, PCC, 10 IN. (RAMP)	SY	110	
55	7030-108-E-0	CONCRETE MEDIANS, APRON, BANDING, PCC, 10 IN.	SY	301	
56	7030-108-F-1	CONCRETE UNIT PAVERS TYPE B & C WITH SAND SETTING BED & PCC SUBBASE	SF	1,300	
57	7030-108-F-2	HISTORIC PAVERS, TYPE A WITH SAND SETTING BED & PCC SUBBASE (PAVERS FURNISHED BY CITY)	SF	550	
58	7030-108-F-3	CROSSWALK PAVERS WITH 3/4" ASPHALT SETTING BED	SF	720	
59	7030-108-G-0	DETECTABLE WARNING	SF	300	
60	7030-108-H-1	DRIVEWAY, PAVED, PCC, 7 INCH	SY	600	
61	7030-108-H-1	DRIVEWAY, PAVED, PCC, 10 INCH	SY	505	
	7000 100 11 1	Sitt Ethni, integritori			
FOTION 7	040 DAVEMENT DE	TIADILITATION			
	040 - PAVEMENT RE		21	,	1
62	7040-108-H-0	PAVEMENT REMOVAL	SY	4,225	
ECTION 80	020 - PAVEMENT MA	ARKINGS			
63	8020-108-B-0	PAINTED PAVEMENT MARKINGS, SOLVENT/WATERBORNE	STA	27.0	
	<u>'</u>				
ECTION 90	010 - SEEDING				1
64	9010-108-B-0	SEEDING, FERTILIZING & HYDROMULCHING	AC	0.5	
V-T	00 10-100 - D-0	SEESTING, LETTILLETTO & THE STORIGE OF HITO	AU	0.0	
EOTIC:::					
	020 - SODDING	T			
65	9020-108-A-0	SOD	SQ	150	
ECTION 90	030 - PLANT MATER	IAL AND PLANTING			
66	9030-108-B-0	DECIDUOUS SHRUBS	EA	19	
67	9030-108-B-0	ORNAMENTAL TREE	EA	8	
68	9030-108-B-0	PERENNIAL GROUND COVER (1 GAL)	EA	558	
69	9030-108-B-0	DECIDUOUS TREE	EA	18	
09	9030-100-D-0	DECIDOOOS TREE	LA	10	
ECTION 90	040 - EROSION AND	SEDIMENT CONTROL			
70	9040-108-A-2	SWPPP MANAGEMENT	LS	1	
71	9040-108-D-1	FILTER SOCKS, 12 INCH	LF	1,800	
/ 1		SILT FENCE OR SILT FENCE DITCH CHECK	LF	200	
72	9040-108-N-1		LF		
72		INLET PROTECTION DEVICE, DROP IN PROTECTION		21	
	9040-108-N-1 9040-108-T-1	INLET PROTECTION DEVICE, DROP IN PROTECTION	EA	21	
72 73	9040-108-T-1			21	
72 73 ECTION 1	9040-108-T-1	ON SURVEY	EA		
72 73	9040-108-T-1			21	
72 73 ECTION 1	9040-108-T-1	ON SURVEY	EA		
72 73 ECTION 11	9040-108-T-1	ON SURVEY CONSTRUCTION SURVEY	EA		
72 73 ECTION 11	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A	ON SURVEY CONSTRUCTION SURVEY	EA		
72 73 ECTION 12 74	9040-108-T-1 1010 - CONSTRUCTI	ON SURVEY CONSTRUCTION SURVEY	EA LS	1	
72 73 ECTION 12 74 ECTION 12 75	9040-108-T-1 1010 - CONSTRUCTI	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION	EA LS	1	
72 73 ECTION 11 74 ECTION 11	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION	LS LS	1	
72 73 ECTION 12 74 ECTION 12	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION	EA LS	1	
72 73 ECTION 11 74 ECTION 11 75	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT	LS LS	1	
72 73 8ECTION 11 74 75 8ECTION 12 76	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT	LS LS LS	1 1	
72 73 ECTION 11 74 ECTION 11 75 ECTION 12 77	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT TEMS LIMESTONE EDGER	LS LS LS LF	1 1 1 310	
72 73 ECTION 11 74 ECTION 11 75 ECTION 11	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT	LS LS LS	1 1	
72 73 ECTION 17 74 ECTION 17 76 ECTION 12 77	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT TEMS LIMESTONE EDGER	LS LS LS LF	1 1 1 310	
72 73 8ECTION 11 74 75 8ECTION 12 76 8ECTION 12 77 78	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1 12010-XXX-X-2	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT TEMS LIMESTONE EDGER	LS LS LS LF	1 1 1 310	
72 73 ECTION 11 74 ECTION 11 75 ECTION 12 77 78	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1 12010-XXX-X-2	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT TEMS LIMESTONE EDGER BOULDER SEATWALLS	LS LS LS LF	1 1 1 310	
72 73 ECTION 11 74 ECTION 12 76 ECTION 12 77 78	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1 12010-XXX-X-2	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT TEMS LIMESTONE EDGER BOULDER SEATWALLS TEMS, ELECTRICAL, DUCT BANK	LS LS LS LF LF	1 1 1 310 25	
72 73 ECTION 17 74 ECTION 17 75 ECTION 17 76 ECTION 17 77 78 ECTION 12 77	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1 12010-XXX-X-2 2,020 - SPECIALTY IT 12,020-XXX-X-1	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT IEMS LIMESTONE EDGER BOULDER SEATWALLS TEMS, ELECTRICAL, DUCT BANK DUCT BANK, 3x2 CONFIGURATION	LS LS LS LF LF	1 1 1 310 25	
72 73 ECTION 11 74 ECTION 11 75 ECTION 12 76 ECTION 12 77 78 ECTION 12 79	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY II 12010-XXX-X-1 12010-XXX-X-2 2,020 - SPECIALTY II 12,020-XXX-X-1	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT IEMS LIMESTONE EDGER BOULDER SEATWALLS TEMS, ELECTRICAL, DUCT BANK DUCT BANK, 3x2 CONFIGURATION TEMS, ELECTRICAL, DISTRIBUTION	LS LS LF LF LF	1 1 1 310 25	
72 73 ECTION 11 74 ECTION 12 76 ECTION 12 77 78 ECTION 12 79	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1 12010-XXX-X-2 2,020 - SPECIALTY IT 12,020-XXX-X-1 2,030 - SPECIALTY IT 12,030-XXX-X-1	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT ITEMS LIMESTONE EDGER BOULDER SEATWALLS TEMS, ELECTRICAL, DUCT BANK DUCT BANK, 3x2 CONFIGURATION TEMS, ELECTRICAL, DISTRIBUTION ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 6-INCH	LS LS LF LF LF	1 1 1 310 25 381	
72 73 ECTION 17 74 ECTION 17 76 ECTION 17 76 ECTION 17 78 ECTION 12 79 ECTION 12 80 81	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1 12010-XXX-X-2 2,020 - SPECIALTY IT 12,020-XXX-X-1 12,030 - SPECIALTY IT 12,030-XXX-X-1 12,030-XXX-X-1	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT FEMS LIMESTONE EDGER BOULDER SEATWALLS TEMS, ELECTRICAL, DUCT BANK DUCT BANK, 3x2 CONFIGURATION TEMS, ELECTRICAL, DISTRIBUTION ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 6-INCH ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 2-INCH	LS LS LF LF LF LF LF	1 1 1 310 25 381 321 1,341	
72 73 ECTION 1: 74 ECTION 1: 75 ECTION 1: 76 ECTION 1: 77 78 ECTION 1: 80	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1 12010-XXX-X-2 2,020 - SPECIALTY IT 12,020-XXX-X-1 2,030 - SPECIALTY IT 12,030-XXX-X-1	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT ITEMS LIMESTONE EDGER BOULDER SEATWALLS TEMS, ELECTRICAL, DUCT BANK DUCT BANK, 3x2 CONFIGURATION TEMS, ELECTRICAL, DISTRIBUTION ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 6-INCH	LS LS LF LF LF	1 1 1 310 25 381	
72 73 ECTION 17 74 ECTION 17 76 ECTION 17 76 ECTION 17 78 ECTION 12 79 ECTION 12 80 81	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1 12010-XXX-X-2 2,020 - SPECIALTY IT 12,020-XXX-X-1 12,030 - SPECIALTY IT 12,030-XXX-X-1 12,030-XXX-X-1	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT FEMS LIMESTONE EDGER BOULDER SEATWALLS TEMS, ELECTRICAL, DUCT BANK DUCT BANK, 3x2 CONFIGURATION TEMS, ELECTRICAL, DISTRIBUTION ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 6-INCH ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 2-INCH	LS LS LF LF LF LF LF	1 1 1 310 25 381 321 1,341	
72 73 ECTION 17 74 ECTION 17 76 ECTION 17 77 78 ECTION 12 77 80 81 82	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1 12010-XXX-X-2 2,020 - SPECIALTY IT 12,020-XXX-X-1 12,030 - SPECIALTY IT 12,030-XXX-X-1 12,030-XXX-X-2 12,030-XXX-X-2 12,030-XXX-X-3	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT FEMS LIMESTONE EDGER BOULDER SEATWALLS TEMS, ELECTRICAL, DUCT BANK DUCT BANK, 3x2 CONFIGURATION TEMS, ELECTRICAL, DISTRIBUTION ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 6-INCH ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 2-INCH JUNCTION BOX, ELECTRICAL, 13"x24"	LS LS LF LF LF LF EA	1 1 310 25 381 321 1,341 2	
72 73 ECTION 17 74 ECTION 17 76 ECTION 17 77 78 ECTION 17 80 81 82 83	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1 12010-XXX-X-2 2,020 - SPECIALTY IT 12,020-XXX-X-1 12,030-XXX-X-1 12,030-XXX-X-1 12,030-XXX-X-2 12,030-XXX-X-3 12,030-XXX-X-4	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT FEMS LIMESTONE EDGER BOULDER SEATWALLS TEMS, ELECTRICAL, DUCT BANK DUCT BANK, 3x2 CONFIGURATION TEMS, ELECTRICAL, DISTRIBUTION ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 6-INCH ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 2-INCH JUNCTION BOX, ELECTRICAL, 13"x24" JUNCTION BOX, ELECTRICAL, 10" DIAMETER	LS LS LS LF LF LF LF EA EA EA	1 1 1 310 25 381 321 1,341 2 1	
72 73 ECTION 17 74 ECTION 17 76 ECTION 17 78 ECTION 17 79 ECTION 12 80 81 82 83 84	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1 12010-XXX-X-2 2,020 - SPECIALTY IT 12,020-XXX-X-1 12,030-XXX-X-1 12,030-XXX-X-2 12,030-XXX-X-3 12,030-XXX-X-4 12,030-XXX-X-4	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT TEMS LIMESTONE EDGER BOULDER SEATWALLS TEMS, ELECTRICAL, DUCT BANK DUCT BANK, 3x2 CONFIGURATION TEMS, ELECTRICAL, DISTRIBUTION ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 6-INCH ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 2-INCH JUNCTION BOX, ELECTRICAL, 13"x24" JUNCTION BOX, ELECTRICAL, 10" DIAMETER FOUNDATION, STREET LIGHT	LS LS LS LF LF LF LF EA EA EA	1 1 1 310 25 381 321 1,341 2 1	
72 73 8ECTION 17 74 8ECTION 17 75 8ECTION 17 76 8ECTION 12 77 78 8ECTION 12 80 81 82 83 84	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY II 12010-XXX-X-1 12010-XXX-X-2 2,020 - SPECIALTY II 12,030-XXX-X-1 12,030-XXX-X-1 12,030-XXX-X-2 12,030-XXX-X-3 12,030-XXX-X-4 12,030-XXX-X-4 12,030-XXX-X-4	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT TEMS LIMESTONE EDGER BOULDER SEATWALLS TEMS, ELECTRICAL, DUCT BANK DUCT BANK, 3x2 CONFIGURATION TEMS, ELECTRICAL, DISTRIBUTION ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 6-INCH ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 2-INCH JUNCTION BOX, ELECTRICAL, 13"x24" JUNCTION BOX, ELECTRICAL, 10" DIAMETER FOUNDATION, STREET LIGHT	LS LS LS LF LF LF EA EA EA EA	1 1 1 310 25 381 321 1,341 2 1 10	
72 73 74 74 8ECTION 17 75 8ECTION 12 77 78 8ECTION 12 79 8ECTION 12 80 81 82 83 84	9040-108-T-1 1010 - CONSTRUCTI 11,010-108-A 1020 - MOBILIZATIO 11,020-108-A 1050 - CONCRETE W 11,050-108-A 2010 - SPECIALTY IT 12010-XXX-X-1 12010-XXX-X-2 2,020 - SPECIALTY IT 12,020-XXX-X-1 12,030-XXX-X-1 12,030-XXX-X-2 12,030-XXX-X-3 12,030-XXX-X-4 12,030-XXX-X-4	ON SURVEY CONSTRUCTION SURVEY N MOBILIZATION VASHOUT CONCRETE WASHOUT TEMS LIMESTONE EDGER BOULDER SEATWALLS TEMS, ELECTRICAL, DUCT BANK DUCT BANK, 3x2 CONFIGURATION TEMS, ELECTRICAL, DISTRIBUTION ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 6-INCH ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 2-INCH JUNCTION BOX, ELECTRICAL, 13"x24" JUNCTION BOX, ELECTRICAL, 10" DIAMETER FOUNDATION, STREET LIGHT	LS LS LS LF LF LF LF EA EA EA	1 1 1 310 25 381 321 1,341 2 1	





REV	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
			JGS	2ND & MULBERRY ROUNDABOUT
			CHECKED	ESTIMATED QUANTITIES & REFERENCE NOTES
			ALH	2311117(12) 007(111112) 0 1(2) 2(2) 1(0) 1(2)

		ESTIMATE REFERENCE NOTES
tem No.	Item Code	Description
1	1070-206-A-0	TRAFFIC CONTROL A. REFER TO J SHEETS FOR DETAILS. EXISTING SIGNS SHALL BE REMOVED BY THE CONTRACTOR TO FACILITATE EACH STAGE OF CONSTRUCTION. CONTRACTOR IS TO NOTIFY THE CITY WHEN SIGNS NEED TO BE PICKED UP. THIS ITEM INCLUDES ALL TEMPORARY SIGNS, BARRICADES, PAVEMENT MARKING REMOVALS, AND TRAFFIC CONTROL DEVICES REQUIRED TO EXECUTE TRAFFIC CONTROL IN ACCORDANCE WITH MUTCD.
2	2010-108-C-0	CLEARING AND GRUBBING
		A. THIS ITEM INCLUDES THE REMOVAL OF ALL TREES, STUMPS, BUSHES, AND ROOTS WITHIN THE EASEMENTS AND CONSTRUCTION LIMITS FOR PROPER INSTALLATION OF PROPOSED ITEMS. REMOVAL SHALL BE TO A DEPTH OF 12" BELOW PROPOSED GRADE. ADDITIONAL TREES OR STUMPS THAT NEED TO BE REMOVED WILL REQUIRE PERMISSION FROM THE ENGINEER PRIOR TO COMPLETION OF THE WORK. PROTECT ALL TREES NOT MARKED FOR REMOVAL. REMOVAL OF PREVIOUSLY FELLED TREES AND BRUSH ARE INCLUDED IN THIS PAY ITEM. ALL TRASH AND DEBRIS LOCATED WITHIN THE PROJECT LIMITS SHALL ALSO BE REMOVED, COST INCIDENTAL. CONTRACTOR MAY DISPOSE OF TREES, BRUSH AND ORGANIC DEBRIS AT THE CITY COMPOSE SITE LOCATED OFF OF HOUSER ST. AT MUSSER ST. AT NO CHARGE TO THE CONTRACTOR.
3	2010-108-D-3	TOPSOIL, OFF SITE A. CONTRACTOR SHALL BE RESPONSIBLE TO FURNISH AND SPREAD TO ALLOW FOR A MINIMUM OF FINISHED DEPTH OF 6" OF TOPSOIL. QUANTITY IS BASED ON 6" OF TOPSOIL LOCATED BETWEEN THE BACK OF CURB AND THE EDGE OF THE PROJECT LIMITS. ITEM IS TO SUPPLEMENT TOPSOIL PROVIDED BY CITY. USE OF THIS ITEM MUST RECEIVE PRIOR APPROVAL BY THE ENGINEER.
4	2010-108-D-X	TOPSOIL, OFF SITE, LOAD & SPREAD
		A. CITY SHALL BE RESPONSIBLE TO FURNISH TOPSOIL AND CONTRACTOR SHALL BE RESPONSIBLE TO LOAD, TRANSPORT AND SPREAD TO A MINIMUM FINISHED DEPTH OF 6 INCHES. HAUL DISTANCE SHALL BE NO MORE THAN 3 MILES ROUND TRIP. QUANTITY IS BASED ON 6" OF TOPSOIL LOCATED BETWEEN THE BACK OF CURB AND THE EDGE OF THE PROJECT LIMITS.
5	2010-108-E-0	EXCAVATION, CLASS 13
		A. THIS ITEM SHALL INCLUDE THE REMOVAL OF EXISTING SOIL AND AGGREGATE BASE, HAULING AND PLACEMENT OF THE MATERIAL WITHIN THE GRADING LIMITS, HAULING AND PLACEMENT OF BORROW MATERIAL IN ACCORDANCE WITH THE SPECIFICATIONS AND THESE PLANS. THE CONTRACTOR SHALL DISPOSE OF EXCESS MATERIAL AND MATERIAL THAT IS NOT SUITABLE FOR EMBANKMENT CONSTRUCTION TO LOCATIONS AS DESIGNATED BY THE ENGINEER. ANY BRICKS FOUND DURING EXCAVATION SHALL BE SALVAGED TO THE YARD LOCATED AT PUBLIC WORKS. ITEM DOES NOT INCLUDE ANY UTILITY TRENCH EXCAVATION.
		B. THE CITY RAVINE SITE LOCATED LESS THAN 3 MILES ROUND TRIP FROM THE PROJECT AREA SHALL BE USED FOR BOTH THE BORROW SITE AND DISPOSAL OF UNSUITABLE OR EXCESS SOIL. REFER TO SHEET MAP ON A.01 FOR LOCATION OF CITY RAVINE SITE.
		C. THE FINISHED GRADE SHALL BE OF UNIFORM CROSS-SECTION AND APPROVED BY THE ENGINEER PRIOR TO PLACEMENT OF THE MODIFIED SUBBASE. CONTRACTOR SHALL NOTIFY CITY OF ANY DISPUTE WITH EXCAVATION PLAN PRIOR TO CONSTRUCTION, OTHERWISE PLAN QUANTITY WILL BE USED FOR PAYMENT. ESTIMATED CUT VOLUME = 2900 CY ESTIMATED FILL VOLUME = 1000 CY EST. FILL *1.3 (FILL FACTOR) = 1300 CY ESTIMATED TO BE WASTED = 1600 CY
6	2010-108-G-0	SUBGRADE PREPARATION
		A. INCLUDES SUBGRADE PREPARATION FOR ALL ROADWAY PAVEMENT TO A DEPTH OF 12 INCHES. QUANTITY IS BASED ON THE AREA OF 12 INCH SUBGRADE PREPARATION, COMPLETED IN 2 - 6" LIFTS, EXTENDING 2 FOOT BEYOND THE PAVEMENT EDGE. BOTH LIFTS SHALL BE COMPACTED AND PROOFROLLED TO SATISFACTION OF ENGINEER. THE TOP LIFT SHALL BE LEVELED AND SMOOTHED WITH A STEEL DRUM ROLLER AND PROOF ROLLED PRIOR TO STARTING SUBBASE PLACEMENT.
		B. IN INSTANCES OF CONFLICT WITH UTILITIES, THE DEPTH MAY BE REDUCED AS DIRECTED BY THE ENGINEER. PREPARATION UNDER ENTRANCES, DRIVES AND SIDEWALKS SHALL BE INCIDENTAL TO THOSE ITEMS.
7	2010-108-G-X	SUBGRADE STABILIZATION, 12-INCH
		A. THIS ITEM SHALL BE USED AT THE DISCRETION OF THE ENGINEER/OWNER. CONTRACTOR SHALL OBTAIN APPROVAL OF ENGINEER/OWNER PRIOR TO UTILIZING THIS ITEM. THIS ITEM INVOLVES THE OVEREXCAVATION OF UNSUITABLE SOIL WITHIN THE RIGHT OF WAY. THE CONTRACTOR SHALL OVEREXCAVATE ONE FOOT OF MATERIAL, COMPACT BOTTOM OF OVEREXCAVATION, PLACE GEOTEXILE FABRIC ON BOTTOM OF OVEREXCAVATION (NOT A PART OF THIS BID ITEM) AND REPLACE UNSUITABLE MATERIAL WITH MODIFIED SUBBASE.
		B. THIS ITEM SHALL INCLUDE EXCAVATION OF UNSUITABLE MATERIAL, HAULING OF UNSUITABLE MATERIAL TO CITY RAVINE SITE, COMPACTION OF OVEREXCAVATED AREA, PLACEMENT OF ONE FOOT OF MODIFIED SUBBASE AND COMPACTION OF MODIFIED SUBBASE.
8	2010-108-H-0	SUBGRADE TREATMENT, GEOTEXTILE A. THIS PAY ITEM SHALL BE THE GEOTEXTILE FABRIC USED IN THE SUBGRADE STABILIZATION. THIS ITEM SHALL BE NON-WOVEN PERMEABLE FABRIC MEETING THE REQUIREMENT OF ASTM D-4439. FABRIC SHALL MEET THE REQUIREMENTS OF IOWA DOT 4196 SUBGRADE STABILIZATION MATERIAL.
9	2010-108-I-2	SUBBASE, MODIFIED SUBBASE, 6-INCH A. MODIFIED SUBBASE TO BE INSTALLED WHERE NOTED IN THE TYPICAL SECTIONS, INCLUDING THE AREAS UNDER PCC PAVEMENT, HMA PAVEMENT AND EXTEND 2' BEYOND THE BACK OF CURB.
		B. CONTRACTOR MAY RECYCLE THE PCC PAVEMENT THAT IS REMOVED AS PART OF THIS PROJECT TO CREATE THE MODIFIED SUBBASE AS LONG AS THE CRUSHED MATERIAL MEETS THE GRADATION OF MODIFIED SUBBASE. RECYCLED MATERIAL FROM THIS PROJECT AND/OR VIRGIN MATERIA MAY BE USED.
10	2010-108-X-2	REMOVAL, HYDRANT A. REFER TO SHEETS M.01 THRU M.02 FOR REMOVAL LAYOUT. REFER TO SHEET C.07 FOR TABULATION. THIS ITEM SHALL INCLUDE ANY EXCAVATION, SUITABLE BACKFILL, AND COMPACTION REQUIRED FOR REMOVING THE HYDRANT AND PIPE THREE FEET BELOW FINISH GRADE, REMOVING THE TOP SECTION OF THE VALVE BOX, AND CAPPING THE WATER MAIN.
11	2010-108-X-3	REMOVAL, TRAFFIC SIGNAL FOUNDATION A. REFER TO SHEETS M.11 THRU M.12 FOR REMOVAL LAYOUT. REFER TO SHEET C.07 FOR TABULATION. THIS ITEM INCLUDES THE DEMOLITION OF EXISTING FOUNDATIONS TO 24-INCHES BELOW FINISH GRADE. MPW SHALL REMOVE ALL TRAFFIC SIGNAL POLES. CONTRACTOR SHALL COORDINATE REMOVAL OF TRAFFIC SIGNAL POLES WITH MPW.
12	2010-108-X-4	REMOVAL OF TRAFFIC SIGNAL POLES WITH MPW. REMOVAL, STREET LIGHT POLES AND FOUNDATIONS A. REFER TO SHEETS M.11 THRU M.12 FOR REMOVAL LAYOUT. REFER TO SHEET C.07 FOR TABULATION. THIS ITEM INCLUDES THE REMOVAL AND DISPOSAL OF ALL STREET LIGHT POLES AND FOUNDATIONS. THE CONTRACTOR SHALL PROVIDE MPW WITH A TWO WEEK NOTICE OF ANY STREET LIGHT POLE DEMOLITION. MPW SHALL REMOVELIGHT FIXTURES FROM THE POLES. CONTRACTOR SHALL PROTECT STREET LIGHTS AND POLES AS NOTED ON R.01.
13	2010-108-X-5	EXPLORATORY EXCAVATION
-		A. THIS ITEM IS FOR THE INVESTIGATION OF LOCATIONS AND ELEVATIONS OF AN EXISTING UTILITY TO VERIFY THE POTENTIAL FOR CONFLICTS AND/OR CONNECTIONS. CONTRACTOR HAS THE OPTION TO USE OPEN EXCAVATION OR VACUUM TYPE EQUIPMENT TO PERFORM THE EXCAVATION DEPENDING UPON SITE CONDITIONS. PAYMENT INCLUDES THE PROPER BACKFILLING OF THE EXCAVATION AND DISPOSAL OF UNSUITABLE MATERIAL OFFSITE. THE ENGINEER OR THEIR REPRESENTATIVE MUST VERIFY THE CONDITIONS FOUND. QUANTITY IS ESTIMATED TO ESTABLISH A UNIT PRICE, ONLY QUANTITY APPROVED BY ENGINEER PRIOR TO WORK WILL BE PAID.
		B. ITEM IS NOT INTENDED TO BE USED TO FIND KNOWN UTILITY LOCATIONS

15	3010-108-D-0	REPLACEMENT OF UNSUITABLE BACKFILL MATERIAL
		A. THIS ITEM SHALL BE USED TO BACKFILL ANY TRENCHES OR EXCAVATIONS WHERE THE EXCAVATION IS WITHIN 10 FOOT OF ROADWAY PAVEMENT. TRENCHES NOT WITHIN 10 FEET OF ROADWAY PAVEMENT SHALL HAVE NATIVE SOIL BACKFILL AND SHALL BE INCIDENTAL TO PIPE. EXCAVATED MATERIAL SHALL BE DISPOSED OF AT THE CITY RAVINE SITE.
		B. REPLACEMENT MATERIAL SHALL BE MANSAND OR GRANULAR MATERIAL AS APPROVED BY THE ENGINEER.
		C. REPLACEMENT MATERIAL QUANTITY IS CALCULATED AT A WIDTH OF PIPE DIAMETER PLUS 2 FOOT WITH VERTICAL TRENCH WALL TO WITHIN 2 FOOT OF THE BOTTOM OF THE ROCK AND THEN FLARE OUT AT A 1:1 SLOPE TO THE BOTTOM OF ROCK. REPLACEMENT MATERIAL SHALL BE MEASURED FROM TOP OF PIPE BEDDING TO BOTTOM OF SUBBASE MATERIAL.
		D. UTILITY TRENCH BACKFILL SHOULD BE PLACED AND COMPACTED AS DESCRIBED IN THE SUDAS STANDARD SPECIFICATIONS, SECTION 3010, WITH THE FOLLOWING MODIFICATIONS:
		CLASS I AND II (CLEAN GRANULAR) BACKFILL MATERIALS SHOULD BE COMPACTED TO AT LEAST 70% RELATIVE DENSITY WITHIN 10 FEET OF THE ROADWAY, REGARDLESS OF DEPTH OR POSITION RELATIVE TO THE UTILITY LINE.
		CLASS III AND IVA (GRANULAR WITH FINES AND COHESIVE) BACKFILL MATERIALS SHOULD BE COMPACTED TO AT LEAST 95% STANDARD PROCTOF DENSITY WITHIN 10 FEET OF THE ROADWAY, REGARDLESS OF DEPTH OR POSITION RELATIVE TO THE UTILITY LINE.
16	3010-108-D-0	REPLACEMENT OF UNSUITABLE BACKFILL MATERIAL, COHESIVE BACKFILL
		A. THIS ITEM SHALL BE USED AS BACKFILL MATERIAL AROUND THE CONCRETE ELECTRIC DUCT BANK. THIS MATERIAL SHALL BE PLACED UP TO THE EXISTING GRADE OR TO THE ELEVATION OF THE ROADWAY SUBBASE, WHICH EVER IS HIGHER. REFER TO SUDAS SECTION 2010 FOR SUITABLE SELECT BACKFILL. THIS MATERIAL SHALL BE A COHESIVE SOIL.
		B. UTILITY TRENCH BACKFILL SHOULD BE PLACED AND COMPACTED AS DESCRIBED IN THE SUDAS STANDARD SPECIFICATIONS, SECTION 2010, WITH THE FOLLOWING MODIFICATIONS:
		CLASS III AND IVA (GRANULAR WITH FINES AND COHESIVE) BACKFILL MATERIALS SHOULD BE COMPACTED TO AT LEAST 95% STANDARD PROCTOF DENSITY WITHIN THE RIGHT OF WAY, REGARDLESS OF DEPTH OR POSITION RELATIVE TO THE UTILITY LINE.
17	3010-108-X-X	RAVINE FILL AREA EARTHWORK MANAGEMENT
		A. UNIT PRICE INCLUDES ALL COSTS OF LABOR AND EQUIPMENT NEEDED TO DO THE GRADING ASSOCIATED WITH WASTING AND BORROWING MATERIAL IN THE CITY OF MUSCATINE'S DESIGNATED RAVINE FILL AREA. WHERE THE MATERIAL IS TO BE BORROWED AND WASTED SHALL BE DEFINED BY THE CITY OF MUSCATINE'S RAVINE GRADING PLAN. THE PLAN IS AVAILABLE FOR REVIEW FROM THE CITY. PRICE INCLUDES GRADING AREAS WHERE WASTE EXCAVATION MATERIAL HAS BEEN DUMPED AT THE RAVINE AND REGRADING AREAS WHERE BORROW MATERIAL HAS BEEN DUMPED AT THE RAVINE AND REGRADING AREAS WHERE BORROW MATERIAL HAS BEEN EXCAVATED. THIS GRADING IS TO ESTABLISH REQUIRED DRAINAGE FOR THE AREAS CHANGED AND WILL BE DIRECTED BY THE ENGINEER. PAYMENT WILL BE BASED ON THE ACTUAL QUANTITY FOR THE REPLACEMENT OF UNSUITABLE BACKFILL ITEMS. NO ADDITIONAL COMPENSATION WILL BE MADE FOR MATERIALS REMOVED FROM THE RAVINE FOR USE ON THIS PROJECT. THE RAVINE IS ALSO USED FOR THE OPERATIONS OF THE CITY OF MUSCATINE'S SANITARY AND STORM SEWER SEPARATION PROJECT CONTRACTOR, AS WELL BY CITY FORCES. CONTRACTORS TO KEEP THE STREETS USED FOR ACCESS CLEAN AND CLEAR OF ALL MUD, DUST AND DELETERIOUS MATERIAL CREATED FROM THE HAULING OPERATIONS. ACCESS WILL BE FROM THE INTERSECTION OF WEST 6TH AND LOCUS STREETS, UNLESS DIRECTED OTHERWISE BY THE ENGINEER.
18	3010-108-F-0	TRENCH COMPACTION TESTING
		A. TRENCH COMPACTION TESTING IS REQUIRED FOR ALL TRENCHES.
19	4010-108-A-1	SANITARY SEWER GRAVITY MAIN, TRENCHED, PVC, 8 INCH
		A. REFER TO SHEET C.06 FOR TABULATIONS. REFER TO MSS SHEETS FOR LOCATIONS. CONTRACTOR SHALL MANDREL TEST AND TELEVISE ALL SANITARY SEWERS AND TURN OVER DATA TO CITY UPON COMPLETION OF THE TESTING AND INSPECTION BEFORE SUBGRADE PREPARATION. DATA SUBMITTAL TO BE APPROVED BY ENGINEER. ANY VISIBLE LEAKS SHALL BE REPAIRED REGARDLESS OF SEVERITY. CONTRACTOR SHALL RE-VIDEO ANY REQUIRED REPAIRS AND PROVIDE VIDEO TO THE CITY AT NO ADDITIONAL COST.
		B. WHERE THE SEWER CROSSES OVER OR LESS THAN 18 INCHES BELOW A WATER MAIN, LOCATE ONE FULL LENGTH OF SEWER PIPE OF WATER MAIN MATERIAL SO BOTH JOINTS ARE AS FAR AS POSSIBLE FROM THE WATER MAIN. THE SEWER AND WATER PIPES MUST BE ADEQUATELY SUPPORTED AND HAVE WATERTIGHT JOINTS. USE A LOW PERMEABILITY SOIL FOR BACKFILL MATERIAL WITHIN 10 FEET OF THE POINT OF CROSSING. THIS WORK SHALL BE INCIDENTAL TO THE PRICE BID.
		C. PIPE EMBEDMENT DETAIL, TYPE F-3, MODIFIED TO REQUIRE ONLY 6" ABOVE THE TOP OF THE PIPE. FURNISHING AND PLACING ELBOWS AND TEES, PLUGS, CONNECTION TO EXISTING SANITARY SEWER AND BEDDING MATERIALS AS REQUIRED SHALL BE CONSIDERED INCIDENTAL TO THIS ITEM. CONNECTION TO EXISTING SANITARY PIPES SHALL BE INCIDENTAL TO THIS ITEM.
		D. CONTRACTOR SHALL PLUG SEWER AT THE END OF EACH WORKING DAY. DAMAGES RESULTING FROM THE CONTRACTOR'S INABILITY TO KEEP GROUND AND STORM WATER OUT OF THE SANITARY SYSTEM SHALL BE CHARGED TO THE CONTRACTOR.
20	4010-108-E-0	SANITARY SEWER SERVICE STUB, PVC, 6"
		A. REFER TO SHEET C.06 FOR TABULATION. REFER TO MSS SHEETS FOR LOCATIONS. SANITARY SERVICE PIPE SHALL BE CONNECTED TO THE EXISTING SERVICE PIPE AT THE RIGHT OF WAY. CONNECTION SHALL BE BY "FERNCO" STYLE RUBBER BOOT CONNECTORS FOR THE TYPES OF EXISTING PIPE. PIPE MATERIAL SHALL BE SDR 23.5 POLYVINYL CHLORIDE PIPE (PVC). FURNISHING AND PLACEMENT OF ELBOWS AND TEES, BEDDING, AND GRANULAR BACKFILL MATERIAL SHALL CONSIDERED INCIDENTAL TO THIS ITEM. ALL SERVICES SHALL BE WATER TIGHT AND CONNECTED TO THE SEWER MAIN WITH A PREFORMED WYE, USE OF SADDLE WYES WILL NOT BE ALLOWED. ALL VISIBLE LEAKS SHALL BE REPAIRED AT THE CONTRACTOR'S EXPENSE. CONTRACTOR SHALL PROVIDE AS-CONSTRUCTED LOCATIONS OF ALL SERVICES.
21	4010-108-H-0	REMOVAL OF SANITARY SEWER, 12" AND LESS DIA.
		A. REFER TO SHEET R.01 FOR LOCATIONS. EXISTING PIPE TRENCH SHALL BE FILLED WITH GRANULAR MATERIAL AND PAID FOR UNDER "REPLACEMENT OF UNSUITABLE BACKFILL MATERIAL" ITEM. ASSUMED TRENCH WIDTH IS PIPE DIAMETER PLUS TWO FEET AND FILLED TO BOTTON OF SUBBASE.
22	4010-108-K-0	SANITARY SEWER ABANDONMENT, 8" DIA.
		A. REFER TO SHEET R.01 FOR LOCATIONS.
23	4020-108-A-1	STORM SEWER, TRENCHED, RCP, 15 INCH
		A. REFER TO SHEET C.06 FOR TABULATIONS. REFER TO MSS SHEETS FOR LOCATIONS. CONTRACTOR SHALL MANDREL TEST AND TELEVISE ALL STORM SEWERS AND TURN OVER DATA TO CITY UPON COMPLETION OF THE TESTING AND INSPECTION AND PRIOR TO SUBGRADE PREPARATION DATA SUBMITTAL TO BE APPROVED BY ENGINEER.
		B. BEDDING CLASS SHALL BE R-2 FOR ALL PIPES. TYPE OF PIPE ALLOWED SHALL BE RCP, CLASS III. THE JOINTS WILL BE WRAPPED WITH ENGINEERING FABRIC. ANY LOCATION WHERE THE STORM SEWER IS LOCATED WITHIN 18 INCHES VERTICALLY OR OVER A WATERMAIN THE STORM.

A. AT THE DISCRETION OF THE ENGINEER THIS ITEM IS TO INCORPORATE TRENCH FOUNDATION WHERE UNSUITABLE MATERIALS ARE FOUND BELOW THE PIPE BEDDING DURING CONSTRUCTION. QUANTITY IS ESTIMATED TO ESTABLISH A UNIT PRICE. THE ACTUAL TRENCH FOUNDATION QUANTITY USED WILL BE PAID. ENGINEER SHALL APPROVE ALL TRENCH FOUNDATION LOCATIONS PRIOR TO CONTRACTOR PERFORMING THIS





3010-108-C-0

3010-108-D-0

TRENCH FOUNDATION

REPLACEMENT OF UNSUITABLE BACKFILL MATERIAL

WORK.

REV	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
			JGS	2ND & MULBERRY ROUNDABOUT
			CHECKED	ESTIMATE REFERENCE NOTES

23	4020-108-A-1	STORM SEWER, TRENCHED, RCP, 15 INCH
		A. REFER TO SHEET C.06 FOR TABULATIONS. REFER TO MSS SHEETS FOR LOCATIONS. CONTRACTOR SHALL MANDREL TEST AND TELEVISE ALL STORM SEWERS AND TURN OVER DATA TO CITY UPON COMPLETION OF THE TESTING AND INSPECTION AND PRIOR TO SUBGRADE PREPARATION. DATA SUBMITTAL TO BE APPROVED BY ENGINEER.
		B. BEDDING CLASS SHALL BE R-2 FOR ALL PIPES. TYPE OF PIPE ALLOWED SHALL BE RCP, CLASS III. THE JOINTS WILL BE WRAPPED WITH ENGINEERING FABRIC. ANY LOCATION WHERE THE STORM SEWER IS LOCATED WITHIN 18 INCHES VERTICALLY OR OVER A WATERMAIN THE STORM SEWER PIPE SHALL BE GASKETED WITH THE JOINTS LOCATED AS FAR FROM THE WATER MAIN AS POSSIBLE.
24	4020-108-A-1	STORM SEWER, TRENCHED, RCP, 18 INCH
		A. REFER TO SHEET C.06 FOR TABULATIONS, REFER TO MSS SHEETS FOR LOCATIONS. CONTRACTOR SHALL MANDREL TEST AND TELEVISE ALL STORM SEWERS AND TURN OVER DATA TO CITY UPON COMPLETION OF THE TESTING AND INSPECTION AND PRIOR TO SUBGRADE PREPARATION. DATA SUBMITTAL TO BE APPROVED BY ENGINEER.
		B. BEDDING CLASS SHALL BE R-2 FOR ALL PIPES. TYPE OF PIPE ALLOWED SHALL BE RCP, CLASS III. THE JOINTS WILL BE WRAPPED WITH ENGINEERING FABRIC. ANY LOCATION WHERE THE STORM SEWER IS LOCATED WITHIN 18 INCHES VERTICALLY OR OVER A WATERMAIN THE STORM SEWER PIPE SHALL BE GASKETED WITH THE JOINTS LOCATED AS FAR FROM THE WATER MAIN AS POSSIBLE.
25	4020-108-C-0	REMOVAL OF STORM SEWER, LESS THAN 36 INCH A. REFER TO SHEET R.01 SHEETS FOR LOCATIONS. EXISTING PIPE TRENCH SHALL BE FILLED WITH GRANULAR MATERIAL AND PAID FOR UNDER "REPLACEMENT OF UNSUITABLE BACKFILL MATERIAL" ITEM. TRENCH WIDTH SHALL BE PIPE DIAMETER PLUS TWO FEET AND FILLED TO BOTTOM OF SUBBASE.
26	4040-108-A-0	SUBDRAIN, HDPE, 6 INCH A. SEE TYPICAL ROADWAY SECTIONS IN B SHEETS FOR TYPICAL PLACEMENT. SEE D AND E SERIES SHEETS FOR OTHER LOCATIONS. B. SUBRAIN SHALL BE CASE B, TYPE 1. SUBDRAIN PIPE SHALL BE WRAPPED IN FILTER SOCK. NO ENGINEERING FABRIC IS REQUIRED AROUND THE
27	4040-108-C-0	TRENCH. SUBDRAIN CLEANOUT
		A. SEE D AND E SERIES SHEETS FOR LOCATIONS. B. SUBDRAIN CLEANOUT SHALL BE TYPE A1.
28	4040-108-D-0	SUBDRAIN OUTLETS AND CONNECTIONS
		A. SEE C SHEETS FOR TABULATIONS.
		B. OUTLET THROUGH STORM STRUCTURE WALLS SHALL BE COMPLETED USING CMP WITH RODENT GUARD.
29	5010-108-A-1	WATER MAIN, TRENCHED, FUSED HDPE, 12"
		A. REFER TO SHEETS M.01 THRU M.02 FOR LAYOUT. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM INCLUDES EXCAVATION, HAULING OFF EXCAVATED SOIL TO AN APPROVED LOCATION, INSTALLATION OF PIPE, FITTINGS, THRUST BLOCKS, AND APPURTENANCES, AND COMPACTION OF BACKFILL. PIPE WALL THICKNESS SHALL BE DR11. THIS ITEM SHALL BE INSTALLED IN ACCORDANCE WITH MUSCATINE POWER AND WATER'S STANDARD SPECIFICATIONS FOR WATER DISTRIBUTION SYSTEM IMPROVEMENTS. B. MECHANICAL JOINT (MJ) CONNECTIONS TO VALVES SHALL BE MADE USING GF PIPING SYSTEMS MJ ADAPTERS WITH STAINLESS STEEL STIFFENER RINGS OR MPW ENGINEER APPROVED EQUAL. BOLTS AND NUTS SHALL BE CORTEN BLUE.
30	5010-108-A-1	WATER MAIN, TRENCHED, FUSED HDPE, 10"
		A. REFER TO SHEETS M.01 THRU M.02 FOR LAYOUT. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM INCLUDES EXCAVATION, HAULING OFF EXCAVATED SOIL TO AN APPROVED LOCATION, INSTALLATION OF PIPE, FITTINGS, THRUST BLOCKS, AND APPURTENANCES, AND COMPACTION OF BACKFILL. PIPE WALL THICKNESS SHALL BE DR11. THIS ITEM SHALL BE INSTALLED IN ACCORDANCE WITH MUSCATINE POWER AND WATER'S STANDARD SPECIFICATIONS FOR WATER DISTRIBUTION SYSTEM IMPROVEMENTS. B. MECHANICAL JOINT (M.J) CONNECTIONS TO VALVES SHALL BE MADE USING GF PIPING SYSTEMS M.J ADAPTERS WITH STAINLESS STEEL STIFFENER RINGS OR MPW ENGINEER APPROVED EQUAL. BOLTS AND NUTS SHALL BE CORTEN BLUE.
31	5010-108-A-1	WATER MAIN, TRENCHED, FUSED HDPE, 6"
		A. REFER TO SHEETS M.01 THRU M.02 FOR LAYOUT. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM INCLUDES EXCAVATION, HAULING OFF EXCAVATED SOIL TO AN APPROVED LOCATION, INSTALLATION OF PIPE, FITTINGS, THRUST BLOCKS, AND APPURTENANCES, AND COMPACTION OF BACKFILL. PIPE WALL THICKNESS SHALL BE DR11. THIS ITEM SHALL BE INSTALLED IN ACCORDANCE WITH MUSCATINE POWER AND WATER'S STANDARD SPECIFICATIONS FOR WATER DISTRIBUTION SYSTEM IMPROVEMENTS. B. MECHANICAL JOINT (MJ) CONNECTIONS TO VALVES SHALL BE MADE USING GF PIPING SYSTEMS MJ ADAPTERS WITH STAINLESS STEEL STIFFENER RINGS OR MPW ENGINEER APPROVED EQUAL. BOLTS AND NUTS SHALL BE CORTEN BLUE.
32	5010-108-C-1	CUT AND CAP, 10"
		A. REFER TO SHEETS M.01 THRU M.02 FOR LAYOUT. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM INCLUDES PIPE CUTTING, REMOVAL AND DISPOSAL OF PIPE, DISPOSAL OF TRENCH WATER, AND THRUST RESTRAINT (FOR CAPS AND PLUGS SUBJECT TO PRESSURE). MEASUREMENT AND PAYMENT SHALL BE BASED ON EACH TYPE AND SIZE OF COUPLING, CAP, OR PLUG INSTALLED AS SPECIFIED IN THE CONTRACT DOCUMENTS OR AS REQUIRED FOR PROPER INSTALLATION OF THE WATERMAIN. B. THE CONTRACTOR SHALL CONFIRM OUTSIDE DIAMETER FOR CAPS (WATERMAIN IN THIS AREA MAY BE CAST IRON SIZE PIPE). C. THE LENGTH OF CUT AND CAP TIME SHALL BE KEPT TO A MINIMUM. MAXIMUM OUTAGE TIME FRAME IS 4 HOURS. COORDINATE THE CUT AND CAP AND OUTAGE WITH MP&W, MINIMUM OF THREE DAYS NOTICE TO NOTIFY CUSTOMERS.
33	5010-108-C-1	CUT AND CAP, 12"
	0010 100 0 1	A. REFER TO SHEETS M.01 THRU M.02 FOR LAYOUT. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM INCLUDES PIPE CUTTING, REMOVAL AND DISPOSAL OF PIPE, DISPOSAL OF TRENCH WATER, AND THRUST RESTRAINT (FOR CAPS AND PLUGS SUBJECT TO PRESSURE). MEASUREMENT AND PAYMENT SHALL BE BASED ON EACH TYPE AND SIZE OF COUPLING, CAP, OR PLUG INSTALLED AS SPECIFIED IN THE CONTRACT DOCUMENTS OR AS REQUIRED FOR PROPER INSTALLATION OF THE WATERMAIN. B. THE CONTRACTOR SHALL CONFIRM OUTSIDE DIAMETER FOR CAPS (WATERMAIN IN THIS AREA MAY BE CAST IRON SIZE PIPE). C. THE LENGTH OF CUT AND CAP TIME SHALL BE KEPT TO A MINIMUM. MAXIMUM OUTAGE TIME FRAME IS 4 HOURS. COORDINATE THE CUT AND CAP AND OUTAGE WITH MP&W, MINIMUM OF THREE DAYS NOTICE TO NOTIFY CUSTOMERS.
34	5010-108-D-0	WATER SERVICE STUB, COPPER, 1-INCH
		A. REFER TO SHEETS M.01 THRU M.02 FOR LAYOUT. THIS ITEM IS FOR THE WATER SERVICE TO THE CENTER ROUNDABOUT ISLAND AND INCLUDES THE INSTALLATION OF COPPER PIPE, CURB STOP, AND APPURTENANCES IN ACCORDANCE WITH MUSCATINE POWER AND WATER'S STANDARD
	5000 100 5 6	SPECIFICATIONS FOR WATER DISTRIBUTION SYSTEM IMPROVEMENTS FOR A COMPLETE CONNECTION OF THE SERVICE TO THE WATER MAIN.
35	5020-108-B-0	TAPPING SLEEVE AND VALVE, 12"X12" A. REFER TO SHEETS M.01 THRU M.03 FOR LAYOUT AND DETAIL. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM SHALL BE INSTALLED IN ACCORDANCE WITH MUSCATINE POWER AND WATER'S STANDARD SPECIFICATIONS FOR WATER DISTRIBUTION SYSTEM IMPROVEMENTS. MEASUREMENT AND PAYMENT SHALL INCLUDE THE TAPPING SLEEVE, TAPPING VALVE, THRUST BLOCKS, EXCAVATION, GRANULAR BACKFILL, AND COMPACTION. CONTRACTOR SHALL MAKE ALL TAPS TO EXISTING MAINS USING APPROVED TAPPING EQUIPMENT FOR WATER MAIN INSTALLATION, APPROVAL SHALL BE PROVIDED BY MPW.
36	5020-108-B-0	TAPPING SLEEVE AND VALVE, 10"x10" A. REFER TO SHEET S. SHEETS M.01 THRU M.03 FOR LAYOUT AND DETAIL. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM SHALL BE INSTALLED IN ACCORDANCE WITH MUSCATINE POWER AND WATER'S STANDARD SPECIFICATIONS FOR WATER DISTRIBUTION SYSTEM IMPROVEMENTS. MEASUREMENT AND PAYMENT SHALL INCLUDE THE TAPPING SLEEVE, TAPPING VALVE, THRUST BLOCKS, EXCAVATION, GRANULAR BACKFILL, AND COMPACTION. CONTRACTOR SHALL MAKE ALL TAPS TO EXISTING MAINS USING APPROVED TAPPING EQUIPMENT FOR WATER MAIN INSTALLATION, APPROVAL SHALL BE PROVIDED BY MPW.

		B. ANY VISIBLE LEAKS SHALL BE REPAIRED. MANHOLE CASTINGS SHALL READ "SANITARY SEWER" AND BE AN EAST JORDAN 1045 WITH CONCEALED PICK HOLES OR APPROVED EQUAL. SANITARY MANHOLE SHALL HAVE INTERNAL CHIMNEY SEAL.
39	6010-108-A-0	MANHOLE TYPE SW-401, 60 INCH
		A. REFER TO SHEET C.06 FOR TABULATIONS. REFER TO MSS SHEETS FOR LOCATIONS.
		B. MANHOLE CASTINGS SHALL READ "STORM SEWER" AND BE AN EAST JORDAN 1045 WITH CONCEALED PICK HOLES
40	6010-108-B-0	INTAKE TYPE SW-501
		A. REFER TO SHEET C.06 FOR TABULATIONS. REFER TO MSS SHEETS FOR LOCATIONS. CASTING SHALL READ " NO DUMP, DRAINS TO WATERWAY".
41	6010-108-B-0	INTAKE TYPE SW-503
		A. REFER TO SHEET C.06 FOR TABULATIONS. REFER TO MSS SHEETS FOR LOCATIONS. CASTING SHALL READ " NO DUMP, DRAINS TO WATERWAY".
42	6010-108-F-0	MANHOLE ADJUSTMENT, MAJOR
		A. REFER TO MSS SHEETS FOR LOCATION.
		B. THIS BID ITEM SHALL INCLUDE ALL MATERIALS, LABOR AND EQUIPMENT NECESSARY TO ADJUST CASTINGS TO FINISHED GRADE. ITEM SHALL INCLUDE REMOVING THE EXISTING CASTING, REPLACING CONCRETE ADJUSTING RINGS TO PROPER ELEVATION, INSTALLATION OF EXISTING CASTING AND INSTALLATION OF NEW INTERNAL CHIMNEY SEAL ON SANITARY SEWER MANHOLES.
43	6010-108-H-0	REMOVE MANHOLE
		A. REFER TO R SHEETS FOR LOCATIONS. REMOVED STRUCTURE SHALL BECOME PROPERTY OF THE CONTRACTOR AND PROPERLY DISPOSED OF. CASTING SHALL BECOME PROPERTY OF THE CITY AND DELIEVERED TO THE CITY YARD.
44	6010-108-H-0	REMOVE INTAKE
		A. REFER TO R SHEETS FOR LOCATIONS. REMOVED STRUCTURE SHALL BECOME PROPERTY OF THE CONTRACTOR AND PROPERLY DISPOSED
45	7010-108-A-0	OF. CASTING SHALL BECOME PROPERTY OF THE CITY AND DELIEVERED TO THE CITY YARD. PAVEMENT, PCC, 10 INCH
45	7010-100-74-0	A. REFER TO SHEET C.08 TABULATION. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO D AND E SHEETS FOR LAYOUT.
		REFER TO L SHEETS FOR JOINT SPACING. ALL JOINTS SHALL BE CUT TO A DEPTH OF T/3 AND SEALED.
		B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. LOW AIR TOLERANCE LIMIT PER 7010-3.08-B SHALL BE 6%. BUMP CART SHALL BE USED FOR PAYMENET SMOOTHNESS EVALUATION AND SURFACE CORRECTIONS SHALL BE MADE IN ACCORDANCE WITH 7010-3.07-C. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE.
		C. THIS ITEM SHALL INCLUDE QUANTITIES FOR CURB GUTTER SECTIONS CONNECTED TO THE PAVEMENT.
46	7010-108-A-0	PAVEMENT, PCC, 10 INCH, COLORED
		A. REFER TO SHEETS C.08 FOR TABULATION. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO D SHEETS FOR LAYOUT. REFER TO L SHEETS FOR JOINT SPACING. ALL JOINTS SHALL BE CUT TO A DEPTH OF T/3 AND SEALED.
		B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. LOW AIR TOLERANCE LIMIT PER 7010-3.08-B SHALL BE 6%. BUMP CART SHALL BE USED FOR PAYMENET SMOOTHNESS EVALUATION AND SURFACE CORRECTIONS SHALL BE MADE IN ACCORDANCE WITH 7010-3.07-C. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED, CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE.
		C. THIS ITEM SHALL INCLUDE QUANTITIES FOR CURB AND GUTTER SECTIONS CONNECTED TO THE PAVEMENT.
47	7010-108-E-0	CURB AND GUTTER, 36 INCH, 10 INCH THICK
		A. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. LOW AIR TOLERANCE LIMIT PER 7010-3.08-B SHALL BE 6%. BUMP CART OR STRAIGHTEDGE SHALL BE USED FOR PAYMENT SMOOTHNESS REQUIREMENT AND SURFACE CORRECTIONS SHALL BE MADE IN ACCORDANCE WITH 7010-3.07-C. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE.
48	7010-108-F-0	BEAM CURB
		A. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. LOW AIR TOLERANCE LIMIT PER 7010-3.08-B SHALL BE 6%. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE.
		B. VARIATION IN DEPTH OF BEAM CURB SHALL BE INCIDENTAL TO THIS ITEM. THIS ITEM SHALL COVER THE BEAM CURB AT THE BACK OF SIDEWALK ON THE SOUTH SIDE OF 2ND STREET AT THE EAST END OF THE PROJECT.
49	7010-108-I-0	PCC PAVEMENT SAMPLES AND TESTING A. THIS ITEM SHALL BE MEASURED AND PAID IN ACCORDANCE WITH SECTION 7010, 1.08 I. THICKNESS AND SMOOTHNESS INCENTIVES ARE NOT II EFFECT FOR THIS PROJECT.
50	7020-108-B-0	HMA PAVEMENT, 8 INCH
		A. INCLUDES ALL EQUIPMENT AND MATERIALS NECESSARY TO PLACE HMA BASE, LEVELING, AND SURFACE LAYERS AS SHOWN IN TYPICAL ROADWAY SECTION IN B SERIES SHEETS. SEE D.02 FOR PLAN AND PROFILE. CONTRACTOR SHALL PROVIDE QUALITY CONTROL ACCORDING TO SECTION 7020, 3.06. B (SMALL QUANTITIES), PLANT REPORTING SHALL BE REQUIRED.
51	7030-108-A-0	REMOVAL OF SIDEWALK A. REFER TO R SHEETS FOR LOCATIONS.
		B. ALL REMOVALS TO BE MARKED AND MEASURED BY THE ENGINEER. FULL DEPTH SAW CUTS ALONG THE REMOVAL LIMITS ARE INCIDENTAL TO THIS ITEM. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ADDITIONAL REMOVAL, EARTHWORK, SUBGRADE PREPARATION, MODIFIED SUBBASE AND PAVING EXPENSES DUE TO DAMAGED EDGES. ADDITIONAL REMOVAL TO BE DETERMINED BY ENGINEER. PAYMENT SHALL BE MADE FOR THI AREA OF PAVEMENT REMOVED, REGARDLESS OF THICKNESS.

A. REFER TO SHEETS M.01 THRU M.02 FOR LAYOUT. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM SHALL BE INSTALLED IN ACCORDANCE WITH MUSCATINE POWER AND WATER'S STANDARD SPECIFICATIONS FOR WATER DISTRIBUTION SYSTEM IMPROVEMENTS.





5020-108-C-0 HYDRANT, ASSEMBLY

MANHOLE TYPE SW-301, 60 INCH

A. REFER TO SHEET C.06 FOR TABULATIONS. REFER TO MSS SHEETS FOR LOCATIONS.

REV	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
			JGS	2ND & MULBERRY ROUNDABOUT
			CHECKED	ESTIMATE REFERENCE NOTES

-108-E-0	REMOVAL OF DRIVEWAY A. REFER TO R SHEETS FOR LOCATIONS. B. ALL REMOVALS TO BE MARKED AND MEASURED BY THE ENGINEER. FULL DEPTH SAW CUTS ALONG THE REMOVAL LIMITS ARE INCIDENTAL TO THIS ITEM. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ADDITIONAL REMOVAL, EARTHWORK, SUBGRADE PREPARATION, MODIFIED SUBBASE AND PAVING EXPENSES DUE TO DAMAGED EDGES. ADDITIONAL REMOVAL TO BE DETERMINED BY ENGINEER. PAYMENT SHALL BE MADE FOR THE AREA OF PAVEMENT REMOVED, REGARDLESS OF THICKNESS. SIDEWALK, PCC, 5 IN. A. REFER TO C SHEET FOR QUANTITY TAB. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO F SHEETS FOR LAYOUT AND T SHEETS FOR JOINTING, ITEMS INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. SIDEWALK, PCC, 10 IN. (RAMP) A. REFER TO S SERIES SHEETS FOR SIDEWALK RAMP LAYOUT AND TABULATIONS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL BE CONSIDERED INCIDENTAL IF REQUIREMENT SHALL BE SUBJECT TO THE PAIR OF THE SAME CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIREMENT OR SEPENSE UNLESS, IN THE JUDGEMENT OF THE ENGIN
-108-E-0	B. ALL REMOVALS TO BE MARKED AND MEASURED BY THE ENGINEER. FULL DEPTH SAW CUTS ALONG THE REMOVAL LIMITS ARE INCIDENTAL TO THIS ITEM. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ADDITIONAL REMOVAL, EARTHWORK, SUBGRADE PREPARATION, MODIFIED SUBBASE AND PAVING EXPENSES DUE TO DAMAGED EDGES. ADDITIONAL REMOVAL TO BE DETERMINED BY ENGINEER. PAYMENT SHALL BE MADE FOR THE AREA OF PAVEMENT REMOVED, REGARDLESS OF THICKNESS. SIDEWALK, PCC, 5 IN. A. REFER TO C SHEET FOR QUANTITY TAB. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO F SHEETS FOR LAYOUT AND T SHEETS FOR JOINTING, ITEMS INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS, AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED, CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. BIGUINEM, PCC, 10 IN. (RAMP) A. REFER TO S SERIES SHEETS FOR SIDEWALK RAMP LAYOUT AND TABULATIONS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. CONCRETE MEDIAN, APPRO
-108-E-0	THIS ITEM. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ADDITIONAL REMOVAL, EARTHWORK, SUBGRADE PREPARATION, MODIFIED SUBBASE AND PAVING EXPENSES DUE TO DAMAGED EDGES. ADDITIONAL REMOVAL TO BE DETERMINED BY ENGINEER. PAYMENT SHALL BE MADE FOR THE AREA OF PAVEMENT REMOVED, REGARDLESS OF THICKNESS. SIDEWALK, PCC, 5 IN. A. REFER TO C SHEET FOR QUANTITY TAB. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO F SHEETS FOR LAYOUT AND T SHEETS FOR JOINTING, ITEMS INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. SIDEWALK, PCC, 10 IN. (RAMP) A. REFER TO S SERIES SHEETS FOR SIDEWALK RAMP LAYOUT AND TABULATIONS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT SHALL BE MADE. SIDEWALK, PCC, 10 IN. (RAMP) A. REFER TO S SERIES SHEETS FOR SIDEWALK RAMP LAYOUT AND TABULATIONS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT SHALL BE DESCRIPTION OF THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PAYMENT SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE
-108-E-0	SIDEWALK, PCC, 5 IN. A. REFER TO C SHEET FOR QUANTITY TAB. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO F SHEETS FOR LAYOUT AND T SHEETS FOR JOINTING. ITEMS INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS, AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. SIDEWALK, PCC, 10 IN. (RAMP) A. REFER TO S SERIES SHEETS FOR SIDEWALK RAMP LAYOUT AND TABULATIONS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. CONCRETE MEDIAN, APRONS, BANDING, PCC, 10 IN. A. ITEM IS FOR CONCRETE APRONS, MEDIAN INFILL, AND DECORATIVE BANDS. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO T SHEETS FOR LAYOUT AND JOINTING. ITEM INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS.
	SHEETS FOR JOINTING. ITEMS INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. SIDEWALK, PCC, 10 IN. (RAMP) A. REFER TO S SERIES SHEETS FOR SIDEWALK RAMP LAYOUT AND TABULATIONS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. CONCRETE MEDIAN, APRONS, BANDING, PCC, 10 IN. A. ITEM IS FOR CONCRETE APRONS, MEDIAN INFILL, AND DECORATIVE BANDS. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO T SHEETS FOR LAYOUT AND JOINTING. ITEM INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS.
	THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. SIDEWALK, PCC, 10 IN. (RAMP) A. REFER TO S SERIES SHEETS FOR SIDEWALK RAMP LAYOUT AND TABULATIONS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. CONCRETE MEDIAN, APRONS, BANDING, PCC, 10 IN. A. ITEM IS FOR CONCRETE APRONS, MEDIAN INFILL, AND DECORATIVE BANDS. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO T SHEETS FOR LAYOUT AND JOINTING. ITEM INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS.
	SIDEWALK, PCC, 10 IN. (RAMP) A. REFER TO S SERIES SHEETS FOR SIDEWALK RAMP LAYOUT AND TABULATIONS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. CONCRETE MEDIAN, APRONS, BANDING, PCC, 10 IN. A. ITEM IS FOR CONCRETE APRONS, MEDIAN INFILL, AND DECORATIVE BANDS. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO T SHEETS FOR LAYOUT AND JOINTING. ITEM INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS.
	SIDEWALK, PCC, 10 IN. (RAMP) A. REFER TO S SERIES SHEETS FOR SIDEWALK RAMP LAYOUT AND TABULATIONS. B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. CONCRETE MEDIAN, APRONS, BANDING, PCC, 10 IN. A. ITEM IS FOR CONCRETE APRONS, MEDIAN INFILL, AND DECORATIVE BANDS. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO T SHEETS FOR LAYOUT AND JOINTING. ITEM INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS.
-108-E-0	B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. CONCRETE MEDIAN, APRONS, BANDING, PCC, 10 IN. A. ITEM IS FOR CONCRETE APRONS, MEDIAN INFILL, AND DECORATIVE BANDS. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO T SHEETS FOR LAYOUT AND JOINTING. ITEM INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS.
.108-E-0	THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE. C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE. CONCRETE MEDIAN, APRONS, BANDING, PCC, 10 IN. A. ITEM IS FOR CONCRETE APRONS, MEDIAN INFILL, AND DECORATIVE BANDS. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO T SHEETS FOR LAYOUT AND JOINTING. ITEM INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS.
108-E-0	CONCRETE MEDIAN, APRONS, BANDING, PCC, 10 IN. A. ITEM IS FOR CONCRETE APRONS, MEDIAN INFILL, AND DECORATIVE BANDS. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO T SHEETS FOR LAYOUT AND JOINTING. ITEM INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS.
·108-E-0	A. ITEM IS FOR CONCRETE APRONS, MEDIAN INFILL, AND DECORATIVE BANDS. REFER TO B SHEETS FOR TYPICAL PAVEMENT SECTIONS. REFER TO T SHEETS FOR LAYOUT AND JOINTING. ITEM INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS.
	TO T SHEETS FOR LAYOUT AND JOINTING. ITEM INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT AS SHOWN ON THE T SHEETS AND DETAILED IN THE U SHEETS.
	B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING
	THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE.
	C. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE FOR THICKENED EDGES.
-108-F-1	CONCRETE UNIT PAVERS TYPE B & C WITH SAND SETTING BED & PCC SUBBASE
	A. THIS ITEM INCLUDES PAVER TYPES B & C, POLYMERIC SAND FOR JOINTS, SAND SETTING BED, GEOTEXTILE FABRIC, 4 INCH THICK CONCRETE BASE, REBAR, AND AGGREGATE SUBBASE.
	BASE, REDAR, AND AGGREGATE SUDDAGE.
	B. REFER TO T SHEETS FOR TYPE, LOCATION AND PATTERN. SEE NOTES AND DETAILS ON U SHEETS REGARDING INSTALLATION AND INCIDENTAL ITEMS. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE FOR THICKENED EDGES.
	C. SEE SPECIAL PROVISION FOR ADDITIONAL INFORMATION.
-108-F-2	HISTORIC PAVERS, TYPE A WITH SAND SETTING BED & PCC SUBBASE (HISTORIC PAVERS FURNISHED BY CITY)
	A. THIS ITEM INCLUDES POLYMERIC SAND FOR JOINTS, SAND SETTING BED, GEOTEXTILE FABRIC, 4 INCH THICK CONCRETE BASE, REBAR, AND AGGREGATE SUBBASE. HISTORIC PAVERS TO BE FURNISHED BY OWNER.
	B. REFER TO T SHEETS FOR TYPE, LOCATION AND PATTERN. SEE NOTES AND DETAILS ON U SHEETS REGARDING INSTALLATION AND INCIDENTAL ITEMS. THICKENED EDGES SHALL BE INCIDENTAL TO THIS ITEM AND NO ADDITIONAL PAYMENT SHALL BE MADE FOR THICKENED EDGES.
	C. REFER TO T SHEETS FOR TYPE, LOCATION AND PATTERN. SEE NOTES AND DETAILS ON U SHEETS REGARDING INSTALLATION AND INCIDENTAL ITEMS.
-108-F-3	CROSSWALK PAVERS WITH 3/4" ASPHALT SETTING BED
	A. THIS ITEM INCLUDES THE 8 CM THICK CONCRETE UNIT PAVER, POLYMERIC SAND FOR JOINTS, BITUMINOUS SETTING BED, NEOPRENE MASTIC, 6
	INCH THICK CONCRETE BASE, AND REBAR.
	B. REFER TO T SHEETS FOR TYPE, LOCATION AND PATTERN. SEE NOTES AND DETAILS ON U SHEETS REGARDING INSTALLATION AND INCIDENTAL ITEMS.
	C. SEE SPECIAL PROVISION FOR ADDITIONAL INFORMATION.
108-G-0	DETECTABLE WARNING
100 :: :	A. DETECTABLE WARNING SYSTEMS SHALL BE NEENAH DETECTABLE WARNING PLATES, MODEL 4984-36B OR APPROVED EQUAL. CONTRACTOR SHALL VERIFY TYPE WITH ENGINEER AND CITY PRIOR TO ORDERING MATERIALS.
- ιυ ၓ-H-1	DRIVEWAY, PAVED, PCC, 7 INCH
	A. REFER TO SHEET C.08 FOR TABULATION. REFER TO F SHEETS FOR LAYOUT. ITEMS INCLUDES SCORING, DECORATIVE JOINTING AND REINFORCEMENT.
	B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE.
-108-H-1	DRIVEWAY, PAVED, PCC, 10 INCH
100-11-1	A. ITEM IS FOR TRUCK ALTERNATE DRIVEWAY. REFER TO SHEET E.02 FOR LAYOUT.
	B. ALL CONCRETE SHALL BE CLASS C AND MEET MINIMUM FLEXURAL STRENGTH REQUIREMENT OF 550 PSI AT 28 DAYS. AREAS NOT MEETING THIS REQUIREMENT SHALL BE SUBJECT TO REPAIRS, REPLACEMENT OR REDUCED PAYMENT AS DETERMINED BY THE ENGINEER AND TEST RESULTS WILL REPRESENT ALL CONCRETE PLACED IN THE SAME LOT. COLD WEATHER CONCRETE WILL BE CONSIDERED INCIDENTAL IF REQUIRED. CRACKED PANELS SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE UNLESS, IN THE JUDGEMENT OF THE ENGINEER, CRACK ROUTING AND SEALING IS ACCEPTABLE.





7040-108-H-0

8020-108-B-0

9010-108-B-0

9020-108-A-0

9030-108-B-0

9030-108-B-0

9030-108-B-0

9030-108-B-0

9040-108-A-2

9040-108-D-1

9040-108-N-1

9040-108-T-1

11,010-108-A

11,020-108-A

11,050-108-A

12010-XXX-X-1

PAVEMENT REMOVAL

A. THE THICKNESS OF THE EXISTING PAVEMENT IS VARIABLE. SEE BORING LOGS FOR PAVEMENT THICKNESS. PAVEMENT TYPE VARIES FROM PCC TO HMA TO A MIXTURE OF PCC AND HMA. UNIT PRICE SHALL BE FULL COMPENSATION FOR REMOVAL OF PAVEMENT REGARDLESS OF

A. ALL PAVEMENT MARKINGS SHALL BE IN ACCORDANCE WITH THE CURRENT EDITION OF THE MANUAL ON UNIFORM TRAFFIC CONTROL DEVICES (MUTCD) PART 3. PAVEMENT SHALL BE CLEAN AND FREE OF ALL DEBRIS AND CURE PRIOR TO PAINTING. METHOD OF CLEANING SHALL BE BY HIGH PRESSURE WATER BLASTING. ITEM INCLUDES ENOUGH QUANTITY TO PAINT THE PROJECT TWICE. ONCE AT THE COMPLETION OF EACH PHASE

B. THIS ITEM INCLUDES REMOVAL OF ROCK AND OTHER DEBRIS, REPAIRING RILLS AND WASHES, SEEDBED PREPARATION, FURNISHING AND PLACEMENT OF SEED, FURNISHING, PLACEMENT, AND INCORPORATING FERTILIZER AND MULCH, FURNISHING WATER AND OTHER CARE, AND ANY RESEEDING NECESSARY UNTIL FINAL ACCEPTANCE. THE CONTRACTOR IS RESPONSIBLE FOR MOWING AND MAINTAINING SEEDED AREAS UNTIL THE PROJECT IS ACCEPTED BY THE OWNER. SEEDING OF AREAS DISTURBED OUTSIDE OF THE CONSTRUCTION LIMITS SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR AT NO ADDITIONAL COST TO THE OWNER. SEE SHEET T.01 FOR SEEDING NOTES, MULCH SHALL BE

A. SOD ALL AREAS DISTURBED BY CONSTRUCTION UNLESS INDICATED ON PLANS. COST FOR WATERING SHALL BE CONSIDERED INCIDENTAL TO THIS ITEM. ROCK PICKING, FINISH GRADING, AND REWORK, INCLUDING REGRADING AND ADJUSTING GRADING, ARE CONSIDERED INCIDENTAL TO THIS ITEM. CONTRACTOR RESPONSIBLE FOR PROTECTING ALL SODDED AREAS THROUGH ESTABLISHMENT AND ACCEPTANCE. CONTRACTOR RESPONSIBLE FOR MOWING AND MAINTAINING SODDED AREAS UNTIL PROJECT IS ACCEPTED BY OWNER. SODDING OF DISTURBED AREAS

A. THIS ITEM INCLUDES LABOR, MATERIAL, AND EQUIPMENT TO FURNISH AND INSTALL DECIDUOUS SHRUBS IN ACCORDANCE WITH SUDAS SECTION 9030 AND AMENDED AS FOLLOWS: PLANTINGS SHALL HAVE ONE YEAR WARRANTY FROM DATE OF FINAL ACCEPTANCE FOR ALL PLANTINGS IN THE PROJECT. ACCEPTANCE OF PLANT MATERIALS CONSTRUES FULL PAYMENT (MINUS ANY PROJECT RETAINAGE). INCLUDES ALL BUT NOT LIMITED TO, AMENDED SOILS DELIVERY, EXCAVATION, INSTALLATION, MULCHING, HERBICIDE, MAINTENANCE DURING ESTABLISHMENT PERIOD, AND WARRANTY AND REJECTION REPLACEMENTS. AMENDED PLANTING SOIL IS CONSIDERED INCIDENTAL TO THIS ITEM. SEE T SHEETS

A. THIS ITEM INCLUDES LABOR, MATERIAL, AND EQUIPMENT TO FURNISH AND INSTALL ORNAMENTAL TREE IN ACCORDANCE WITH SUDAS SECTION 9030 AND AMENDED AS FOLLOWS: PLANTINGS SHALL HAVE ONE YEAR WARRANTY FROM DATE OF FINAL ACCEPTANCE FOR ALL PLANTINGS IN THE PROJECT. ACCEPTANCE OF PLANT MATERIALS CONSTRUES FULL PAYMENT (MINUS ANY PROJECT RETAINAGE). INCLUDES ALL BUT NOT LIMITED TO, AMENDED SOILS DELIVERY, EXCAVATION, INSTALLATION, MULCHING, HERBICIDE, MAINTENANCE DURING ESTABLISHMENT PERIOD, AND WARRANTY AND REJECTION REPLACEMENTS. AMENDED PLANTING SOIL IS CONSIDERED INCIDENTAL TO THIS ITEM. SEE T SHEETS

A. THIS ITEM INCLUDES LABOR, MATERIAL, AND EQUIPMENT TO FURNISH AND INSTALL PERENNIAL GROUND COVER (1 GAL) IN ACCORDANCE WITH SUDAS SECTION 9030 AND AMENDED AS FOLLOWS: PLANTINGS SHALL HAVE ONE YEAR WARRANTY FROM DATE OF FINAL ACCEPTANCE FOR ALL PLANTINGS IN THE PROJECT. ACCEPTANCE OF PLANT MATERIALS CONSTRUES FULL PAYMENT (MINUS ANY PROJECT RETAINAGE). INCLUDES ALL, BUT NOT LIMITED TO, AMENDED SOILS DELIVERY, EXCAVATION, INSTALLATION, MULCHING, HERBICIDE, MAINTENANCE DURING ESTABLISHMENT PERIOD. AND WARRANTY AND REJECTION REPLACEMENTS. AMENDED PLANTING SOIL IS CONSIDERED INCIDENTAL TO THIS ITEM. SEE T SHEETS

A. THIS ITEM INCLUDES LABOR, MATERIAL, AND EQUIPMENT TO FURNISH AND INSTALL DECIDUOUS TREE IN ACCORDANCE WITH SUDAS SECTION 9030 AND AMENDED AS FOLLOWS: PLANTINGS SHALL HAVE ONE YEAR WARRANTY FROM DATE OF FINAL ACCEPTANCE FOR ALL PLANTINGS IN THE PROJECT. ACCEPTANCE OF PLANT MATERIALS CONSTRUES FULL PAYMENT (MINUS ANY PROJECT RETAINAGE). INCLUDES ALL, BUT NOT LIMITED TO, AMENDED SOILS DELIVERY, EXCAVATION, INSTALLATION, MULCHING, HERBICIDE, MAINTENANCE DURING ESTABLISHMENT PERIOD, AND WARRANTY AND REJECTION REPLACEMENTS. AMENDED PLANTING SOIL IS CONSIDERED INCIDENTAL TO THIS ITEM. SEE T SHEETS FOR

A. INSPECTIONS WILL MEET THE REQUIREMENTS AS SET FORTH IN THE NPDES GENERAL PERMIT NO. 2 AND SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR. THE CONTRACTOR SHALL MAINTAIN COPIES OF THE SWPPP PLAN AND ALL INSPECTION REPORTS AND SHALL BE RESPONSIBLE FOR ALL INSPECTIONS UNTIL THE NOTICE OF DISCONTINUATION. WEEKLY INSPECTIONS SHALL BE REQUIRED AND ALL REPORTS

A. QUANTITY IS AN ASSUMED AMOUNT NEEDED FOR EROSION CONTROL. QUANTITY SHALL BE FIELD MEASURED FOR FINAL PAYMENT. ITEM

A. ALL DEVICES SHALL BE DROP IN STYLE AS PER SUDAS 9040-2.18-A. ADDITIONAL QUANTITY, IF REQUIRED, SHALL BE APPROVED BY THE ENGINEER PRIOR TO PLACEMENT. REMOVAL OF INLET PROTECTION DEVICE SHALL BE CONSIDERED INCIDENTAL. SILT TRAPPED IN THE DEVICE

A. ITEM IS AN ASSUMED AMOUNT NEEDED FOR EROSION CONTROL. QUANTITY SHALL BE FIELD MEASURED FOR FINAL PAYMENT. ITEM INCLUDES

A. THIS ITEM IS FOR ALL SURVEY WORK NECESSARY FOR CONSTRUCTION OF THIS PROJECT AS DETAILED ON THE CONSTRUCTION DOCUMENTS

A. THIS ITEM IS FOR ALL PREPARATORY WORK AND COSTS INCURRED BEFORE BEGINNING THE WORK ON THE PROJECT AND DURING THE PROJECT. THIS ITEM SHALL ALSO INCLUDE THE COSTS FOR ANY STAGED CONSTRUCTION AND EQUIPMENT SET UP TO COMPLETE THE WORK.

N. THIS PAY ITEM INCLUDES FURNISHING AND THE PERIODIC CLEAN OUT AND MAINTENANCE OF THE WASHOUT AREA AS DIRECTED BY THE

A. THIS ITEM INCLUDES LABOR, MATERIALS AND EQUIPMENT TO FURNISH AND INSTALL LIMESTONE EDGER. SEE T SHEETS FOR LOCATIONS AND U

THICKNESS, TYPE, AND REINFORCING, SEE R SHEETS FOR REMOVAL LIMITS AND BORING LOGS.

A SEED FERTILIZE AND MULCH ALL AREAS WHERE INDICATED ON PLANS. SEEDING SHALL BE TYPE 1.

OUTSIDE OF CONSTRUCTION LIMITS SHALL BE RESPONSIBILITY OF CONTRACTOR AT NO ADDITIONAL COST TO OWNER.

AND ONCE AT THE END OF THE PROJECT. SEE N SHEETS FOR LAYOUT AND TABULATION.

PAINTED PAVEMENT MARKINGS, SOLVENT/WATERBORNE

SEEDING, FERTILIZING & HYDROMULCHING

BONDED FIBER MATRIX (BFM)

DECIDUOUS SHRUBS

ORNAMENTAL TREE

FOR LOCATIONS AND PLANT LIST.

FOR LOCATIONS AND PLANT LIST.

FOR LOCATIONS AND PLANT LIST

LOCATIONS AND PLANT LIST.

SWPPP MANAGEMENT

COPIED TO THE CITY.

FILTER SOCKS, 12 INCH

CONSTRUCTION SURVEY

CONCRETE WASHOUT

MORII IZATION

SILT FENCE OR SILT FENCE DITCH CHECK

INLET PROTECTION DEVICE, DROP IN PROTECTION

THIS ITEM TO BE PAID PER SUDAS 11,020, 1,08A

INCLUDES INSTALLATION, MAINTENANCE AND REMOVAL OF FILTER SOCKS.

AND APPROVED REVISIONS. ELECRONIC DRAWING ARE AVAILABLE FOR THE CONTRACTORS USE.

SHEETS FOR DETAILS. ITEM SHALL BE FIELD MEASURED FOR PAYMENT ON A LINEAR FOOT BASIS

INSTALLATION, MAINTENANCE AND REMOVAL OF SILT FENCE.

SHALL BE REMOVED AND DISPOSED OF AT NO ADDITIONAL COST.

ENGINEER. CONCRETE WASHOUT SHALL BE NOTED IN THE SWPPP.

B. SEE SUPPLEMENTAL SPECIFICATIONS FOR ADDITIONAL INFORMATION.

DECIDUOUS TREE

PERENNIAL GROUND COVER (1 GAL)

62

63

64

65

66

68

69

70

71

72

73

74

75

76

77

855 WRIGHT BROTHERS BLVD SW, SUITE 2A
CEDAR RAPIDS, IOWA 52404
Phone: (319) 362-3219
Email: CedarRapids@bolton-menk.com
www.bolton-menk.com

	REV	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
				JGS	2ND & MULBERRY ROUNDABOUT
				CHECKED	ESTIMATE REFERENCE NOTES
_					

C.04

78	12010-XXX-X-2	BOULDER SEATWALLS						
		A. THIS ITEM INCLUDES LABOR, MATERIALS AND EQUIPMENT TO FURNISH AND INSTALL BOULDER SEATWALLS. SEE T SHEETS FOR LOCATIONS AND U SHEETS FOR DETAILS. ITEM SHALL BE FIELD MEASURED FOR PAYMENT PER LINEAR FOOT ALONG THE FRONT FACE OF INSTALLED SEATWALL.						
		B. SEE SUPPLEMENTAL SPECIFICATIONS FOR ADDITIONAL INFORMATION.						
79	12,020-XXX-X-1	DUCT BANK, 3x2 CONFIGURATION						
		A. REFER TO SHEETS M.11 THRU M.13 FOR LAYOUT AND DETAILS. REFER TO SHEET C.09 FOR TABULATION. COHESIVE BACKFILL MATERIAL SHALL BE USED AS SUITABLE BACKFILL MATERIAL TO FILL IN TRENCH. THIS ITEM SHALL INCLUDE EXCAVATION, COMPACTION, CONSTRUCTION OF DUCT BANK, COLORED CONCRETE, AND MAGNETIC MARKING TAPE AND COPPER WIRE PER DETAIL 1 ON SHEET M.13. FINAL ACCEPTANCE OF DUCT BANK SHALL BE AFTER THE COMPLETION OF A SUCCESSFUL MANDREL TEST. CONTRACTOR SHALL INCLUDE 'USE TAX' ON MATERIAL AND ANY COST ASSOCIATED WITH THIS MATERIAL (I.E. ADHESIVE, CAPS, ETC.) IN THE UNIT BID COST. NO 'USE TAX' IS REQUIRED ON LABOR. B. THE MATERIAL SHALL BE 6-INCH SCHEDULE 40 PVC. IN EACH CONDUIT INSTALL 1/2 INCH POLYESTER PULLING TAPE WITH A MINIMUM BREAKING STRENGTH OF 1,000 LB AND MEASUREMENT MARKINGS. CONDUIT SHALL BE CONSTRUCTED USING STANDARD DUCT SPACERS EVERY 6-1/2' TO 7' TO MAINTAIN A MINIMUM 2' SEPARATION BETWEEN DUCTS. BOTH ENDS OF CONDUIT SHALL BE SEALED. METHOD OF MEASUREMENT IS FROM EDGE OF STRUCTURE TO EDGE OF STRUCTURE.						
80	12,030-XXX-X-1	ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 6-INCH						
		A. REFER TO SHEETS M.11 THRU M.13 FOR LAYOUT AND DETAILS. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM INCLUDES MATERIAL AND INSTALLATION OF ALL ELECTRICAL CONDUIT MATERIALS INCLUDING SWEEPS INTO ELECTRICAL INFRASTRUCTURE. THIS ITEM INCLUDES TRENCHING, BACKFILL, AND COMPACTION. THE MATERIAL SHALL BE 6-INCH HOPE, SDR 17, BLACK WITH A RED STRIPE OR SCHEDULE 40 PVC. IN EACH CONDUIT INSTALL 1/2 INCH MULE TAPE WITH A MINIMUM BREAKING STRENGTH OF 1,000 LB. BOTH ENDS OF CONDUIT SHALL BE SEALED. METHOD OF MEASUREMENT IS FROM CENTER OF STRUCTURE TO CENTER OF STRUCTURE. CONDUIT INSTALLATION ACCEPTANCE VIA SUCCESFUL MANDRAL TESTING BY CONTRACTOR. CONTRACTOR SHALL INCLUDE 'USE TAX' ON MATERIAL AND ANY COST ASSOCIATED WITH THIS MATERIAL (i.e. ADHESIVE, CAPS, ETC.) IN THE UNIT BID COST. NO 'USE TAX' IS REQUIRED ON LABOR.						
81	12,030-XXX-X-2	ELECTRICAL CONDUIT, OPEN CUT, HDPE OR PVC, 2-INCH						
		A. REFER TO SHEETS M.11 THRU M.13 FOR LAYOUT AND DETAILS. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM INCLUDES MATERIAL AND INSTALLATION OF ALL ELECTRICAL CONDUIT MATERIALS INCLUDING SWEEPS INTO ELECTRICAL INFRASTRUCTURE. THIS ITEM INCLUDES TRENCHING, BACKFILL, AND COMPACTION. THE MATERIAL SHALL BE 2-INCH HDPE, SDR 13.5, BLACK WITH A RED STRIPE OR SCHEDULE 40 PVC. IN EACH CONDUIT INSTALL 1/2 INCH MULE TAPE WITH A MINIMUM BREAKING STRENGTH OF 1,000 LB. BOTH ENDS OF CONDUIT SHALL BE SEALED. METHOD OF MEASUREMENT IS FROM CENTER OF STRUCTURE TO CENTER OF STRUCTURE. CONDUIT INSTALLATION ACCEPTANCE VIA SUCCESSFUL MANDRAL TESTING BY CONTRACTOR. CONTRACTOR SHALL INCUE "USE TAX" ON MATERIAL AND ANY COST ASSOCIATED WITH THIS MATERIAL (i.e. ADHESIVE, CAPS, ETC.) IN THE UNIT BID COST. NO "USE TAX" IS REQUIRED ON LABOR.						
82	2 12,030-XXX-X-3	JUNCTION BOX, ELECTRICAL, 13"x24"						
		A. REFER TO SHEETS M.11 THRU M.13 FOR LAYOUT AND DETAILS. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM INCLUDES EXCAVATION, GRANULAR BASE, SUITABLE BACKFILL, AND COMPACTION. FURNISH AND INSTALL JUNCTION BOX AND LID. CONTRACTOR SHALL INCLUDE 'USE TAX' ON MATERIAL IN THE UNIT BID COST. NO 'USE TAX' IS REQUIRED ON LABOR.						
83	12,030-XXX-X-4	JUNCTION BOX, ELECTRICAL, 10" DIAMETER						
		A. REFER TO SHEETS M.11 THRU M.13 FOR LAYOUT AND DETAILS. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM INCLUDES EXCAVATION, GRANULAR BASE, SUITABLE BACKFILL, AND COMPACTION. FURNISH AND INSTALL JUNCTION BOX AND LID. CONTRACTOR SHALL INCLUDE 'USE TAX' ON MATERIAL IN THE UNIT BID COST. NO 'USE TAX' IS REQUIRED ON LABOR.						
84	12,030-XXX-X-5	FOUNDATION, STREET LIGHT						
		A. REFER TO SHEETS M.11 THRU M.13 FOR LAYOUT AND DETAILS. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM SHALL INCLUDE EXCAVATION FOR FOUNDATION, CONSTRUCTION FORMS, INSTALLATION OF CONDUIT FROM FOUNDATION TO JUNCTION, 10"X15" JUNCTION BOX, CONCRETE, GRANULAR BACKFILL AND COMPACTION. CONTRACTOR SHALL INCLUDE 'USE TAX' ON MATERIAL IN THE UNIT BID COST. NO 'USE TAX IS REQUIRED ON LABOR.						
85	12,040-XXX-X-1	COMMUNICATION CONDUIT, OPEN CUT, HDPE, QUAD DUCT (4x1.5-INCH)						
		A. REFER TO SHEETS M.11 THRU M.13 FOR LAYOUT AND DETAILS. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM INCLUDES MATERIAL AND INSTALLATION OF ALL ELECTRICAL CONDUIT MATERIALS INCLUDING SWEEPS INTO ELECTRICAL INFRASTRUCTURE. THIS ITEM INCLUDES TRENCHING, BACKFILL, AND COMPACTION. THE MATERIAL SHALL BE FOUR (4) 1.50-INCH HDPE, SDR 15.5, COLORS: WHITE, PURPLE, BLACK, ORANGE, WITH PULL STRING. BOTH ENDS OF CONDUIT SHALL BE SEALED. METHOD OF MEASUREMENT IS FROM CENTER OF STRUCTURE TO CENTER OF STRUCTURE. CONTRACTOR SHALL INCLUDE 'USE TAX' ON MATERIAL AND ANY COST ASSOCIATED WITH THIS MATERIAL (i.e. ADHESIVE, CAPS, ETC.) IN THE UNIT BID COST. NO 'USE TAX' IS REQUIRED ON LABOR.						
86	12,040-XXX-X-2	HAND HOLE, COMMUNICATIONS, 30"x48"						
		A. REFER TO SHEETS M.11 THRU M.13 FOR LAYOUT AND DETAILS. REFER TO SHEET C.09 FOR TABULATION. THIS ITEM INCLUDES EXCAVATION, GRANULAR BASE, COMPACTION, FURNISHING AND INSTALLATION OF HAND HOLE BOX AND LID, AND BACKFILL. CONTRACTOR SHALL INCLUDE 'USE TAX' ON MATERIAL IN THE UNIT BID COST. NO 'USE TAX' IS REQUIRED ON LABOR.						





	855 WRIGHT BROTHERS BLVD SW. SUITE 2A	
ŀ	CEDAR RAPIDS, IOWA 52404	
ı	Phone: (319) 362-3219	
•	Email: CedarRapids@bolton-menk.com	
	www.bolton-menk.com	

REV	EV ISSUED FOR DATE JGS			CITY OF MUSCATINE, IOWA
			JGS	2ND & MULBERRY ROUNDABOUT
			CHECKED	ESTIMATE REFERENCE NOTES

STORM SEWER STRUCTURE TABLE							
Structure Name	STATION	OFFSET	TYPE	RIM/FG	FL INFO		
EX AREA DRAIN	9+08.15	-114.97	EX AREA DRAIN	555.68	FL: 554.45 (Out) SE		
EX MH	6+37.70	0.00	EX STRM MH, 60-IN	555.39	FL: 550.37 (In) N		
INT-2	7+38.79	24.03	SW-501	556.48	FL: 552.31 (Out) W		
INT-3	7+43.64	-21.32	SW-501	556.60	FL: 552.31 (Out) E		
INT-5	9+90.03	-24.60	SW-501	561.35	FL: 555.68 (In) NW FL: 555.58 (Out) SE FL: 556.34 (In) NE		
INT-6	11+01.07	20.35	SW-501	567.68	FL: 563.87 (In) SW FL: 559.56 (Out) SE		
INT-7	11+09.60	-19.49	SW-501	567.93	FL: 564.37 (Out) NE FL: 564.62 (In) NW		
INT-8 INT-9	12+95.88	-17.54	SW-501	574.61	FL: 570.52 (In) S FL: 570.38 (Out) SE		
	12+79.19	-31.43	SW-501	574.17	FL: 570.74 (Out) N		
INT-10	8+28.71	-102.41	SW-501	560.11	FL: 556.73 (In) NW FL: 556.53 (Out) E		
INT-11	8+73.90	-115.14	SW-501	560.40	FL: 557.13 (Out) SE FL: 557.13 (In) NW		
INT-12	7+99.31	30.79	SW-501	557.14	FL: 553.20 (In) N FL: 553.10 (Out) W		
INT-13	8+66.06	83.62	SW-501	556.76	FL: 554.08 (Out) S FL: 554.08 (In) NW		
INT-14	NT-14 8+92.77		SW-501	558.21	FL: 555.24 (In) NE		
INT-15	8+94.72	82.97	SW-501	557.75	FL: 555.24 (Out) SW		
INT-16	9+76.99	31.82	SW-501	560.46	FL: 557.50 (Out) SW		
STMH-1	7+41.13	1.37	SW-401	556.91	FL: 551.97 (In) N FL: 551.87 (Out) S FL: 551.97 (In) E FL: 551.97 (In) W		
STMH-4	8+09.09	-3.03	SW-503	557.87	FL: 554.50 (In) W FL: 552.88 (In) NW FL: 552.65 (Out) S FL: 552.75 (In) E		

	STORM SEWERIPE TABLE								
Pipe Name PIPE TYPE		Length	Slope	START INVERT	END INVERT	FROM STRUCTURE	TO STRUCTURE		
P-1	18" Ø RCP	103.0	1.45%	551.87	550.37	STMH-1	EX MH		
P-2	15" Ø RCP	22.8	1.50%	552.31	551.97	INT-2	STMH-1		
P-3	15" Ø RCP	22.8	1.50%	552.31	551.97	INT-3	STMH-1		
P-4	18" Ø RCP	68.0	1.00%	552.65	551.97	STMH-4	STMH-1		
P-5	15" Ø RCP	161.7	1.67%	555.58	552.88	INT-5	STMH-4		
P-6	15" Ø RCP	111.9	3.48%	559.56	555.68	INT-6	INT-5		
P-7	15" Ø RCP	40.7	1.23%	564.37	563.87	INT-7	INT-6		
P-8	15" Ø RCP	189.3	3.04%	570.38	564.62	INT-8	INT-7		
P-9	15" Ø RCP	21.7	1.00%	570.74	570.52	INT-9	INT-8		
P-10	15" Ø RCP	101.1	2.01%	556.53	554.50	INT-10	STMH-4		
P-11	15" Ø RCP	42.3	0.95%	557.13	556.73	INT-11	INT-10		
P-11A	15" Ø RCP	9.6	-27.98%	554.45	557.13	EX AREA DRAIN	INT-11		
P-12	15" Ø RCP	35.2	1.00%	553.10	552.75	INT-12	STMH-4		
P-13	15" Ø RCP	88.1	1.00%	554.08	553.20	INT-13	INT-12		
P-14	15" Ø RCP	40.1	1.00%	554.48	554.08		INT-13		
P-15	15" Ø RCP	19.4	0.00%	555.24	555.24	INT-15	INT-14		
P-16	15" Ø RCP	57.9	2.00%	557.50	556.34	INT-16	INT-5		

PIPE TABULATION							
MATERIAL SIZE LENGTH (LF)							
RCP (STORM)	15"	971					
RCP (STORM)	18"	189					
PVC (SANITARY)	8"	671					

STRUCTURE TABULATION						
TYPE	QTY					
SW-301	2					
SW-401	1					
SW-501	14					
SW-503	1					

SANITARY SEWER STRUCTURE TABLE								
Structure Name	STATION	OFFSET	TYPE	TYPE RIM/FG				
EXMH-1	6+29.90	-12.74	SSWR-MH-EC-N 60	554.57	FL: 545.59 (In) NW			
FERNCO COUPLER 8+88.38		-88.04	Null Structure	553.68	FL: 552.91 (Out) NW FL: 552.91 (Out) SE			
FERNCO COUPLER 8+61.21		-83.03	Null Structure	552.93	FL: 552.15 (In) NW FL: 552.15 (Out) SE			
SSMH-1 8+47.09 -79.		-79.33	SSWR-MH-EC-N 60	559.45	FL: 551.56 (In) NW FL: 551.56 (Out) SE FL: 552.00 (In) SW			
SSMH-2	12+49.35	-10.14	SSWR-MH-EC-N 60	573.98	FL: 565.44 (In) SE			

SANITARY SEWER PIPE TABLE									
Pipe Name	PIPE TYPE Length Slope START END FROM TO STRUCTURE STRUCTURE								
P-21	8" Ø PVC	226.2	2.64%	551.56	545.59	SSMH-1	EXMH-1		
P-22	8" Ø PVC	13.5	4.38%	552.15	551.56	FERNCO COUPLER	SSMH-1		
P-23	8" Ø C900 PVC	20.0	3.78%	552.91	552.15	FERNCO COUPLER	FERNCO COUPLER		
P-24	8" Ø PVC	324.4	-3.86%	565.44	552.91	SSMH-2	FERNCO COUPLER		
P-25	8 inch PVC Pipe	86.1	2.17%	553.87	552.00		SSMH-1		
Pipe - (9)	4 inch PVC Pipe	39.4	2.54%	561.00	560.00				

SANITARY SEWER SERVICE						
STATION	REMARKS					
20+79	UNKNOWN					
20+83	UNKNOWN					
12+00	UNKNOWN	DEKOCK LAW FIRM SERVICE LOCATION UNKNOWN, CONTRACTOR SHALL LOCATE AND RESTORE				









٨	REV	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
				JGS	2ND & MULBERRY ROUNDABOUT
				CHECKED	STORM & SANITARY TABULATIONS
				ALH	3131111 4 37 11 11 11 11 17 17 18 18 18 18 18 18 18 18 18 18 18 18 18

	REMOVAL OF DRIVEWAYS									
BEGIN STATION	END STATION	SIDE	PAVEMENT TYPE	AREA	REMARKS					
6+67.21	6+86.62	LT	CONCRETE	24.3						
6+74.82	7+10.71	RT	CONCRETE	126.7						
10+24.36	10+49.61	LT	CONCRETE	35.4						
10+65.75	10+84.50	RT	CONCRETE	61.9						
10+82.45	10+94.00	LT	CONCRETE	19.2						
	ТОТ	AL:		267.4						

	REMOVAL OF SIDEWALKS								
BEGIN STATION	END STATION	SIDE S	ABRA	REMARKS					
6+30.16	6+64.95	LT	51.1						
6+37.92	6+83.59	RT	41.6						
6+84.64	8+29.11	LT	144.2						
7+05.83	8+30.85	RT	128.3						
8+98.25	10+62.55	RT	160.3						
8+73.46	10+84.64	LT	75.8						
10+52.00	10+83.71	LT	66.9						
10+84.34	11+11.88	RT	27.3						
10+95.32	12+40.00	LT	184.5						
12+30.57	12+44.50	RT	14.9						
12+75.9	12+89.10	RT	14.2						
12+80.22	12+98.93	LT	26.0						
21+04.91	21+49.71	LT	53.0						
21+19.55	21+51.45	RT	31.3						
22+21.88	24+52.10	RT	198.0						
22+09.58	24+52.10	LT	223.7						
TOTA	L:		1441.0						

	REMOVAL OF STREET LIGHTS					
	LOCATION					
7+28, 56' LT						
	7+86, 29' LT					
	7+91, 77' LT					
	9+78, 48' LT					
	10+51, 3' LT					
	10+55, 56' LT					
	21+49, 21' RT					
	21+58, 39' LT					
	22+33, 39' RT					
	22+33, 25' LT					
	23+40, 22' RT					
	23+74, 25' LT					
	24+60, 24' RT					

REMOVAL OF TRAFFIC SIGNALS
LOCATION
21+44, 22'LT
21+58, 34' RT
22+08, 37' LT


REMOVAL OF FIRE HYDRANTS
STA. 110+64, 43.4' RT
STA. 120+36, 18' RT
STA. 121+70, 16 RT

PIPE REMOVAL TABLE										
ALIGNMENT	STA	OFF	то	STA	OFF	TYPE	MATERIAL	SIZE	LENGTH (LF)	REMARKS
MULBERRY	6+30.50	0.00		8+54.62	-70.25	STM	RCP	15"	225	
MULBERRY	6+30.40	-12.75		12+50.00	-10.25	SAN	Clay	8-12"	580	
2ND STREET	20+69.00	10.25		21+69.00	12.00	SAN	Clay	8"	100	
2ND STREET	21+46.25	17.5		21+83.50	5.50	STM	RCP	12-15"	38	
2ND STREET	21+46.50	-18.75		21+83.50	5.50	STM	RCP	12-15"	44	
2ND STREET	21+83.50	5.5		21+98.50	-34.50	STM	RCP	12-15"	43	
2ND STREET	21+98.50	-34.5		22+35.75	-45.50	STM	RCP	12-15"	39	
MULBERRY	12+50.00	-10.25		12+96.00	-17.50	STM	RCP	12-15"	48	
MULBERRY	12+77.80	-31.46		12+96.00	-17.50	STM	RCP	12-15"	23	
2ND STREET	21+46.50	-18.75		21+47.00	-33.00	STM	RCP	12-15"	14	
							TOTALS:	SAN -	680	LF
								STM -	474	LF

	STRUCTURES RE	MOVAL TABLE		
ALIGN	STATION	OFFSET	TYPE	REMARKS
2ND ST	21+46.00	18.00	INTAKE	DOUBLE
2ND ST	21+46.50	-19.00	INTAKE	DOUBLE
2ND ST	21+69.00	9.37	SAN MH	
2ND ST	21+83.50	5.39	STM MH	
2ND ST	21+98.50	-34.40	INTAKE	
2ND ST	22+35.85	-45.64	INTAKE	
2ND ST	22+71.00	9+75	SAN MH	
MULBERRY	12+49.50	-10.00	SAN MH	
MULBERRY	12+77.75	-31.50	INTAKE	
MULBERRY	12+96.00	-17.70	INTAKE	
	TOTALS:	INTAKES	6	
		MANHOLES	4	



PCC PAVEMENT



	LOCATION			AREAS				
ROAD IDENTIFICATION	DIRECTION OF TRAVEL	STATION	TO STATION	A SY	B SY	C SY	D SY	E SY
MULBERRY	вотн	5+85	7+08			437.8		
MULBERRY	NB	7+08	8+13	223.7				
MULBERRY	SB	7+08	8+13		210.4			
MULBERRY	ROUND	8+13	9+46				1142.1	
MULBERRY	ROUND	8+13	9+46					373.9
MULBERRY	NB	9+46	10+51	270.5				
MULBERRY	SB	9+45	10+51		223.73			
MULBERRY	вотн	10+51	11+29			355.9		
2ND	BOTH	80+81	81+09			122.1		
2ND	EB	81+09	82+12	230.7				
2ND	WB	81+09	82+12		219.2			
2ND	EB	83+43	84+14	170.3				
2ND	WB	83+43	84+14		150.5			
2ND	BOTH	84+14	84+72			273.3		
			SUBTOTALS:	895.2	803.83	1189.07	1142.1	373.9
	I		TOTAL:	4404.1			1	1

HMA PAVEMENT

	AREAS			
ROAD IDENTIFICATION	DIRECTION OF TRAVEL		O STATION	SY
MULBERRY	SB	12+99	11+29	353.1

SIDEWALK PAVEMENT

	LOCATION					AREA		
ROAD				WIDTH	5" PCC SIDEWALK	10" PCC RAMP	DETECTABLE WARNINGS	
IDENTIFICATION	STATION T	O STATION	SIDE	FT	SY	SY	SF	
MULBERRY	5+85	6+87	RT	6	61.5			
MULBERRY	7+23	8+89	RT	6	188.2			
MULBERRY	5+85	6+67	LT	10	121.1			
MULBERRY	6+95	8+31	LT	6	117			
MULBERRY	9+06	11+11	RT	5	209.7			
MULBERRY	8+58	10+13	LT	6	107.6			
MULBERRY	10+42	10+83	LT	6	33.7			
MULBERRY	10+96	11+29	LT	11	49.8			
MULBERRY	11+29	12+39	LT	10	107.2			
MULBERRY	12+80	12+99	LT	9	25.9			
2ND	21+60	21+66	RT	6		11.1	12	
2ND	21+66	21+72	RT	6		3.69	12	
2ND	21+66	21+72	LT	6		4.1	12	
2ND	21+62	21+68	LT	6		6.2	12	
2ND	23+54	23+58	RT	6		4.2	10	
2ND	23+48	23+53	RT	6		3.2	10	
2ND	23+47	23+52	LT	6		3.3	10	
2ND	23+51	23+56	LT	6		3	10	
MULBERRY	7+75	7+81	RT	6		5.8	12	
MULBERRY	7+76	7+81	RT	6		6.03	12	
MULBERRY	7+74	7+79	LT	6		6.6	12	
MULBERRY	7+68	7+74	LT	6		8.6	12	
MULBERRY	9+73	9+68	RT	6		2.8	10	
MULBERRY	9+64	9+68	RT	6		6.8	10	
MULBERRY	9+65	9+70	LT	6		5.56	10	
MULBERRY	9+77	9+82	LT	6		6.92	10	
				TOTALS:	1021.7	87.9	176	

	DRIVEWAYS, PAVED						
STATION	SIDE	1 1/2" DROPPED	WIDTH	RADIUS	DRIVEWAY SURFACE AREA		
		CURB			PCC		
		FT	FT	FT	SY		
7+01.99	RT	68	25	VARIES	106		
6+81.09	LT	67	22	VARIES	70.6		
10+21.44	LT	48	30	9	206.4		
10+64.39	RT	31.1	20		37.5		
10+89.32	LT	39	15	15	43.5		
21+10.15	LT	14.1	16		8.7		
21+35.39	LT	15.3	16		6.5		
				TOTAL:	479.2		

CURB AND GUTTER

TATION TO STATION		SIDE	CURB HEIGHT	WIDTH	LENGTH
			IN	FT	FT
1+28.70	12+39.24	LT	6	3	117.7
2+30.46	12+44.53	RT	6	3	24.0
2+80.19	12+98.90	LT	6	3	30.8
2+75.88	12+89.04	RT	6	3	20.5
				TOTAL:	193.0





C.08

COMMUNCATIONS - HAND HOLES			
LOCATION	SIZE		
6+90, 36' LT	30"X48"		
23+74, 25' RT	30"X48"		

COMMUNCATIONS CONDUIT, QUAD DUCT					
LOCATION	CONDUIT TYPE	LENGTH	LOCATION		
5+88, 15' LT	QUAD DUCT	109	6+90, 36' LT		
6+90, 36' LT	QUAD DUCT	270	23+74, 25' RT		
23+74, 25' RT	QUAD DUCT	195	23+90, 166' LT		
23+74, 25' RT	QUAD DUCT	73	24+48, 19' RT		

JUNCTION BOXES				
LOCATION	SIZE			
10+92, 21' RT	13"X24"			
11+08, 33' LT	13"X24"			
8+79	10" DIA.			

STRE	STREET LIGHTS, STREET LIGHT					
LIGHT NO.	LOCATION	JUNCTION BOX TYPE				
1	6+52, 13' RT	8"X18"				
2	7+28, 23' LT	8"X18"				
3	8+15, 40' RT	8"X18"				
4	8+18, 49' LT	8"X18"				
5	9+30, 46' RT	8"X18"				
6	9+50, 43' LT	8"X18"				
7	9+92, 32' RT	8"X18"				
8	10+56, 28' LT	8"X18"				
9	23+48, 35' RT	8"X18"				
10	24+22, 26' LT	8"X18"				

TRANSMISSION - 69kV DUCT BANK				
LOCATION	LENGTH	LOCATION	COMMENTS	
STA. 201+37	381'	STA. 205+18	3X2 CONFIGURATION	

	ELECTRICAL 2-INCH LIGHT FEED CONDUIT				
LOCATION	LENGTH	LOCATION	COMMENTS		
6+52, 13' RT	159'	8+15, 40' RT	LIGHT NO. 1 TO LIGHT NO. 3		
22+80, 62' RT	87'	23+48, 35' RT	LIGHT NO. 3 TO LIGHT NO. 9		
23+48, 35' RT	72'	24+22, 26' RT	LIGHT NO. 9 TO LIGHT NO. 10		
24+22, 26' LT	26'	24+48, 27' LT	LIGHT NO. 10 TO EXISTING CONDUIT AT ORANGE ST		
9+30, 46' RT	87'	9+92, 32' RT	LIGHT NO. 5 TO LIGHT NO. 7		
9+92, 32' RT	96'	10+92, 21' RT	LIGHT NO. 7 TO 13"X24" JUNCTION BOX		
10+92, 21' RT	27'	11+28, 23' RT	13"X24" JUNCTION BOX TO EXISTING CONDUIT ON MULBERRY ST		
10+92, 21' RT	55'	11+08, 33' LT	13"X24" JUNCTION BOX TO 13"X24" JUNCTION BOX		
11+08, 33' LT	62'	10+56, 28' LT	13"X24" JUNCTION BOX TO LIGHT NO. 8		
10+56, 28' LT	104'	9+50, 43' LT	LIGHT NO. 8 TO LIGHT NO. 6		
11+08, 33' LT	242'	8+79	13"X24" JUNCTION BOX TO 10" JUNCTION BOX		
22+15, 55' LT	119'	21+02, 21' LT	LIGHT NO. 6 TO EXISTING CONDUIT ON 2ND ST		
20+83, 21' RT	115'	21+95, 45' RT	EXISTING CONDUIT ON 2ND ST TO LIGHT NO. 4		
8+18, 49' LT	90'	7+28, 23' LT	LIGHT NO. 4 TO LIGHT NO. 2		

	ELECTRICAL 6-INCH CONDUIT											
LOCATION LENGTH LOCATION COMMENTS												
6+98, 2' LT	321'	24+48, 21' RT	MANHOLE AT 31 ALLEY TO EXISTING CONDUIT AT ORANGE ST									

w	WATER MAIN, DR11 HDPE												
LOCATION	SIZE	LENGTH	LOCATION										
STA. 100+00	10"	26'	100+26										
STA. 100+26	12"	287'	103+13										
STA. 110+00	6"	238'	112+38										
STA. 120+00	12"	190'	121+90										

	W	ATER FITTIN	NGS	
LOCATION	SIZE	TYPE	MATERIAL	COMMENTS
STA. 100+04	10"	90	HDPE	
STA. 100+22	10"X6"	REDUCER	HDPE	
STA. 100+26	12"X6"	TEE	HDPE	
STA. 100+45	12"	22-1/2	HDPE	VERTICAL BEND
STA. 100+51	12"	22-1/2	HDPE	VERTICAL BEND
STA. 100+62	12"X12"	TEE	HDPE	
STA. 102+15	12"X6"	TEE	HDPE	HYDRANT TEE
STA. 103+04	12"	90	HDPE	
STA. 121+82	12"	90	HDPE	
STA. 100+00, 5' RT	10"	CAP	DI	
STA. 103+13, 5' RT	12"	CAP	DI	
STA. 121+90, 5' LT	12"	CAP	DI	


TAPPING	SLEEVES
LOCATION	SIZE
STA. 100+00	10"X10"
STA. 103+13	12"X12"
STA. 121+90	12"X12"


WATER FIRE HYDRANTS	
LOCATION	
STA. 102+15, 20' LT	






REV	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
			JGS	2ND & MULBERRY ROUNDABOUT
			CHECKED	TABULATIONS







LOG OF BORING

Geote	ippi D	Evalu	atio		BORING: RB-20 LOCATION: Latitude: 41.423895 Longitude: -91.041223						
DRILLE	R: R.	Hunt/C.	Grace	METHOD: Power Auger	DATE:	10/2	7/16		SCALE: 1" = 4'		
Elev. feet	Depth feet	0		Description of Materials	140 4 0000)	BPF	WL	MC	Tests or Notes		
557.0	0.0	DAV	DOI	(Soil-ASTM D2488 or D2487, Rock-USACE EM1*) PCC Pavement	110-1-2908)			%			
556.2	0.8										
555.5	1.5	AGG	XXXX	Aggregate Base		10					
		FILL	₩	FILL: Silty Sand with Clay pockets, brown, de	у —	12					
554.0	3.0	En .		Ell I. Condy Cill trace Curved business to deal	hrou	H					
		FILL	\bowtie	FILL: Sandy Silt, trace Gravel, brown to dark dry	prown,	М 8		16	LL= N/A, PL= NP,		
-			₩	w. j	_	XI J			PI=NP		
552.0	5.0	FILL	\bowtie	FILL: Poorly Graded Sand with Silt, orange b	rown	H			P200= 50%		
_		''	\bowtie	moist	Ovvii,				Bulk sample from 3 to feet.		
			\bowtie						q _p = 2.0 tsf		
-			\bowtie		-				-r'		
549.0	8.0					П					
		FILL	\bowtie	FILL: Lean Clay with Sand, brown, moist		M 5					
-			₩		_						
547.0	10.0		XXX	END OF BODING		Ä					
				END OF BORING.							
				Water not observed while drilling.							
				Boring then backfilled.	_						
				boning their backlined.	_						
-					_						
_											
-					-						
_					_						
-					-						
-					_						
-					_						
-					-						
-					_						
_											
-					_						
_					_						
-					_						
-											
— I											

	BORI	NG									Pa	age 1 of 1
CL	IENT Stanley Consultants, Inc.		ENG	INE	ER		Stan	ley Co	nsulf	ante	inc	
SIT			PRC	JEC	T		<u> </u>	icy oc	, iouic	arres,	1110.	
	Muscatine, Iowa			F	rop				pi Dri	ve Re	constru	ction
	Boring Location: 528110.3N, 2314678.5E					SAI	MPLES	<u> </u>		I	TESTS	······································
GRAPHIC LOG	DESCRIPTION Approx. Surface Elev.: 556.9 ft		DEPTH, ft.	USCS SYMBOL	NUMBER	TYPE	RECOVERY, in.	SPT-N** BLOWS/ft.	WATER CONTENT. %	DRY UNIT WT pcf	UNCONFINED STRENGTH, psf	ATTERBERG LIMITS
XXX	Approx. 2" Asphaltic Cement Concrete					HS						
$\overset{**}{\otimes}$	Approx. 7" Portland Cement Concrete FILL. CLAYEY SAND Brown-Gray				1	ST	14		19	96	1620	
XX			=		2	HS SS	16	4	19			LL=22
$\widetilde{\mathfrak{M}}$	SILTY CLAY WITH SAND (ALLUVIUM)	51,9	5	CL	3	ST	22		24	97	1130	PI=6
	Brown Medium Stiff		Ξ	ML		HS						
				CL	4	ST	19		28	91	1140	
	10 54 BOTTOM OF BORING	16.9	10	ML								
	Sample 2 - 41% passing #200 sieve											
The : betw	stratification lines represent the approximate boundary lines een soil and rock types: in-situ, the transition may be gradual.							**	'CME 1	40 lb. S		enetrometer atic hammer
NΑ	TER LEVEL OBSERVATIONS, ft		****	-			BORIN	VG STA	RTE)		12-2-10
	Y None WD Y Y PERIOD		~	-		E		VG CO	MPLE	TED		12-2-10
٧L	Ā Ā BEL	6		Ļ		F	RIG		92		REMAN	
٧L						Α	PPR	OVED	VE	R JC	B# 0	7105080


Exhibit A-12


NOTE:
BORING LOGS SHOWN ON THIS PAGE ARE FOR REFERENCE AND WERE OBTAINED FROM
THE PROJECT MANUAL. THE FULL BORING REPORT CAN BE FOUND IN THE PROJECT
MANUAL AND SHOULD BE REFERENCED AS NEEDED FOR MORE DETAILED INFORMATION.





855 WRIGHT BROTHERS BLVD SW, SUITE ZA
CEDAR RAPIDS, IOWA 52404
Phone: (319) 362-3219
Email: CedarRapids@bolton-menk.com
www.holton-mank.com


REV	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
			JGS	2ND & MULBERRY ROUNDABOUT
			CHECKED	BORING LOGS
			ALH	2011110 2003


























	2ND STREET ALIGNMENT														
NUMBER	START STATION	END STATION	LENGTH	DELTA	RADIUS	CHORD	START N	START E	END N	END E	LINE / CHORD DIRECTION				
L1	20+00	22+57.96	257.96				528114.34	2314431.68	528273.38	2314634.78	N51° 56' 19"E				
L2	22+57.96	26+00	342.04				528273.38	2314634.78	528485.46	2314903.14	N51° 40' 52"E				

	MULBERRY AVENUE ALIGNMENT														
NUMBER	START STATION	END STATION	LENGTH	DELTA	RADIUS	CHORD	START N	START E	END N	END E	LINE / CHORD DIRECTION				
L3	5+00	6+12.69	112.69				527938.36	2314802.24	528026.46	2314731.98	N38° 34' 23"W				
C1	6+12.69	7+10.93	98.24	17°22'27"	323.97	97.86	528026.46	2314731.98	528115.17	2314690.65	N24° 58' 40"W				
C2	7+10.93	8+78.90	167.98	9°34'29"	1005.16	167.78	528115.17	2314690.65	528273.38	2314634.78	N19° 27' 01"W				
C3	8+78.90	9+45.49	66.59	26°28'54"	144.08	66.00	528273.38	2314634.78	528325.50	2314594.30	N37° 49' 59"W				
C4	9+45.49	10+09	63.51	15°49'21"	229.98	63.31	528325.50	2314594.30	528352.94	2314537.25	N64° 18' 53"W				
C5	10+09	10+49.33	40.33	4°06'33"	562.29	40.32	528352.94	2314537.25	528362.76	2314498.14	N75° 54' 23"W				
C6	10+49.33	11+28.70	79.37	40°28'16"	112.36	77.73	528362.76	2314498.14	528404.27	2314432.42	N57° 43' 31"W				
L4	11+28.70	13+50	221.30				528404.27	2314432.42	528578.59	2314296.09	N38° 01' 40"W				

SOUTHEAST GUTTERLINE ALIGNMENT											
NUMBER	START STATION	END STATION	LENGTH	DELTA	RADIUS	CHORD	START N	START E	END N	END E	LINE / CHORD DIRECTION
L7	30+00	30+27.69	27.69				528012.30	2314758.62	528033.94	2314741.36	N38° 34' 23"W
C7	30+27.69	31+10.43	82.74	33°44'35"	140.50	81.55	528033.94	2314741.36	528109.72	2314711.20	N21° 42' 05"W
C8	31+10.43	31+82.57	72.14	11°14'47"	367.51	72.02	528109.72	2314711.20	528180.54	2314698.13	N10° 27' 11"W
C9	31+82.57	32+34.96	52.39	25°41'19"	116.86	51.96	528180.54	2314698.13	528232.35	2314694.22	N4° 18' 58"W
C10	32+34.96	33+41.97	107.01	34°05'21"	179.86	105.44	528232.35	2314694.22	528327.40	2314739.88	N25° 39' 21"E
C11	33+41.97	33+63.07	21.10	11°04'05"	109.24	21.07	528327.40	2314739.88	528341.45	2314755.57	N48° 10' 00"E
L8	33+63.07	34+83.54	120.46				528341.45	2314755.57	528415.53	2314850.57	N52° 03' 02"E

NORTHEAST GUTTERLINE ALIGNMENT											
NUMBER	START STATION	END STATION	LENGTH	DELTA	RADIUS	CHORD	START N	START E	END N	END E	LINE / CHORD DIRECTION
L9	40+00	40+64.09	64.09				528450.49	2314822.99	528410.81	2314772.65	S51° 45' 07"W
C12	40+64.09	41+61.43	97.34	18°32'33"	300.77	96.91	528410.81	2314772.65	528350.97	2314696.42	S51° 51' 59"W
L10	41+61.43	41+67.51	6.08				528350.97	2314696.42	528348.03	2314691.10	S61° 08' 31"W
C13	41+67.51	42+28.22	60.71	57°29'38"	60.50	58.19	528348.03	2314691.10	528347.92	2314632.90	S89° 53' 20"W
L11	42+28.22	42+34.50	6.28				528347.92	2314632.90	528350.93	2314627.39	N61° 21' 52"W
C14	42+34.50	43+09.78	75.28	21°37'14"	199.50	74.84	528350.93	2314627.39	528373.84	2314556.15	N72° 10' 29"W
L12	43+09.78	43+51.45	41.67				528373.84	2314556.15	528378.93	2314514.79	N82° 59' 06"W
C15	43+51.45	44+29.99	78.55	44°46'45"	100.50	76.56	528378.93	2314514.79	528416.52	2314448.09	N60° 35' 43"W





C16

C17

C18

C19

L14

C20

C22

51+18.17

51+56.34

52+27.84

53+09.60

60+00

C21 61+01.94

C23 62+54.70

L15 63+22.75

60+57.90

61+69.36

62+54.70

63+22.75

63+88.68

85.34

30°19'00"

68.04 27°56'47" 139.50 67.37

161.28

84.35

528186.25 2314634.35

528110.14 2314670.70

528048.88 2314698.75 527997.49 2314740.05


528110.14 2314670.70

528048.88 2314698.75

S25° 31' 57"E

S24° 35' 59"E


S38° 47' 25"E








855 WRIGHT BROTHERS BLVD SW, SUITE 2A	ı
CEDAR RAPIDS, IOWA 52404	F
Phone: (319) 362-3219	H
Email: CedarRapids@bolton-menk.com	ŀ
www.bolton-menk.com	ı


v	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
			JGS	2ND & MULBERRY ROUNDABOUT
_			CHECKED	RIGHT OF WAY
			ALH	Mon or war


























855 WRIGHT BROTHERS BLVD SW, SUITE 2A
CEDAR RAPIDS, IOWA 52404
Phone: (319) 362-3219
Email: CedarRapids@bolton-menk.com
www.bolton-menk.com

ISSUED FOR	DATE	DESIGNED BWR	CITY OF MUSCATINE, IOWA
FOR BIDS	11/21/18	DRAWN NV	2ND & MULBERRY ROUNDABOUT
		CHECKED BWR	WATER UTILITIES
















855 WRIGHT BROTHERS BLVD SW, SUITE 2A	
CEDAR RAPIDS, IOWA 52404	
Phone: (319) 362-3219	
Email: CedarRapids@bolton-menk.com	
www.bolton-menk.com	

v	ISSUED FOR	DATE	BWR	CITY OF MUSCATINE, IOWA	SHEET
)	FOR BIDS	11/21/18	DRAWN NV	2ND & MULBERRY ROUNDABOUT	M 02
			CHECKED	WATER UTILITIES	101.02
			BWR	WATER UTILITIES	

WATER MAIN PHASING PLAN

- THE FOLLOWING IS A SUGGESTED PHASING PLAN. CONTRACTOR IS REQUIRED TO DEVELOP A
 CONSTRUCTION SEQUENCE THAT MAINTAINS CUSTOMER SERVICE THROUGHOUT PROJECT WITHIN ALLOWABLE SERVICE DISRUPTIONS. CONTRACTOR SHALL COORDINATE PROPOSED PHASING PLAN WITH OWNER.
- CONSTRUCT WATER MAINS WITHIN PHASE 1 AND 1A OF ROUNDABOUT CONSTRUCTION.
- DISINFECT, FLUSH, AND TEST WATER MAIN. THE INTENT IS TO PRESSURE TEST ALL NEW WATER MAINS AS ONE UNIT. BACTERIA TESTING BY MPW.
- REMOVE HYDRANTS INDICATED ON PLANS
 CUT AND CAP WATER MAIN AT LOCATIONS INDICATED.



TAPPING SLEEVE TYPICAL DETAIL

SCALE: NONE











855 WRIGHT BROTHERS BLVD SW, SUITE 2A
CEDAR RAPIDS, IOWA 52404
Phone: (319) 362-3219
Email: CedarRapids@bolton-menk.com
www.bolton-menk.com

TE 2A	REV	ISSUED FOR	DATE	BWR	CITY OF MUSCATINE, IOWA	SHEET
	0	FOR BIDS	11/21/18	DRAWN NV	2ND & MULBERRY ROUNDABOUT	M 03
om				CHECKED BWR	WATER DETAILS	101.05







M.11










855 WRIGHT BROTHERS BLVD SW, SUITE 2A
CEDAR RAPIDS, IOWA 52404
Phone: (319) 362-3219
Email: CedarRapids@bolton-menk.com
www.bolton-menk.com

REV	ISSUED FOR	DATE	DESIGNED BWR	CITY OF MUSCATINE, IOWA	
0	FOR BIDS	11/21/18	DRAWN NV	2ND & MULBERRY ROUNDABOUT	
			CHECKED BWR	ELECTRICAL AND COMMUNICATIONS UTILITIES	

















Phone: (319) 362-3219
Email: CedarRapids@bolton-menk.com
www.bolton-menk.com

REV	ISSUED FOR	DATE	DESIGNED BWR	CITY OF MUSCATINE, IOWA
0	FOR BIDS	11/21/18	DRAWN NV	2ND & MULBERRY ROUNDABOUT
			CHECKED	FLECTRICAL AND COMMUNICATIONS UTILITIES
			BWR	ELECTRICAL AND COMMONICATIONS OTHER









- JUNCTION BOXES SHALL BE LOCATED AS INDICATED ON THE PLANS FOR FEED LIGHTING AND SINGLE PHASE JUNCTIONS
- 2. ALL RECTANGULAR JUNCTION BOXES AND HAND HOLES SHALL BE A QUAZITE POLYMER
- 3. ALL ROUND HAND HOLES SHALL BE PENCELL HIGH DENSITY POLYETHYLENE BOXES.

3x2 DUCT SECTION (TYP.)

JUNCTION BOX / HANDHOLE DETAIL (TYP.)

CONDUIT DELIVERY STORAGE, AND HANDLING SHALL COMPLY WITH SUDAS DIVISION 1 - GENERAL PROVISIONS AND COVENANTS.

CONDUIT MATERIAL SPECIFICATIONS:

GENERAL CONSTRUCTION NOTES

- 1. FURNISH WATER PROOF FITTINGS OF IDENTICAL OR COMPATIBLE MATERIAL TO THE CONDUIT. USE STANDARD FACTORY ELBOWS, COUPLINGS, AND OTHER FITTINGS
- 2 USE A MANUFACTURED CONDUIT SEALING COMPOUND THAT IS READILY WORKABLE MATERIAL AT TEMPERATURES AS LOW AS 30°F AND WILL NOT MELT OR RUN AT TEMPERATURES AS HIGH AS 300°F.
- 3. PLASTIC CONDUIT AND FITTINGS
- 3.1. PVC
 - 3.1.1. PVC SCHEDULE 40 PLASTIC CONDUIT AND FITTINGS COMPLYING WITH NEMA TC-2 (PIPE), NEMA TC-3 (FITTINGS), AND UL 651 FOR SCHEDULE 40 HEAVY WALL TYPE.
 - 3.1.2. SOLVENT WELDED, SOCKET TYPE FITTINGS, EXCEPT WHERE OTHERWISE SPECIFIED IN THE CONTRACT DOCUMENTS.
 - 3.1.3 PVC TO BE USED WHEN OPEN TRENCH CONSTRUCTION TECHNIQUE IS UTILIZED BY CONTRACTOR FOR ELECTRIC CONDUIT.
- 3.2.1. COMPLY WITH ASTM F 2160 (CONDUIT) AND STM D 3350 (HDPE MATERIAL)
- 3.2.2. USE SDR 13.5 BLACK COLORED CONDUIT WITH RED STRIPE FOR ALL TWO INCH ELECTRICAL CONDUIT.
- 3.2.3. USE SDR 17 BLACK COLORED CONDUIT WITH RED STRIPE FOR ALL FOUR INCH AND LARGER ELECTRICAL CONDUIT.
- 3.2.4. USE SCHEDULE 40 ORANGE COLORED CONDUIT FOR SINGLE CONDUIT COMMUNICATION INSTALLATIONS
- 3.2.5. USE
 - QUAD 4X1.50", SDR-15.5 COLORS: WHITE, PURPLE, BLACK, ORANGE, WITH PULL ROPE AND LUBE, ALL COLORS ON SAME REEL TO ALLOW DISPENSING AT SAME TIME
- 3.2.6. CONTINUOUS REEL OR STRAIGHT PIECES TO MINIMIZE SPLICING OF HDPE. NON-FUSED SPLICING OF HDPE IS DISCOURAGED.
- 3.2.7. HDPE TO BE USED IN OPEN TRENCH CONSTRUCTION FOR COMMUNICATION.
- 3.2.8. HDPE TO BE USED IN TRENCHLESS INSTALLATION METHOD FOR ELECTRIC OR COMMUNICATION CONDUIT

CONDUIT INSTALLATION SPECIFICATIONS:

- 1. PLACE CONDUIT TO A MINIMUM DEPTH OF 30 INCHES AND A MAXIMUM DEPTH OF 60 INCHES BELOW THE GUTTERLINE. WHEN CONDUIT IS PLACED BEHIND THE CURB, PLACE TO A MINIMUM DEPTH OF 24 INCHES AND A MAXIMUM DEPTH OF 48 INCHES BELOW TOP OF CURB. ALL TRENCHED ELECTRIC CONDUIT TO HAVE WARNING TAPE INSTALLED AT A DEPTH OF 12 INCHES BELOW GROUND LEVEL AND SHALL HAVE A MINIMUM 12 INCHES OF CLEARANCE TO INSTALLED CONDUIT.
- 2. MINIMUM TRENCH WIDTH SHALL BE 2 INCHES GREATER THAN THE NOMINAL DIAMETER OF EACH CONDUIT ADDED TOGETHER.
- 3. ALL CONDUIT SHALL BE OF ONE CONTINUOUS MATERIAL TYPE BETWEEN EXPOSED ENDS. DO NOT INTERCHANGE PVC AND HDPE.
- ALL CONDUIT SHALL BE INSTALLED ON THE BOTTOM OF THE TRENCH. ELECTRICAL AND COMMUNICATION SHALL BE PLACED ON OPPOSITE ENDS OF TRENCH. BENCHING OF CONDUIT WOULD ALSO BE ALLOWED WITH OWNER APPROVAL.
- 5 CHANGE DIRECTION AT HANDHOLES OR BY BENDING, SUCH THAT THE CONDUIT WILL NOT BE DAMAGED, OR ITS INTERNAL DIAMETER CHANGED. ENSURE BENDS ARE UNIFORM IN CURVATURE AND THE INSIDE RADIUS OF CURVATURE OF ANY BEND IS NO LESS THAN SIX TIMES THE INTERNAL DIAMETER OF THE CONDUIT.
- 6. WHEN PLACING CONDUIT UNDER PAVEMENTS. USE THE TRENCHLESS INSTALLATION METHODS DESCRIBED IN IOWA SUDAS SECTION 3020.
- ON THE EXPOSED ENDS OF CONDUIT, PLACE BELL-END FITTINGS ON PVC OR HDPE CONDUIT AND BUSHINGS ON STEEL CONDUIT. EXTEND ALL CONDUITS A MINIMUM OF 2-INCHES AND A MAXIMUM OF 6-INCHES ABOVE THE FINISHED SURFACE OF ANY FOUNDATION, FOOTING, OR STRUCTURAL BASE
- 8. PERFORM AN OWNER WITNESSED PROOF TEST OF CONDUIT INSTALLATION BY PULLING A MANDREL OF APPROPRIATE SIZE THROUGH INSTALLED CONDUITS. INSTALL PULLING TAPE AFTER ACCEPTANCE OF PROOF TEST.
- 9. SEAL CONDUIT ENDS TO MINIMIZE INGRESS OF WATER OR ANY ITEM THAT MAY HINDER THE INSTALLATION OF WIRE.
- 10. SUITABLE BACKFILL SHALL BE MANUFACTURED SAND WHEN TRENCH IS WITHIN 10'-0" OF ROADWAY OR UNDER PAVEMENT.

SHEET

M.13

	6"	1'-0" FINISH GRADE (TYP.)	2'-0"
3'-6" (TYP.)		COMPACTED SUITA BACKFILL (TYP.)	ABLE
	V UNDISTURBED I	EARTH (TYP.)	

ELECTRICAL / COMMUNICATION TRENCH DETAIL (TYP.) SCALE: 1/2" = 1'-0'












REV	ISSUED FOR	DATE	DESIGNED BWR	CITY OF MUSCATINE, IOWA
0	FOR BIDS	11/21/18	DRAWN NV	2ND & MULBERRY ROUNDABOUT
			CHECKED BWR	CONDUIT, TRENCH AND BOX DET



STREET LIGHT CONCRETE FOUNDATION

PROVIDE MINIMUM 2" CLEAR FOR ALL REINFORCEMENT.

CAP OPEN ENDS OF CONDUIT DURING CONSTRUCTION TO PREVENT INFILTRATION OF FOREIGN MATERIAL. AFTER THE CABLE IS INSTALLED SEAL THE UPPER END OF THE DUCTS AGAINST ENTRY OF MOISTURE BY A METHOD APPROVED BY THE ENGINEER.

TYPE A FOUNDATION

FOR ACCESS DUCTS, USE A 2" NOMINAL INSIDE DIAMETER DUCT.

WHEN PRECAST FOUNDATIONS ARE USED, BACKFILL WITH CLASS B CONCRETE. WHEN CAVING SOIL OR GROUND WATER IS PRESENT, REMOVE TO PROVIDE AN ACCEPTABLE CONDITION PRIOR TO PLACING CLASS B CONCRETE.

- ① #4 BARS LAPPED A MINIMUM OF 12" AS INDICATED. HOOPS MAY BE WELDED TO VERTICAL BARS.
- ② USE FULL LENGTH GALVANIZED ANCHOR BOLTS. REFER TO THE MANUFACTURER'S REQUIREMENTS FOR ANCHOR BOLT DIMENSIONS. OBTAIN A TEMPLATE FROM THE LIGHT POLE MANUFACTURER FOR ANCHOR BOLT PLACEMENT, DO NOT WELD ANCHOR BOLTS. MPW WILL PROVIDE ANCHOR BOLTS FOR INSTALLATION BY
- 3 PLACE 8 BARS SPACED EQUALLY.














855 WRIGHT BROTHERS BLVD SW, SUIT CEDAR RAPIDS, IOWA 52404 Phone: (319) 362-3219 Email: CedarRapids@bolton-menk.co www.bolton-menk.com

ITE 2A	REV	ISSUED FOR	DATE	BWR	CITY OF MUSCATINE, IOWA
	0	FOR BIDS	11/21/18	DRAWN NV	2ND & MULBERRY ROUNDABOUT
com				CHECKED BWR	STREET LIGHT FOUNDATION DETAIL

M.14














855 WRIGHT BROTHERS BLVD SW, SUITE 2A	K
CEDAR RAPIDS, IOWA 52404	г
Phone: (319) 362-3219	⊢
Email: CedarRapids@bolton-menk.com	⊢
www.bolton-menk.com	ᆫ

SUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA	SHEET	
		JGS	2ND & MULBERRY ROUNDABOUT	MSS.03	
		CHECKED	STORM & SANITARY PLAN & PROFILE	10133.03	



SF SF SF SF SF SF SF SF	STATION	OFFSET	SIGN TYPE	ANCHOR	POST QTY	SIGN DIMENSION	SIGN AREA	QTY	TOTAL AREA	REMARKS
7+13.22 -00.01 R4-7 CONCRETE 1.0 24 X 30 5.00 1.00 5.00 7+13.22 -00.01 OM1-2 18 X 18 2.25 1.00 2.25 7+39.93 25.02 W3-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 7+73.34 27.53 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 7+73.34 27.53 W16-PPL 24 X 12 2.00 1.00 2.00 7+73.97 01.35 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 7+74.82 -32.30 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 7+74.82 -32.30 W16-PPL 24 X 12 2.00 1.00 2.00 8+11.12 07.75 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 8+62.90 14.35 R6-4A SOIL 2.0 48 X						IN	SF		SF	
7+13.22 -00.01 OM1-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 7+39.93 25.02 W3-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 7+73.34 27.53 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 7+73.39 7.33 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 7+74.82 -32.30 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 7+74.82 -32.30 W16-7PL 24 X 12 2.00 1.00 2.00 8+11.12 07.75 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 8+62.90 14.35 R6-4A SOIL 2.0 48 X 24 8.00 1.00 9.00 8+95.02 -15.46 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 9+50.53 -08.15	6+67.30	14.34	W2-6A	SOIL	1.0	36 X 36	9.00	1.00	9.00	
7+39.93 25.02 W3-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 7+73.34 27.53 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 7+73.34 27.53 W16-7PL 24 X 12 2.00 1.00 2.00 7+79.97 01.35 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 7+74.82 -32.30 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 7+74.82 -32.30 W16-7PL 24 X 12 2.00 1.00 2.00 8+11.12 07.75 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 8+62.90 14.35 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 8+95.02 -15.46 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 9+50.53 -08.15 R6-2R 24 X 30<	7+13.22	-00.01	R4-7	CONCRETE	1.0	24 X 30	5.00	1.00	5.00	
7+73.34 27.53 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 7+73.34 27.53 W16-7PL 24 X 12 2.00 1.00 2.00 7+73.97 01.35 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 7+74.82 -32.30 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 7+74.82 -32.30 W16-7PL 24 X 12 2.00 1.00 2.00 8+11.12 07.75 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 8+62.90 14.35 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 8+95.02 -15.46 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 9+50.53 -08.15 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 9+65.02 35.70 W11-2 SOIL	7+13.22	-00.01	OM1-2			18 X 18	2.25	1.00	2.25	
7+73.34 27.53 W16-PPL 24 X 12 2.00 1.00 2.00 7+73.97 01.35 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 7+74.82 -32.30 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 7+74.82 -32.30 W16-7PL 24 X 12 2.00 1.00 2.00 8+11.12 07.75 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 8+62.90 14.35 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 8+95.02 -15.46 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 9+50.53 -08.15 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 8.00 9+65.02 35.70 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+65.02 35.70 W16-7PL 24	7+39.93	25.02	W3-2	SOIL	1.0	36 X 36	9.00	1.00	9.00	
7+73.97 01.35 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 7+74.82 -32.30 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 7+74.82 -32.30 W16-7PL 24 X 12 2.00 1.00 2.00 8+11.12 07.75 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 8+62.90 14.35 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 8+95.02 -15.46 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 9+50.53 -08.15 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 9+50.53 -08.15 R6-2R 24 X 30 5.00 1.00 9.00 9+50.53 -08.15 R6-2R 24 X 30 5.00 1.00 5.00 9+65.02 35.70 W11-2 SOIL 1.0 30 X	7+73.34	27.53	W11-2	SOIL	1.0	30 X 30	6.25	1.00	6.25	
7+74.82 -32.30 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 7+74.82 -32.30 W16-7PL 24 X 12 2.00 1.00 2.00 8+11.12 07.75 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 8+62.90 14.35 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 8+95.02 -15.46 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 9+50.53 -08.15 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 8.00 9+50.53 -08.15 R6-2R 24 X 30 5.00 1.00 9.00 9+50.53 -08.15 R6-2R 24 X 30 5.00 1.00 5.00 9+65.02 35.70 W16-7PL 24 X 12 2.00 1.00 6.25 9+65.02 35.70 W16-7PL 24 X 12 2.00 1.00 9.00	7+73.34	27.53	W16-7PL			24 X 12	2.00	1.00	2.00	
7+74.82 -32.30 W16-7PL 24 X 12 2.00 1.00 2.00 8+11.12 07.75 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 8+11.12 07.75 R6-2R 24 X 30 5.00 1.00 5.00 8+62.90 14.35 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 8+95.02 -15.46 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 9+50.53 -08.15 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 9+50.53 -08.15 R6-2R 24 X 30 5.00 1.00 9.00 9+65.02 35.70 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+65.02 35.70 W16-7PL 24 X 12 2.00 1.00 2.00 9+70.03 -40.91 R1-2 SOIL 1.0 36 X 36 9.00 1.00	7+73.97	01.35	R1-6B	CONCRETE	1.0	12 X 36	3.00	2.00	6.00	
8+11.12 07.75 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 8+11.12 07.75 R6-2R 24 X 30 5.00 1.00 5.00 8+62.90 14.35 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 8+95.02 -15.46 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 9+50.53 -08.15 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 9+50.53 -08.15 R6-2R 24 X 30 5.00 1.00 5.00 9+65.02 35.70 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+65.02 35.70 W16-7PL 24 X 12 2.00 1.00 2.00 9+70.03 -40.91 R1-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 9+86.76 -26.40 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+86.76 -26.40 W16-7PL	7+74.82	-32.30	W11-2	SOIL	1.0	30 X 30	6.25	1.00	6.25	
8+11.12 07.75 R6-2R 24 X 30 5.00 1.00 5.00 8+62.90 14.35 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 8+95.02 -15.46 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 9+50.53 -08.15 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 9+50.53 -08.15 R6-2R 24 X 30 5.00 1.00 5.00 9+65.02 35.70 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+65.02 35.70 W16-7PL 24 X 12 2.00 1.00 2.00 9+70.03 -40.91 R1-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 9+71.55 03.81 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 9+86.76 -26.40 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+86.76 -26.40 W16-7PL	7+74.82	-32.30	W16-7PL			24 X 12	2.00	1.00	2.00	
8+62.90 14.35 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 8+95.02 -15.46 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 9+50.53 -08.15 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 9+50.53 -08.15 R6-2R 24 X 30 5.00 1.00 5.00 9+65.02 35.70 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+65.02 35.70 W16-7PL 24 X 12 2.00 1.00 2.00 9+70.03 -40.91 R1-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 9+71.55 03.81 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 9+86.76 -26.40 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+86.76 -26.40 W16-7PL 24 X 12 2.00 1.00 2.00 10+47.23 -23.47 W3-2	8+11.12	07.75	R1-2	CONCRETE	1.0	36 X 36	9.00	1.00	9.00	
8+95.02 -15.46 R6-4A SOIL 2.0 48 X 24 8.00 1.00 8.00 9+50.53 -08.15 R1-2 CONCRETE 1.0 36 X 36 9.00 1.00 9.00 9+50.53 -08.15 R6-2R 24 X 30 5.00 1.00 5.00 9+65.02 35.70 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+65.02 35.70 W16-7PL 24 X 12 2.00 1.00 2.00 9+70.03 -40.91 R1-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 9+71.55 03.81 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 9+86.76 -26.40 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+86.76 -26.40 W16-7PL 24 X 12 2.00 1.00 2.00 10+47.23 -23.47 W3-2 SOIL 1.0 36 X	8+11.12	07.75	R6-2R			24 X 30	5.00	1.00	5.00	
9+50.53	8+62.90	14.35	R6-4A	SOIL	2.0	48 X 24	8.00	1.00	8.00	
9+50.53 -08.15 R6-2R 24 X 30 5.00 1.00 5.00 9+65.02 35.70 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+65.02 35.70 W16-7PL 24 X 12 2.00 1.00 2.00 9+70.03 -40.91 R1-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 9+71.55 03.81 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 9+86.76 -26.40 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+86.76 -26.40 W16-7PL 24 X 12 2.00 1.00 2.00 10+47.23 -23.47 W3-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 10+47.91 -00.10 R4-7 CONCRETE 1.0 24 X 30 5.00 1.00 5.00 10+47.91 -00.10 OM1-2 18 X 18 2.25 <td< td=""><td>8+95.02</td><td>-15.46</td><td>R6-4A</td><td>SOIL</td><td>2.0</td><td>48 X 24</td><td>8.00</td><td>1.00</td><td>8.00</td><td></td></td<>	8+95.02	-15.46	R6-4A	SOIL	2.0	48 X 24	8.00	1.00	8.00	
9+65.02 35.70 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+65.02 35.70 W16-7PL 24 X 12 2.00 1.00 2.00 9+70.03 -40.91 R1-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 9+71.55 03.81 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 9+86.76 -26.40 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+86.76 -26.40 W16-7PL 24 X 12 2.00 1.00 2.00 10+47.23 -23.47 W3-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 10+47.91 -00.10 R4-7 CONCRETE 1.0 24 X 30 5.00 1.00 5.00 10+47.91 -00.10 OM1-2 18 X 18 2.25 1.00 2.25	9+50.53	-08.15	R1-2	CONCRETE	1.0	36 X 36	9.00	1.00	9.00	
9+65.02 35.70 W16-7PL 24 X 12 2.00 1.00 2.00 9+70.03 -40.91 R1-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 9+71.55 03.81 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 9+86.76 -26.40 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+86.76 -26.40 W16-7PL 24 X 12 2.00 1.00 2.00 10+47.23 -23.47 W3-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 10+47.91 -00.10 R4-7 CONCRETE 1.0 24 X 30 5.00 1.00 5.00 10+47.91 -00.10 OM1-2 18 X 18 2.25 1.00 2.25	9+50.53	-08.15	R6-2R			24 X 30	5.00	1.00	5.00	
9+70.03 -40.91 R1-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 9+71.55 03.81 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 9+86.76 -26.40 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+86.76 -26.40 W16-7PL 24 X 12 2.00 1.00 2.00 10+47.23 -23.47 W3-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 10+47.91 -00.10 R4-7 CONCRETE 1.0 24 X 30 5.00 1.00 5.00 10+47.91 -00.10 OM1-2 18 X 18 2.25 1.00 2.25	9+65.02	35.70	W11-2	SOIL	1.0	30 X 30	6.25	1.00	6.25	
9+71.55 03.81 R1-6B CONCRETE 1.0 12 X 36 3.00 2.00 6.00 9+86.76 -26.40 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+86.76 -26.40 W16-7PL 24 X 12 2.00 1.00 2.00 10+47.23 -23.47 W3-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 10+47.91 -00.10 R4-7 CONCRETE 1.0 24 X 30 5.00 1.00 5.00 10+47.91 -00.10 OM1-2 18 X 18 2.25 1.00 2.25	9+65.02	35.70	W16-7PL			24 X 12	2.00	1.00	2.00	
9+86.76 -26.40 W11-2 SOIL 1.0 30 X 30 6.25 1.00 6.25 9+86.76 -26.40 W16-7PL 24 X 12 2.00 1.00 2.00 10+47.23 -23.47 W3-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 10+47.91 -00.10 R4-7 CONCRETE 1.0 24 X 30 5.00 1.00 5.00 10+47.91 -00.10 OM1-2 18 X 18 2.25 1.00 2.25	9+70.03	-40.91	R1-2	SOIL	1.0	36 X 36	9.00	1.00	9.00	
9+86.76 -26.40 W16-7PL 24 X 12 2.00 1.00 2.00 10+47.23 -23.47 W3-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 10+47.91 -00.10 R4-7 CONCRETE 1.0 24 X 30 5.00 1.00 5.00 10+47.91 -00.10 OM1-2 18 X 18 2.25 1.00 2.25	9+71.55	03.81	R1-6B	CONCRETE	1.0	12 X 36	3.00	2.00	6.00	
10+47.23 -23.47 W3-2 SOIL 1.0 36 X 36 9.00 1.00 9.00 10+47.91 -00.10 R4-7 CONCRETE 1.0 24 X 30 5.00 1.00 5.00 10+47.91 -00.10 OM1-2 18 X 18 2.25 1.00 2.25	9+86.76	-26.40	W11-2	SOIL	1.0	30 X 30	6.25	1.00	6.25	
10+47.91 -00.10 R4-7 CONCRETE 1.0 24 X 30 5.00 1.00 5.00 10+47.91 -00.10 OM1-2 18 X 18 2.25 1.00 2.25	9+86.76	-26.40	W16-7PL			24 X 12	2.00	1.00	2.00	
10+47.91 -00.10 OM1-2 18 X 18 2.25 1.00 2.25	10+47.23	-23.47	W3-2	SOIL	1.0	36 X 36	9.00	1.00	9.00	
	10+47.91	-00.10	R4-7	CONCRETE	1.0	24 X 30	5.00	1.00	5.00	
11+14.05 -20.51 W2-6A CONCRETE 1.0 36 X 36 9.00 1.00 9.00	10+47.91	-00.10	OM1-2			18 X 18	2.25	1.00	2.25	
·	11+14.05	-20.51	W2-6A	CONCRETE	1.0	36 X 36	9.00	1.00	9.00	


ROAD	STA	STATION 1 OFF	TO STATION STA	OFF	LENGTH (STA)	DIR. OF TRAVEL	MARKING TYPE	LINE TYPE	L	SIDE	R	FACTORED LENGTH (STA)	REMARKS
MULBERRY AVE	7+09.50		8+15.75		2.64	BOTH	Waterborne/Solvent Paint	ELY4	х			2.64	Edge Line Around Island
MULBERRY AVE	8+15.80	13.23	8+08.23	33.28	0.22	EB	Waterborne/Solvent Paint	YLW2	х	х	х	0.38	
MULBERRY AVE	8+15.80	13.23	8+37.60	51.69	0.45	EB	Waterborne/Solvent Paint	DLW4	х	х	х	0.15	
MULBERRY AVE	9+28.88	-55.44	9+47.59	-12.67	0.47	WB	Waterborne/Solvent Paint	DLW4	х	х	х	0.16	
MULBERRY AVE	9+47.59	-12.67	9+63.44	-33.98	0.27	WB	Waterborne/Solvent Paint	YLW2	х	х	х	0.47	
MULBERRY AVE	9+47.59		10+50.42		1.03	вотн	Waterborne/Solvent Paint	ELY4	х			1.03	Edge Line Around Island
MULBERRY AVE	5+85.50	0	6+70.00	0	0.85	вотн	Waterborne/Solvent Paint	DCY4		х		1.7	
MULBERRY AVE	6+70.00	0	7+10.00	0	1.03	вотн	Waterborne/Solvent Paint	CHY8		х		2.06	
MULBERRY AVE	10+50.25	0	11+05.35	0	1.32	вотн	Waterborne/Solvent Paint	CHY8		х		2.64	
MULBERRY AVE	11+05.35	0	12+18.00	0	1.13	вотн	Waterborne/Solvent Paint	DCY4		х		2.26	







v	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
			JGS	2ND & MULBERRY ROUNDABOUT
			CHECKED	PAVEMENT MARKINGS & SIGNS
			ALH	17/VEIVIEIVI 101/11/11/105 & 510145



	SIGN INFORMATION - 2ND STREET												
STATION	OFFSET	SIGN TYPE	ANCHOR	POST QTY	SIGN DIMENSION IN	SIGN AREA SF	QTY	TOTAL AREA SF	REMARKS				
20+64.14	20.68	W2-6A	CONCRETE	1.0	36 X 36	9.00	1.00	9.00					
20+90.74	-00.10	R4-7	CONCRETE	1.0	24 X 30	5.00	1.00	5.00					
20+90.74	-00.10	OM1-2			18 X 18	2.25	1.00	2.25					
21+27.44	20.05	W3-2	CONCRETE	1.0	36 X 36	9.00	1.00	9.00					
21+58.30	23.18	W11-2	SOIL	1.0	30 X 30	6.25	1.00	6.25					
21+58.30	23.18	W16-7PL			24 X 12	2.00	1.00	2.00					
21+63.37	-02.22	R1-6B	CONCRETE	1.0	12 X 36	3.00	2.00	6.00					
21+77.93	32.57	R1-2	SOIL	1.0	36 X 36	9.00	1.00	9.00					
21+80.95	-39.82	W11-2	SOIL	1.0	30 X 30	6.25	1.00	6.25					
21+80.95	-39.82	W16-7PL			24 X 12	2.00	1.00	2.00					
21+89.76	05.60	R1-2	CONCRETE	1.0	36 X 36	9.00	1.00	9.00					
21+89.76	05.60	R6-2R			24 X 30	5.00	1.00	5.00					
22+40.99	13.70	R6-4A	SOIL	2.0	48 X 24	8.00	1.00	8.00					
22+75.23	-12.73	R6-4A	SOIL	2.0	48 X 24	8.00	1.00	8.00					
23+26.05	-08.19	R1-2	SOIL	1.0	36 X 36	9.00	1.00	9.00					
23+26.05	-08.19	R6-2R			24 X 30	5.00	1.00	5.00					
23+31.46	-31.17	R1-2	SOIL	1.0	36 X 36	9.00	1.00	9.00					
23+50.03	30.29	W11-2	SOIL	1.0	30 X 30	6.25	1.00	6.25					
23+50.03	30.29	W16-7PL			24 X 12	2.00	1.00	2.00					
23+55.10	01.09	R1-6B	CONCRETE	1.0	12 X 36	3.00	2.00	6.00					
23+57.25	-23.47	W11-2	SOIL	1.0	30 X 30	6.25	1.00	6.25					
23+57.25	-23.47	W16-7PL			24 X 12	2.00	1.00	2.00					
23+92.32	00.01	R4-7	CONCRETE	1.0	24 X 30	5.00	1.00	5.00					
23+92.32	00.01	OM1-2			18 X 18	2.25	1.00	2.25					
TOTAL:				18.0			26.00	139.50					


ROAD	STATION TO STATION				DIR. OF	MARKING TYPE	LINE		SIDE		FACTORED LENGTH		
	STA	OFF	STA	OFF	(STA)	TRAVEL		TYPE	L	С	R	(STA)	REMARKS
2ND STREET	20+88.00		21+93.81		2.46	вотн	Waterborne/Solvent Paint	ELY4	х			2.46	Edge Line Around Island
2ND STREET	21+81.40	28.24	21+93.81	10.67	0.22	EB	Waterborne/Solvent Paint	YLW2	х	х	х	0.38	
2ND STREET	21+93.81	10.67	22+01.80	55.48	0.46	EB	Waterborne/Solvent Paint	DLW4	x	х	х	0.16	
2ND STREET	CENTER CIRCLE			2.60	вотн	Waterborne/Solvent Paint	ELW4	x			2.6	Edge Line Around Center Circle	
2ND STREET	23+08.64	-48.77	23+21.57	-13.47	0.38	WB	Waterborne/Solvent Paint	DLW4	x	х	х	0.13	
2ND STREET	23+21.57	-13.47	23+30.43	-29.66	0.19	WB	Waterborne/Solvent Paint	YLW2	x	х	х	0.33	
2ND STREET	23+21.57		23+94.82		1.83	вотн	Waterborne/Solvent Paint	ELY4	х			1.83	
2ND STREET	20+05.00	0	20+54.00	0	0.49	вотн	Waterborne/Solvent Paint	DCY4		х		0.98	
2ND STREET	20+54.00	0	2092	0	0.95	вотн	Waterborne/Solvent Paint	CHW8		х		1.9	
2ND STREET	23+91.00	0	24+38.00	0	1.19	вотн	Waterborne/Solvent Paint	CHW8		х		2.38	
2ND STREET	24+38.00	0	24+52.00	0	0.14	вотн	Waterborne/Solvent Paint	DCY4		х		0.28	







REV	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
			DRAWN	2ND & MULBERRY ROUNDABOUT
			JGS	
			CHECKED	PAVEMENT MARKINGS & SIGNS







	033 WINGIN BROTHERS BEVD 3W, 30HE ZA
	CEDAR RAPIDS, IOWA 52404
•	Phone: (319) 362-3219
	Email: CedarRapids@bolton-menk.com
	www.bolton-menk.com

	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
			JGS	2ND & MULBERRY ROUNDABOUT
_			CHECKED	SIDEWALK RAMP LAYOUT
			ALH	SIDEW/ (EK IV (IVII EX I OO)









855 WRIGHT BROTHERS BLVD SW, SUITE 2A	REV	ISSUED FOR	
CEDAR RAPIDS, IOWA 52404			Г
Phone: (319) 362-3219 Email: CedarRapids@bolton-menk.com			
www.bolton-menk.com			

REV	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
			JGS	2ND & MULBERRY ROUNDABOUT
			CHECKED	SIDEWALK RAMP LAYOUT

SHEET










CEDAR RAPIDS, IOWA 5240

Phone: (319) 362-3219

www.bolton-menk.com

SUITE 2A	REV	ISSUED FOR	DATE	JGS	CITY
04				JGS	2ND
nk.com				CHECKED	SID
				ALH	טוכ ן

9 & MULBERRY ROUNDABOUT
DEWALK RAMP LAYOUT










855 WRIGHT BROTHERS BLVD SW, SUITE 2A	REV	ISSUED FOR	DATE	JGS	CITY C
CEDAR RAPIDS, IOWA 52404 Phone: (319) 362-3219				JGS	2ND &
Email: CedarRapids@bolton-menk.com www.bolton-menk.com				CHECKED	SIDEV




Point	to Point	Sidewalk Designation	Distance*	Δ Elevation	Slope %	Legally Acceptable Range Pos. or Neg.	Difference between Designed Slope and Maximum Legally Acceptable Range	Acceptable Constructed Range Pos. or Neg.	Does Designer need to obtain design approval from Method's Engineer?	Staking Required on this Quadrant?	Measured Slope %	Initials Remarks	VALUE	FOR INFORMAT ES USED TO DETERM:) SLOPES
													Point	Station	Offset	Elevation
W3000	W3001	Ramp Running Slope	2.00	0.03	1.5%	0.5% to 8.3%	6.8%	0.5% to 8.3%					3000	7+81.49	9 8.41	556.77
W3001	W3002	Ramp Running Slope	1.95	0.03	1.5%	0.5% to 8.3%	6.8%	0.5% to 8.3%					3001	7+81.5	5 6.41	1 556.80
W3002	W3012	Landing/Turning Space	4.89	0.04	0.8%	0.1% to 2.0%	1.2%	0.1% to 2.0%					3002	7+81.63	3 4.46	6 556.83
W3012	W3003	Landing/Turning Space	4.71	0.03	0.6%	0.1% to 2.0%	1.4%	0.1% to 2.0%					3003	7+79.44	4 -4.88	556.90
W3003	W3004	Ramp Running Slope	1.86	0.03	1.6%	0.5% to 8.3%	6.7%	0.5% to 8.3%					3004	7+78.99	9 -6.68	556.93
W3004	W3005	Ramp Running Slope	2.00	0.02	1.0%	0.5% to 8.3%	7.3%	0.5% to 8.3%					3005	7+78.53	1 -8.62	556.95
W3005	W3006	Ramp Cross Slope	6.04	-0.08	-1.3%	0.1% to 2.0%	0.7%	0.1% to 2.0%					3006	7+72.64	4 -7.18	.8 556.87
W3006	W3007	Ramp Running Slope	2.00	-0.02	-1.0%	0.5% to 8.3%	7.3%	0.5% to 8.3%					3007	7+73.13	3 -5.24	4 556.85
W3007	W3008	Ramp Running Slope	1.62	-0.04	-2.5%	0.5% to 8.3%	5.8%	0.5% to 8.3%					3008	7+73.5	5 -3.68	556.81
W3008	W3013	Landing/Turning Space	4.89	-0.03	-0.6%	0.1% to 2.0%	1.4%	0.1% to 2.0%					3009	7+75.64	4 4.62	556.75
W3013	W3009	Landing/Turning Space	3.67	-0.03	-0.8%	0.1% to 2.0%	1.2%	0.1% to 2.0%					3010	7+75.59	9 6.26	556.73
W3009	W3010	Ramp Running Slope	1.64	-0.02	-1.2%	0.5% to 8.3%	7.1%	0.5% to 8.3%					3011	7+75.54	4 8.26	556.70
W3010	W3011	Ramp Running Slope	2.00	-0.03	-1.5%	0.5% to 8.3%	6.8%	0.5% to 8.3%					3012	7+80.52	2 -0.36	556.87
W3000	W3011	Ramp Cross Slope	5.95	-0.07	-1.2%	0.1% to 2.0%	0.8%	0.1% to 2.0%					3013	7+74.7	5 1.06	556.78
W3001	W3010	Ramp Cross Slope	5.96	-0.07	-1.2%	0.1% to 2.0%	0.8%	0.1% to 2.0%							1	
W3002	W3009	Ramp Cross Slope	5.99	-0.08	-1.3%	0.1% to 2.0%	0.7%	0.1% to 2.0%								
W3012	W3013	Ramp Cross Slope	5.93	-0.09	-1.5%	0.1% to 2.0%	0.5%	0.1% to 2.0%								
W3003	W3008	Ramp Cross Slope	6.01	-0.09	-1.5%	0.1% to 2.0%	0.5%	0.1% to 2.0%								
W3004	W3007	Ramp Cross Slope	6.03	-0.08	-1.3%	0.1% to 2.0%	0.7%	0.1% to 2.0%								
W3200	W3201	Ramp Running Slope	8.54	0.49	5.7%	0.5% to 8.3%	2.6%	0.5% to 8.3%					3200	781.03	26.31	556.29
W3205	W3204	Ramp Running Slope	7.98	0.49	6.1%	0.5% to 8.3%	2.2%	0.5% to 8.3%					3201	780.8	34.85	556.78
W3200	W3205	Ramp Cross Slope	5.84	-0.08	-1.4%	0.1% to 2.0%	0.6%	0.1% to 2.0%					3202	779.65	40.73	556.82
W3201	W3204	Landing/Turning Space	5.88	-0.08	-1.4%	0.1% to 2.0%	0.6%	0.1% to 2.0%					3203	774.1	39.68	556.76
W3201	W3202	Landing/Turning Space	5.99		0.7%	0.1% to 2.0%	1.3%	0.1% to 2.0%					3204	775.02	33.76	556.7
W3202	W3203	Landing/Turning Space	5.65		-1.1%	0.1% to 2.0%	0.9%	0.1% to 2.0%					3205	775.21	25.78	556.21
W3203	W3204	Landing/Turning Space	5.99		-1.0%	0.1% to 2.0%	1.0%	0.1% to 2.0%					3206	786.55	36.18	556.94
W3201	W3203	Landing/Turning Space	8.26	-0.02	-0.2%	0.1% to 2.0%	1.8%	0.1% to 2.0%					3207	792.22	37.73	557.09
W3202	W3204	Landing/Turning Space	8.37	-0.12	-1.4%	0.1% to 2.0%	0.6%	0.1% to 2.0%					3208	785.18	42.01	557.03
W3201	W3206	Sidewalk Running Slope	5.90	0.16	2.7%	0.5% to 5.0%	2.3%	0.5% to 5.0%					3209	790.64	43.5	557.18
W3202	W3208	Sidewalk Running Slope	5.68		3.7%	0.5% to 5.0%	1.3%	0.5% to 5.0%					3210	768.44	38.85	556.82
W3203	W3210	Sidewalk Running Slope	5.72		1.0%	0.5% to 5.0%	4.0%	0.5% to 5.0%					3211	762.7	38.06	556.74
W3204	W3212	Sidewalk Running Slope	5.87	0.04	0.7%	0.5% to 5.0%	4.3%	0.5% to 5.0%					3212	769.21	32.9	556.74
W3212	W3210	Sidewalk Cross Slope	6.00	0.08	1.3%	0.5% to 2.0%	0.7%	0.5% to 2.0%					3213	763.46	32.11	556.65
W3206	W3208	Sidewalk Cross Slope	5.99	0.09	1.5%	0.5% to 2.0%	0.5%	0.5% to 2.0%								





SUITE 2A	REV	ISSUED FOR	DATE	JGS	
)4				DRAWN	
				JGS	
nk.com				CHECKED	
				ALH	



Poliic	to Point	Sidemark hesignation	FT	FT	%	Range Pos. or Neg.		Constructed Range Pos. or Neg.	to obtain design approval from Method's Engineer?	Required on this	Slope %	INITIALS	V	ALUES USED TO DETE	RMINE DESIGNED	D SLOPES
													Poir	nt Station	Offset	Elevation
W3100	W3101	Ramp Running Slope	6.34	0.27	4.3%	0.5% to 8.3%	4.0%	0.5% to 8.3%					3100	774.08	-25.89	556.78
W3101	W3102	Ramp Running Slope	6.02	0.40	6.6%	0.5% to 8.3%	1.7%	0.5% to 8.3%					3101	772.52	-32.04	557.05
W3102	W3103	Sidewalk Running Slope	8.16	0.33	4.0%	0.5% to 5.0%	1.0%	0.5% to 5.0%					3102	770.99	-37.86	557.45
W3109	W3108	Ramp Running Slope	6.24	0.40	6.4%	0.5% to 8.3%	1.9%	0.5% to 8.3%					3103	769.04	-45.78	557.78
W3108	W3107	Ramp Running Slope	6.02	0.43	7.1%	0.5% to 8.3%	1.2%	0.5% to 8.3%					3104	766.76	-53.51	557.72
W3107	W3106	Sidewalk Running Slope	7.68	0.30	3.9%	0.5% to 5.0%	1.1%	0.5% to 5.0%					3105	760.78	-51.5	557.64
W3103	W3106	Landing/Turning Space	6.27	-0.08	-1.3%	0.1% to 2.0%	0.7%	0.1% to 2.0%					3106	763.09	-43.81	557.7
W3106	W3105	Landing/Turning Space	8.03	-0.06	-0.7%	0.1% to 2.0%	1.3%	0.1% to 2.0%					3107	764.96	-36.36	557.4
W3105	W3104	Landing/Turning Space	6.31	0.08	1.3%	0.1% to 2.0%	0.7%	0.1% to 2.0%					3108	766.52	-30.55	556.97
W3104	W3103	Landing/Turning Space	8.06	0.06	0.7%	0.1% to 2.0%	1.3%	0.1% to 2.0%					3109	768.12	-24.52	556.57
W3103	W3105	Landing/Turning Space	10.05	-0.14	-1.4%	0.1% to 2.0%	0.6%	0.1% to 2.0%					3110	774.96	-50.2	557.91
W3104	W3106	Landing/Turning Space	10.37	-0.02	-0.2%	0.1% to 2.0%	1.8%	0.1% to 2.0%					3111	772.45	-55.71	557.95
W3103	W3110	Sidewalk Running Slope	7.39	0.13	1.8%	0.5% to 5.0%	3.2%	0.5% to 5.0%					3112	752.87	-49.29	557.4
W3104	W3111	Sidewalk Running Slope	6.10	0.23	3.8%	0.5% to 5.0%	1.2%	0.5% to 5.0%					3113	754.45	-43.49	557.35
W3105	W3112	Sidewalk Running Slope	8.21	-0.24	-2.9%	0.5% to 5.0%	2.1%	0.5% to 5.0%								
W3106	W3113	Sidewalk Running Slope	8.65	-0.35	-4.0%	0.5% to 5.0%	1.0%	0.5% to 5.0%							-	
W3100	W3109	Crosswalk Cross Slope - No Yield Condition	6.12	-0.21	-3.4%	0.0% to 5.0%	1.6%	0.0% to 5.0%								
W3101	W3108	Ramp Cross Slope	6.18	-0.08	-1.3%	0.1% to 2.0%	0.7%	0.1% to 2.0%								[]
W3102	W3107	Ramp Cross Slope	6.21	-0.05	-0.8%	0.1% to 2.0%	1.2%	0.1% to 2.0%								
W3111	W3110	Sidewalk Cross Slope	6.05	-0.04	-0.7%	0.5% to 2.0%	1.3%	0.5% to 2.0%								[]
W3112	W3113	Sidewalk Cross Slope	6.01	-0.05	-0.8%	0.5% to 2.0%	1.2%	0.5% to 2.0%								








855 WRIGHT BROTHERS BLVD SW, SUITE 2A	REV	ISSUED FOR	DATE	JGS	
CEDAR RAPIDS, IOWA 52404 Phone: (319) 362-3219				JGS	Г
Email: CedarRapids@bolton-menk.com www.bolton-menk.com				CHECKED	Г
www.boitoil-menk.com				ALH	ı

JGS	CITY OF MUSCATINE, IOWA
JGS	2ND & MULBERRY ROUNDABOUT
CHECKED	SIDEWALK RAMP LAYOUT




					<u> </u>			/ / / / /	W.	////								
Point t	o Point	Sidewalk Designation	Distance*	Δ Elevation	Slope	Legally Acceptable Range	Difference between Designed Slope and Maximum Legally Acceptable Range	Acceptable Constructed Range	Does Designer need to obtain design approval from Method's Engineer?	Staking Required on this Quadrant?	Measured Slope	Initials	Remarks		VALUES	FOR INFORMATI S USED TO DETERMIN	NE DESIGNED	SLOPES
			FT	FT	%	Pos. or Neg.		Pos. or Neg.			%				Point	Station	Offset	Elevation
W4000	W4001	Landing/Turning Space	5.23	-0.04	-0.8%	0.1% to 2.0%	1.2%	0.1% to 2.0%						4	1000	21+66.40	-7.27	559.84
W4001	W4000	Landing/Turning Space	5.23	0.04	0.8%	0.1% to 2.0%	1.2%	0.1% to 2.0%						4	1001	21+67.55	-2.17	559.80
W4003	W4004	Landing/Turning Space	5.76	0.05	0.9%	0.1% to 2.0%	1.1%	0.1% to 2.0%						4	1002	21+66.38	2.27	
W4004	W4005	Landing/Turning Space	6.69	-0.04	-0.6%	0.1% to 2.0%	1.4%	0.1% to 2.0%						⊣ ⊢	1003	21+72.24	3.50	
W4000	W4005	Landing/Turning Space	5.99	-0.09	-1.5%	0.1% to 2.0%	0.5%	0.1% to 2.0%						4	1004	21+73.73	-2.06	
W4001	W4004	Landing/Turning Space	6.18	-0.01	-0.2%	0.1% to 2.0%	1.8%	0.1% to 2.0%						4	1005	21+72.24	-8.58	559.75
W4002	W4003	Landing/Turning Space	5.99	-0.06	-1.0%	0.1% to 2.0%	1.0%	0.1% to 2.0%									<u> </u>	
W4100	W4101	Ramp Running Slope	5.29	0.29	5.5%	0.5% to 8.3%	2.8%	0.5% to 8.3%						4:	1100			559.32
W4106	W4105	Ramp Running Slope	6.07	0.32	5.3%	0.5% to 8.3%	3.0%	0.5% to 8.3%						4:				559.61
W4100	W4106	Crosswalk Cross Slope - No Yield Condition	5.99	-0.11	-1.8%	0.0% to 5.0%	3.2%	0.0% to 5.0%						4:	1102	2156.99	30.14	559.54
W4101	W4105	Landing/Turning Space	6.22	-0.08	-1.3%	0.1% to 2.0%	0.7%	0.1% to 2.0%						4:				559.47
W4105	W4104	Landing/Turning Space	5.74	-0.07	-1.2%	0.1% to 2.0%		0.1% to 2.0%										559.46
W4104	W4103	Landing/Turning Space	6.00	0.01	0.2%	0.1% to 2.0%	1.8%	0.1% to 2.0%						4:	1105	2165.93		559.53
W4103	W4102	Landing/Turning Space	7.51	0.07	0.9%	0.1% to 2.0%		0.1% to 2.0%						4:				559.21
W4102	W4101	Landing/Turning Space	5.54	0.07	1.3%	0.1% to 2.0%	0.7%	0.1% to 2.0%						4:	1107			559.74
W4101	W4103	Landing/Turning Space	10.76	-0.14	-1.3%	0.1% to 2.0%								4:	1108	2150.66	28.65	559.78
W4104	W4102	Landing/Turning Space	10.20	0.08	0.8%	0.1% to 2.0%	1.2%	0.1% to 2.0%										Į.
W4102	W4108	Sidewalk Running Slope	6.50	0.24	3.7%	0.5% to 5.0%	1.3%	0.5% to 5.0%										Į.
W4101	W4107	Sidewalk Running Slope	9.47	0.13	1.4%	0.5% to 5.0%	3.6%	0.5% to 5.0%										
W4108	W4107	Sidewalk Cross Slope	5.87	-0.04	-0.7%	0.5% to 2.0%	1.3%											
W4200	W4201	Ramp Running Slope	4.01	0.23	5.7%	0.5% to 8.3%								4:				559.82
W4205	W4204	Ramp Running Slope	3.04	0.19	6.2%	0.5% to 8.3%		0.5% to 8.3%						4.	1201	2167.13		560.05
W4200	W4205	Crosswalk Cross Slope - No Yield Condition	6.02	-0.01	-0.2%	0.0% to 5.0%	4.8%	0.0% to 5.0%						4:				560.11
W4204	W4201	Landing/Turning Space	6.15	0.05	0.8%	0.1% to 2.0%	1.2%	0.1% to 2.0%						4:	1203			560.08
W4201	W4202	Landing/Turning Space	5.99	0.06	1.0%	0.1% to 2.0%	1.0%	0.1% to 2.0%						_			-28.75	560
W4202	W4203	Landing/Turning Space	5.46	-0.03	-0.5%	0.1% to 2.0%		0.1% to 2.0%						4:	1205	2162.12	-25.79	559.81
W4203	W4204	Landing/Turning Space	5.47	-0.08	-1.5%	0.1% to 2.0%												
W4202	W4204	Landing/Turning Space	7.95	-0.11	-1.4%	0.1% to 2.0%	0.6%	0.1% to 2.0%										
W4201	W4203	Landing/Turning Space	8.34	0.03	0.4%	0.1% to 2.0%	1.6%	0.1% to 2.0%										







E 2A	REV	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
				JGS	2ND & MULBERRY ROUNDABOUT
m				CHECKED	SIDEWALK RAMP LAYOUT



Point t	to Point	Sidewalk Designation	Distance*	Δ Elevation	Slope	Legally Acceptable Range		Acceptable Constructed Range	Does Designer need to obtain design approval from Method's Engineer?	Staking Required on this Quadrant?	Measured Slope	Initials	Remarks		FOR INFORMA VALUES USED TO DETER		D SLOPES
			FT	FT	%	Pos. or Neg.		Pos. or Neg.			%			P	oint Station	0ffset	Elevation
5200	5201	Ramp Running Slope	4.19	0.23	5.5%	0.5% to 8.3%	2.8%	0.5% to 8.3%						5200	1239.3	-29.99	574.04
5202	5206	Landing/Turning Space	3.13	0.04	1.3%	0.1% to 2.0%	0.7%	0.1% to 2.0%						5201	1235.11	-29.84	574.27
5206	5208	Landing/Turning Space	4.60	-0.06	-1.3%	0.1% to 2.0%	0.7%	0.1% to 2.0%						5202	1235.28	-28.44	574.26
5208	5209	Landing/Turning Space	1.93	-0.02	-1.0%	0.1% to 2.0%	1.0%	0.1% to 2.0%						5203	1231.92	-24.76	574.2
5209	5210	Landing/Turning Space	1.60	-0.01	-0.6%	0.1% to 2.0%	1.4%	0.1% to 2.0%						5204	1230.39	-24.98	574.18
5210	5207	Landing/Turning Space	4.42	-0.06	-1.4%	0.1% to 2.0%	0.6%	0.1% to 2.0%						5205	1230.47	-20.4	573.9
5207	5203	Landing/Turning Space	3.33	0.05	1.5%	0.1% to 2.0%	0.5%	0.1% to 2.0%						5206	1234.9	-31.55	574.3
5203	5202	Landing/Turning Space	4.98	0.06	1.2%	0.1% to 2.0%	0.8%	0.1% to 2.0%						5207	1228.62	-25.24	574.15
5204	5205	Ramp Running Slope	4.58	-0.28	-6.1%	0.5% to 8.3%	2.2%	0.5% to 8.3%						5208	1230.3	-31.5	574.24
5200	5205	Crosswalk Cross Slope - Yield Condition	13.04	-0.14	-1.1%	0.0% to 2.0%	0.9%	0.0% to 2.0%						5209	1230.24	-29.57	574.22
														5210	1228.64	-29.66	574.21
5300	5301	Ramp Running Slope	5.69	0.21	3.7%	0.5% to 8.3%	4.6%	0.5% to 8.3%						5300	1291.53	-20.25	574.57
5301	5302	Landing/Turning Space	6.15	0.08	1.3%	0.1% to 2.0%	0.7%	0.1% to 2.0%						5301	1290.3	-25.81	574.78
5302	5303	Landing/Turning Space	6.44	-0.08	-1.2%	0.1% to 2.0%	0.8%	0.1% to 2.0%						5302	1294.58	-30.22	574.86
5303	5304	Landing/Turning Space	6.14	-0.08	-1.3%	0.1% to 2.0%	0.7%	0.1% to 2.0%						5303	1289.96	-34.71	574.78
5304	5301	Landing/Turning Space	6.45	0.08	1.2%	0.1% to 2.0%	0.8%	0.1% to 2.0%						5304	1285.68	-30.31	574.7
5304	5305	Ramp Running Slope	5.49	-0.36	-6.6%	0.5% to 8.3%	1.7%	0.5% to 8.3%						5305	1280.42	-31.87	574.34
5302	5306	Sidewalk Running Slope	1.27	0.02	1.6%	0.5% to 5.0%	3.4%	0.5% to 5.0%						5306	1295.49	-29.34	574.88
5306	5307	Sidewalk Running Slope	3.84	0.08	2.1%	0.5% to 5.0%	2.9%	0.5% to 5.0%						5307	1299.33	-29.2	574.96
5300	5308	Sidewalk Running Slope	7.37	0.28	3.8%	0.5% to 5.0%	1.2%	0.5% to 5.0%						5308	1298.9	-20.48	574.85
5307	5308	Sidewalk Cross Slope	8.73	-0.11	-1.3%	0.5% to 2.0%	0.7%	0.5% to 2.0%									







ERS BLVD SW, SUITE 2A	REV	ISSUED FOR	
OS, IOWA 52404			
19) 362-3219			
ls@bolton-menk.com			-
on-menk.com			

ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
		JGS	2ND & MULBERRY ROUNDABOUT
		CHECKED	SIDEWALK RAMP LAYOUT
		ALH	SIDE WITCH LITTOUT

MULBERRY AVENUE







3RD STREET

Point to Point		Sidewalk Designation	Distance*	Δ Elevation	Slope	Legally Acceptable Range	Difference between Designed Slope and Maximum Legally Acceptable Range	Acceptable Constructed Range	Does Designer need to obtain design approval from Method's Engineer?	Staking Required on this Quadrant?	Measured Slope	Initials	Remarks		VALUES	FOR INFORMATI USED TO DETERMIN		SLOPES
			FT	FT	%	Pos. or Neg.		Pos. or Neg.			%	1			Point	Station	Offset	Elevation
5000	5001	Ramp Running Slope	5.53	0.32	5.8%	0.5% to 8.3%	2.5%	0.5% to 8.3%						500	30	1277.68	30.99	573.83
5001	5002	Landing/Turning Space	4.20	0.05	1.2%	0.1% to 2.0%	0.8%	0.1% to 2.0%						500	∂1	1283.21	30.81	574.15
5002	5003	Landing/Turning Space	2.72	0.01	0.4%	0.1% to 2.0%	1.6%	0.1% to 2.0%						500	∂2	1287.41	30.88	574.2
5003	5004	Landing/Turning Space	5.03	-0.05	-1.0%	0.1% to 2.0%	1.0%	0.1% to 2.0%						500	ð3	1289.63	29.31	574.21
5004	5006	Landing/Turning Space	2.99	-0.03	-1.0%	0.1% to 2.0%	1.0%	0.1% to 2.0%						500	∂4	1289.82	24.28	574.16
5006	5007	Landing/Turning Space	5.00	0.05	1.0%	0.1% to 2.0%	1.0%	0.1% to 2.0%						500	∂5	1290.09	18.97	574.02
5004	5005	Ramp Running Slope	5.32	-0.14	-2.6%	0.5% to 8.3%	5.7%	0.5% to 8.3%						500	∂6	1286.83	24.33	574.13
5005	5000	Crosswalk Cross Slope - Yield Condition	17.28	-0.19	-1.1%	0.0% to 2.0%	0.9%	0.0% to 2.0%						500	ð7	1283.26	27.83	574.18
5003	5010	Ramp Running Slope	8.66	0.54	6.2%	0.5% to 8.3%	2.1%	0.5% to 8.3%						500		1287.09	39.36	573.95
5005	5011	Ramp Running Slope	8.85	0.59	6.7%	0.5% to 8.3%	1.6%	0.5% to 8.3%						500	99	1277.63	39.8	573.55
5010	5013	Sidewalk Running Slope	9.02	0.36	4.0%	0.5% to 5.0%	1.0%	0.5% to 5.0%						501	10	1298.29	29.06	574.75
5011	5012	Sidewalk Running Slope	9.25	0.37	4.0%	0.5% to 5.0%	1.0%	0.5% to 5.0%						501	11	1298.94	19.19	574.61
5012	5013	Match Existing Cross Slope	10.22	0.13	1.3%	Match Existing	FALSE	Match Existing						501	12	1308.19	19.1	574.98
5011	5010	Sidewalk Cross Slope	9.89	0.14	1.4%	0.5% to 2.0%	0.6%	0.5% to 2.0%						501	13	1307.31	29.28	575.11
5002	5008	Sidewalk Running Slope	8.49	-0.25	-2.9%	0.5% to 5.0%	2.1%	0.5% to 5.0%								ļ		
5000	5009	Sidewalk Running Slope	8.81	-0.28	-3.2%	0.5% to 5.0%	1.8%	0.5% to 5.0%								ļ		
5008	5009	Match Existing Cross Slope	9.47	-0.40	-4.2%	Match Existing	FALSE	Match Existing								ļ		
																ļ	<u> </u>	
5100	5101	Ramp Running Slope	6.13	0.18	2.9%		5.4%	0.5% to 8.3%						510		1242.02		573.51
5101	5102	Landing/Turning Space	5.00	-0.06	-1.2%		0.8%	0.1% to 2.0%						510		1235.89	29.85	573.69
5102	5103	Landing/Turning Space	5.00	-0.01	-0.2%	0.1% to 2.0%	1.8%	0.1% to 2.0%						510		1230.89	29.86	573.63
5103	5105	Landing/Turning Space	5.00	0.06	1.2%	0.1% to 2.0%	0.8%	0.1% to 2.0%						510		1230.95	24.86	573.62
5103	5104	Ramp Running Slope	4.64	-0.27	-5.8%	0.5% to 8.3%	2.5%	0.5% to 8.3%						510		1231	20.22	573.35
5100	5106	Ramp Running Slope	5.30	-0.26	-4.9%	0.5% to 8.3%	3.4%	0.5% to 8.3%						510		1235.95	24.85	573.68
5102		Ramp Running Slope	4.72	-0.22	-4.7%		3.6%	0.5% to 8.3%						510		1242.04	35.13	573.25
5107	5106	Sidewalk Cross Slope	11.00	-0.16	-1.5%		0.5%	0.5% to 2.0%						510		1231.05	34.58	573.41
5102	5108	Sidewalk Running Slope	5.03	-0.20	-4.0%	0.5% to 5.0%	1.0%	0.5% to 5.0%						510		1225.87	29.54	573.43
5104	5109	Sidewalk Running Slope	5.46	-0.06	-1.1%	0.5% to 5.0%	3.9%	0.5% to 5.0%						510	39	1225.54	20.15	573.29
5109	5108	Sidewalk Cross Slope	9.40	0.14	1.5%	0.5% to 2.0%	0.5%	0.5% to 2.0%								ļ	<u> </u>	
5100	5104	Crosswalk Cross Slope - Yield Condition	14.62	-0.16	-1.1%	0.0% to 2.0%	0.9%	0.0% to 2.0%									<u> </u>	
																<u> </u>		







A	REV	ISSUED FOR	DATE	JGS	CITY OF MUSCATINE, IOWA
				JGS	2ND & MULBERRY ROUNDABOUT
				CHECKED ΔIH	SIDEWALK RAMP LAYOUT

GENERAL NOTES:

- UNDERGROUND UTILITIES: FIELD LOCATE UNDERGROUND UTILITIES PRIOR TO EXCAVATION FOR INSTALLATION OF SITE IMPROVEMENTS. IF A CONFLICT EXISTS BETWEEN PROPOSED SITE IMPROVEMENTS AND EXISTING OR PROPOSED UTILITIES, IMMEDIATELY ADVISE THE OWNERS REPRESENTATIVE.
- SPOT ELEVATIONS: WHERE SHOWN ON THESE DRAWINGS, SPOT ELEVATIONS ARE TO THE TOP OF FINISH SURFACES
- DIMENSIONS: DIMENSIONS ARE FROM BACK OF CURB UNLESS NOTED OR SHOWN OTHERWISE ON THE DRAWINGS.
 HORIZONTAL CONTROL: HORIZONTAL CONTROL FOR THE LAYOUT OF SITE IMPROVEMENTS WILL BE PROVIDED BY THE
- ENGINEER. STATIONS AND OFFSETS INDICATED ON THE DRAWINGS ARE RELATIVE TO THE ROADWAY STATIONING.
- ISOLATION JOINTS IN SIDEWALK PAVING: GENERALLY, ISOLATION JOINTS WILL BE LOCATED ALONG THE BACK OF CURB BETWEEN SIDEWALK PAVEMENTS AND PERMANENT STRUCTURES, WALLS AND BUILDINGS. ISOLATION JOINTS WILL ALSO BE LOCATED WHERE THE SIDEWALK PAVEMENT TURNS OR CHANGES DIRECTION. AND AT EVERY 100 FOOT MARK
- ALL SIDEWALKS AND CONCRETE SURFACES TO HAVE A LIGHT BROOM FINISH PERPENDICULAR TO DIRECTION OF TRAVEL UNLESS OTHERWISE NOTED, TYPICAL.
- SAWCUTS TO BE MADE AS SHOWN ON PLANS UNLESS CONTRACTOR SUBMITTAL OTHERWISE APPROVED BY OWNERS
- CONTRACTOR IS TO PRESERVE AND PROTECT EXISTING VEGETATION TO REMAIN AT ALL STAGES OF CONSTRUCTION. DAMAGED PLANT MATERIAL WILL BE REPLACED AT CONTRACTOR'S EXPENSE.
 CONTRACTOR IS TO PRESERVE AND PROTECT EXISTING BUILDINGS AND FOUNDATIONS AT ALL STAGES OF
- CONSTRUCTION
- 10. CONTRACTOR IS TO VERIFY THAT ALL SLOPES, CROSS SLOPES, LONGITUDINAL SLOPES, DROP CURB SLOPES, ETC. DO NOT EXCEED PROWAG MAXIMUMS. CONTRACTOR IS TO NOTIFY OWNER'S REPRESENTATIVE IF SLOPES EXCEED GUIDELINE RECOMMENDATIONS
- 11. HATCH PATTERNS ON PLAN DRAWINGS SHALL NOT BE USED FOR CONSTRUCTION OR SCALING PURPOSES. REFER TO CONSTRUCTION DETAILS FOR PAVER PATTERNS AND FINISHES.

GENERAL LANDSCAPE IMPROVEMENT NOTES:

- MASTER PLANT SCHEDULE: SHRUBS AND PERENNIALS ARE LISTED IN THE MASTER PLANT SCHEDULE. IF THERE IS A CONFLICT BETWEEN THE QUANTITIES SHOWN ON THE DRAWING AND THE QUANTITIES SHOWN IN THE PLANT SCHEDULE THE PLAN QUANTITIES SHALL PREVAIL
- PLANTING LAYOUT: LAYOUT A TYPICAL SHRUB AND PERENNIAL BED LAYOUT, AND OBTAIN APPROVAL OF THE LANDSCAPE ARCHITECT PRIOR TO PLANTING.
- SHRUB AND PERENNIAL GROUPINGS SHALL BE PLANTED AND MULCHED IN ONE CONTINUOUSLY
- 4. SOD ALL AREAS WHERE INDICATED ON DRAWINGS.

SPECIALTY SOIL TYPES AND NOTES:

- AMENDED PLANTING SOIL: INCIDENTAL TO PERENNIAL/GROUNDCOVER/SHRUB/TREE PLANTING TO DEPTHS SPECIFIED IN PLANTING/STREETSCAPE DETAILS ON U SHEETS
- PLANTING BACKFILL SHALL BE COMPOSED OF SUITABLE TOPSOIL AMENDED TO CONSIST OF 30% TOPSOIL,

SEEDING NOTES:

SUDAS TYPE 2 (PERMANENT COOL SEASON) MIX A. MIX AND INSTALLATION PER SUDAS SPECIFICATIONS

- B. APPLY COMMERCIAL FERTILIZER TO ALL SEEDED AREA AT THE RATE OF 450 POUNDS PER ACRE OF 13-13-13 (OR EQUIVALENT). INCORPORATE INTO THE TOP 2-3 INCHES OF TOPSOIL DURING SEEDBED
- ALL SLOPES 3.5:1 OR GREATER SHALL BE BLANKETED WITH TEMPORARY RECP, TYPE 2.C IMMEDIATELY FOLLOWING SEEDING
- ALL SEEDED AREAS NOT COVERED WITH RECP SHALL BE COVERED WITH HYDROMULCH AT RATE OF MIN. OF 2,600 POUNDS PER ACRE DRY WEIGHT. TACKIFIER SHALL BE INCORPORATED AT RATE OF 50 POUNDS PER ACRE.

LEGEND







SHRUBS/PERENNIALS/GRASSES/ANNUALS



SOD, LAWN



SEED, LAWN PAVER TYPE 'A'



PAVER TYPE 'B'



PAVER TYPE 'C'



STREET LIGHT POLE (NOT-IN-CONTRACT, TO BE USED FOR



FOOTING LOCATION ONLY) FOOTING IN CONTRACT



BOULDER SEATWALL

PAVER TYPE 'D', CROSSWALK PAVERS



STEEL BENCH



LITTER RECEPTACLE

Qty. Sym. Scientific Name

CONCRETE PAVER TYPES/NOTES

CONTRACTOR SHALL REVIEW/CONFIRM PAVER PATTERNS WITH ENGINEER PRIOR TO INSTALLATION

- TYPE "A". HISTORIC PAVER CITY FURNISHED TO CONTRACTOR FOR INSTALLATION, PATTERN: RUNNING BOND (SEE PLANS AND
- TYPE "B": UNILOCK SERIES 3000, 7.75" x 4" x 2.75" (20 CM x 10 CM x 7 CM), COLOR: ONYX BLACK, PATTERN: SOLDIER COURSE (SEE PLANS AND DETAILS)
- TYPE "C": UNILOCK ARTLINE, VARIABLE SIZES PER STANDARD LAYING PATTERN, 2.75" (7 CM) THICKNESS, PREMIER FINISH, COLOR: COPPER RIDGE
- TYPE "D": UNILOCK HOLLAND PREMIER, 7.75" x 4" x 3.25" (20 CM x 10 CM x 8 CM), COLOR: CHARCOAL, PREMIER FINISH, PATTERN: SOLDIER COURSE BORDER, 90 DEGREE HERRINGBONE FIELD (SEE PLANS AND DETAILS)

CONTACT

UNILOCK

301 E. SULLIVAN ROAD, AURORA, ILLINOIS 60505

Unit Size

Spacing Characteristics

BRAD PUNKE - TERRITORY MANAGER

O: 630-892-9191 EXT. 253 M: 847-489-0382

COLORED CONCRETE NOTES:

- COLORED CONCRETE SHALL BE INTEGRALLY COLORED, SELECTED FROM MANUFACTURER'S COLOR CHARTS SHOWING FULL RANGE OF COLORS AVAILABLE
- APPROVED INTEGRALLY COLORED CONCRETE INCLUDE DAVIS COLOR (800) 356-4848, CEMSTONE (651) 688-9292, SOLOMON COLORS (217) 522-3112, OR APPROVED EQUAL.
- CURING AND SEALING MATERIALS SHALL BE A PRODUCT FORMULATED TO PROTECT COLORED ARCHITECTURAL CONCRETE . PRODUCT SHALL BE 26% SOLIDS. NON-YELLOWING, CURE AND A SEAL MADE FROM PURE 100% ACRYLIC. SOLVENT SHALL BE CLEAR, DURABLE, ABRASION-, CHEMICAL-, WEATHER- AND UV-RESISTANT: ASTM C 309 TYPE 1 CLASS B, ASTM C-1315 TYPE 1 CLASS A, B, C. APPROVED MATERIALS INCLUDE TK BRIGHT KURE & SEAL. MATTE FINISH BY TK PRODUCTS (800) 441-2129. OR APPROVED EQUAL MATTE FINISH. SCHEDULE PLACEMENT TO MINIMIZE EXPOSURE TO WIND AND HOT SUN BEFORE CURING MATERIALS ARE APPLIED.
- ONLY ONE BRAND OF CEMENT SHALL BE USED UNLESS WRITTEN PERMISSION TO USE ANOTHER BRAND OF CEMENT IS GRANTED BY THE PROJECT MANAGER AND/OR OWNER REPRESENTATIVE.

QUALITY ASSURANCE:

- MANUFACTURER QUALIFICATIONS: MINIMUM 10 YEARS OF DOCUMENTED EXPERIENCE PRODUCING THE SPECIFIED PRODUCTS.
- INSTALLER QUALIFICATIONS: MINIMUM 5 YEARS OF DOCUMENTED EXPERIENCE WITH WORK OF SIMILAR SCOPE AND COMPLEXITY REQUIRED BY THIS PROJECT AND ACCEPTABLE TO, OR CERTIFIED BY, STAMPED CONCRETE PAVING MANUFACTURER.
- MATERIAL SOURCE: OBTAIN EACH SPECIFIED MATERIAL FROM THE SAME SOURCE TO ENSURE CONSISTENCY AND UNIFORMITY
- NOTIFICATION: GIVE A MINIMUM 7 CALENDAR DAYS' NOTICE TO MANUFACTURER'S AUTHORIZED FIELD REPRESENTATIVE BEFORE DATE ESTABLISHED FOR COMMENCEMENT OF WORK.

REQUIRED MOCK-UP:

- CONTRACTOR SHALL CONSTRUCT A MINIMUM 10 FOOT BY 10 FOOT MOCKUP AT LOCATION SELECTED BY OWNER.
- PROVIDE INDIVIDUAL MOCKUPS FOR EACH COLOR REQUIRED.

 MOCKUP CAN BE PART OF FINAL PROJECT IF, IN THE JUDGEMENT OF THE OWNER, PAVEMENT IS ACCEPTABLE.
- CONSTRUCT MOCKUP USING MATERIALS, PROCESSES, AND TECHNIQUES REQUIRED FOR THE WORK, INCLUDING CURING PROCEDURES. INCORPORATE REPRESENTATIVE CONTROL, CONSTRUCTION, AND EXPANSION JOINTS ACCORDING TO PROJECT REQUIREMENTS. INSTALLER FOR THE WORK TO CONSTRUCT MOCKUP.
- NOTIFY OWNER A MINIMUM OF SEVEN CALENDAR DAYS IN ADVANCE OF THE DATE SCHEDULED FOR EACH MOCKUP CONSTRUCTION.
- OBTAIN THE OWNER'S ACCEPTANCE OF EACH MOCKUP PRIOR TO COMMENCEMENT OF THE WORK.
- EACH MOCKUP TO REMAIN UNTIL COMPLETION OF THE WORK TO SERVE AS A QUALITY CONTROL STANDARD FOR THE WORK. PROVIDE SUITABLE PROTECTIONS TO PRECLUDE DAMAGE TO MOCKUP
- DEMOLISH AND REMOVE EACH MOCKUP FROM SITE WHEN DIRECTED

- SEAK ALL COLORED CONCRETE WITH LIQUID MEMBRANE CURING AND SEALING COMPOUNDS AS RECOMMENDED BY MANUFACTURER
- APPLY TWO COATS OF SPECIFIED CURING AND SEALING COMPOUND ACCORDING TO MANUFACTURER'S WRITTEN INSTRUCTIONS.
- 7.3. PRIOR TO SEALING. THE FOLLOWING CONDITIONS MUST BE PRESENT RELEASE AGENT HAS BEEN REMOVED. 7.3.1.
- MOISTURE CONTENT OF CONCRETE IS LOW ENOUGH THAT ALKALI AND OTHER SALTS DO NOT BECOME TRAPPED BENEATH SEALER. THIS WILL REQUIRE A MINIMUM OF 28 DAYS SUBSEQUENT TO CONCRETE PLACEMENT, OR LONGER IF
- NO EVIDENCE OF FREE WATER ON CONCRETE SURFACES TO RECEIVE CURING AND SEALING COMPOUND

MASTER PLANT SCHEDULE (refer to plan drawings for locations)


	Trees				
2 QB	Quercus bicolor	Swamp White Oak	EA	2" B&B	see plan Balled & Burlapped
2 AF	Acer x freemanii Sienna	Sienna Glen Maple	EA	2" B&B	see plan Balled & Burlapped
2 CO	Celtis occidentalis	Hackberry	EA	2" B&B	see plan Balled & Burlapped
4 SR	Syringa reticulata 'Ivory Silk'	lvory Silk Japanese Tree Lilac	EA	1.5" B&B	see plan Balled & Burlapped
2 MP	Malus sp. 'Prairiefire'	Prairiefire Crab	EA	1.5" B&B	see plan Balled & Burlapped
2 CC	Crataegus crus-galli (thornless form)	Thornless Cockspur Hawthorn	EA	1.5" B&B	see plan Balled & Burlapped
4 GT	Gleditsia triacanthos 'Shademaster'	Shademaster Honeylocust	EA	2" B&B	see plan Balled & Burlapped
2 GTS	Gleditsia triacanthos 'Skyline'	Skyline Honeylocust	EA	2" B&B	see plan Balled & Burlapped
2 UF	Ulmus 'Frontier'	Frontier Elm	EA	2" B&B	see plan Balled & Burlapped
4 UA	Ulmus americana 'New Harmony'	New Harmony Elm	EA	2" B&B	see plan Balled & Burlapped
	Shrubs				
19 RA	Rhus aromatica 'Gro-Low'	Grow-Low Fragrant Sumac	EA	3 gal.	see plan
	Perennials				
88 SA	Sedum x 'Autumn Joy'	Autumn Joy Sedum	EA	1 gal.	see plan
64 SM	Salvia x sylvestris 'May Night'	Salvia May Night	EA	1 gal.	see plan
113 LS	Liatris spicata 'Kobold'	Kobold Liatris	EA	1 gal.	see plan
24 NR	Nepeta racemosa	Walker's Low Catmint	EA	1 gal.	see plan
34 DF	Dianthus Feurhexe 'Firewitch'	Firewitch Dianthus	EA	1 gal.	see plan
	Perennial Grasses				
147 SH	Sporobolus heterolepis	Prairie Dropseed	EA	1 gal.	see plan
88 KF	Calamagrostis x acutiflora 'Karl Foerster'	Feather Reed Grass	EA	1 gal.	see plan


Common Name








REV	ISSUED FOR	DATE	DESIGNED	CITY OF MUSCATINE, IOWA
			DRAWN XXX	2ND & MULBERRY ROUNDABOUT
			CHECKED	LANDSCAPE PLAN



















2 TYPICAL SECTION: CONCRETE SIDEWALK AT BUILDING/WALL EDGE




3 TYPICAL SECTION: CONCRETE SIDEWALK JOINTS - SAWCUT, ISOLATION/EXPANSION SCALE: N.T.S.












NOTES:


- 1. IN PEDESTRIAN CROSSINGS, CONCRETE PAVEMENT SHALL BE PLACED WITHIN CROSSWALK AREAS IN CONJUNCTION WITH STREET PAVING OPERATIONS. THE EDGES OF THE CONCRETE PAVER CROSSWALKS SHALL THEN BE SAW CUT FULL-DEPTH AND THE CONCRETE REMOVED FOR THE PLACEMENT OF CONCRETE PAVERS AND CONCRETE BASE.
- 2. PAYMENT FOR CONCRETE PAVEMENT GREATER THAN 10" THICK ADJACENT TO CROSSWALK AND OTHER STREET PAVERS WILL BE AT THE UNIT PRICE BID FOR 10" CONCRETE PAVEMENT
- 3. PAYMENT FOR CONCRETE PAVEMENT PLACED AND SUBSEQUENTLY REMOVED WILL BE AT THE UNIT PRICE BID FOR 10" CONCRETE PAVEMENT. SAW CUTTING AND REMOVAL SHALL BE INCLUDED IN THE UNIT PRICE BID FOR 'CROSSWALK PAVERS W/ 6" CONCRETE BASE'







8 SECTION: SIDEWALK / MEDIAN CONCRETE UNIT PAVERS





9 SECTION: CROSSWALK CONCRETE UNIT PAVERS
SCALE: 1"=1'-0"





WRIGHT BROTHERS BLVD SW, SUITE 2A	REV	ISSUED FOR	DATE	DESIGNED	CITY OF MUSCATINE, IOWA
CEDAR RAPIDS, IOWA 52404 Phone: (319) 362-3219				DRAWN	2ND & MULBERRY ROUNDABOUT
nail: CedarRapids@bolton-menk.com www.bolton-menk.com				CHECKED	LANDSCAPE DETAILS





BOULDER SEATWALL MATERIAL TO MATCH MISSISSIPPI DRIVE SEATWALL. -LIMESTONE OUTCROPPING BLOCK

-SPLITFACE FRONT/BACK -NATURAL TOP/BOTTOM, WITH SAWN/ MITERED JOINTS AS REQUESTED TO FIT RADIUS.

PROVIDE SHOP DRAWINGS.


BOULDER SEATWALL DIMENSIONS: *RADIUS TO FRONT FACE OF WALL

SEATWALL 'A': RADIUS=10', LENGTH=13.5' SEATWALL 'B': RADIUS=10', LENGTH=9.5'

LIMESTONE OUTCROPPING BOULDER, 18" HT, LENGTH VARIES 18"-30" TO MAINTAIN CONSISTENT FACE OF WALL RADIUS #4 REBAR, 12", 4' O.C.— CONCRETE BAND, SEE--6" EPOXY COATED PIN, PLANS 2 PINS PER BLOCK プロン アピス CONCRETE BAND EXTENDED EXPANSION JOINT -PCC PAVER BASE, BENEATH BOULDER THICKENED EDGE SEATWALL, TO BE PAID IN SIDEWALK CONCRETE -UNIT PAVERS CONCRETE BAND BID ITEM LANDSCAPE BED -COMPACTED AGGREGATE SUBBASE, INCIDENTAL

2 SECTION: BOULDER SEATWALLS
SCALE: 1"=1'-0"

PLAN VIEW - TYPICAL SEATWALL








5 WRIGHT BROTHERS BLVD SW, SUITE 2A	
CEDAR RAPIDS, IOWA 52404	
Phone: (319) 362-3219	
mail: CedarRapids@bolton-menk.com	
www.bolton-menk.com	


ISSUED FOR	DATE	DESIGNED	CITY OF MUSCATINE, IOWA
		DRAWN	2ND & MULBERRY ROUNDABOUT
		CHECKED	LANDSCAPE DETAILS


SHEET U.03





- NOTES:

 1. O.C. TRIANGULAR PLANT SPACING PER PLANS
 2. AREAS IDENTIFIED ON PLANTING PLAN AS O.C. SHALL BE TRIANGULAR SPACED
- 3. SEE PLANTING PLAN/SCHEDULE FOR SPECIES









PLANTING EDGE AT CONC. WALK
SCALE: N.T.S.



	ISSUED FOR	DATE	DESIGNED	CITY OF MUSCATINE, IOWA
			DRAWN XXX	2ND & MULBERRY ROUNDABOUT
			CHECKED	LANDSCAPE DETAILS
_			ALH	LANDSCAI E DETAILS